



October 28, 2016

Dear Young families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Young samples were tested from 46 sites and the water sampled from three drinking fountains and two sinks were above the action level of 15 ppb: two drinking fountains in Building A on the second floor on the East End, a fountain in Building A on the second floor outside of Storage Room 210C, and two sinks in Building A on the second floor inside Storage Rooms 251B and 25C. The water from the sinks and fountains have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. Five of the samples at Young returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for those sinks and fountains and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





28 de octubre de 2016

Estimadas familias de la escuela Young,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Young se tomaron muestras en 46 lugares y el agua de tres bebederos y dos fuentes tenía rastros de plomo por encima del nivel de acción de 15 ppb: dos bebederos del Edificio A, en el este del segundo piso, uno en el Edificio A, segundo piso afuera del salón 210 C de depósito. Dos piletas, también en el segundo piso del Edificio A, dentro de los salones 251B y 25C de depósito. El suministro de agua de los dispositivos fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente cinco de las muestras de Young registraron niveles elevados. Este no es problema general, sino específico de las cañerías de esos dispositivos, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Young HS-Building A**

Date of test 10/14/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Young HS-Building A	51568	51568-B-KIT-KS01-01	Kitchen	6:20AM	1.1	BA
Young HS-Building A	51568	51568-B-KIT-KS01-02	Kitchen	6:20AM	0.92	BA
Young HS-Building A	51568	51568-B-KIT-KS01-03	Kitchen	6:20AM	0.36	BA
Young HS-Building A	51568	51568-B-KIT-KS01-04	Kitchen	6:20AM	0.23	BA
Young HS-Building A	51568	51568-B-KIT-KS01-05	Kitchen	6:20AM	0.27	BA
Young HS-Building A	51568	51568-B-HAL-F01-01	Hall Outside Engineer Office	6:25AM	0.29	BA
Young HS-Building A	51568	51568-B-HAL-F01-02	Hall Outside Engineer Office	6:25AM	0.28	BA
Young HS-Building A	51568	51568-B-HAL-F01-03	Hall Outside Engineer Office	6:25AM	0.31	BA
Young HS-Building A	51568	51568-B-HAL-F01-04	Hall Outside Engineer Office	6:25AM	0.34	BA
Young HS-Building A	51568	51568-B-HAL-F01-05	Hall Outside Engineer Office	6:25AM	0.32	BA
Young HS-Building A	51568	51568-2-HAL-F01-01	Hall in East Dining Area Left	6:30AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F01-02	Hall in East Dining Area Left	6:30AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F01-03	Hall in East Dining Area Left	6:30AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F01-04	Hall in East Dining Area Left	6:30AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F01-05	Hall in East Dining Area Left	6:30AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F03-01	Left Fountain East end of FL	6:35AM	17	AA
Young HS-Building A	51568	51568-2-HAL-F03-02	Left Fountain East end of FL	6:35AM	22	AA
Young HS-Building A	51568	51568-2-HAL-F03-03	Left Fountain East end of FL	6:35AM	24	AA
Young HS-Building A	51568	51568-2-HAL-F03-04	Left Fountain East end of FL	6:35AM	15	AA

Young HS-Building A	51568	51568-2-HAL-F03-05	Left Fountain East end of FL	6:35AM	13	BA
Young HS-Building A	51568	51568-2-HAL-F04-01	Right Fountain East End of FL	6:40AM	15	AA
Young HS-Building A	51568	51568-2-HAL-F04-02	Right Fountain East End of FL	6:40AM	12	BA
Young HS-Building A	51568	51568-2-HAL-F04-03	Right Fountain East End of FL	6:40AM	12	BA
Young HS-Building A	51568	51568-2-HAL-F04-04	Right Fountain East End of FL	6:40AM	9.1	BA
Young HS-Building A	51568	51568-2-HAL-F04-05	Right Fountain East End of FL	6:40AM	8.2	BA
Young HS-Building A	51568	51568-2-HAL-WC01-01	Hall in East Dining Area	6:43AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC01-02	Hall in East Dining Area	6:43AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC01-03	Hall in East Dining Area	6:43AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC01-04	Hall in East Dining Area	6:43AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC01-05	Hall in East Dining Area	6:43AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F02-01	Hall in East Dining Area Right	6:45AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F02-02	Hall in East Dining Area Right	6:45AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F02-03	Hall in East Dining Area Right	6:45AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F02-04	Hall in East Dining Area Right	6:45AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F02-05	Hall in East Dining Area Right	6:45AM	<0.50	BA
Young HS-Building A	51568	51568-2-251B-S01-01	RM 251B Storage	6:50AM	0.73	BA
Young HS-Building A	51568	51568-2-251B-S01-02	RM 251B Storage	6:50AM	16	AA
Young HS-Building A	51568	51568-2-251B-S01-03	RM 251B Storage	6:50AM	8.4	BA
Young HS-Building A	51568	51568-2-251B-S01-04	RM 251B Storage	6:50AM	1.5	BA
Young HS-Building A	51568	51568-2-251B-S01-05	RM 251B Storage	6:50AM	0.47	BA
Young HS-Building A	51568	51568-2-HAL-WC02-01	Hall outside West Dining Area	6:55AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC02-02	Hall outside West Dining Area	6:55AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC02-03	Hall outside West Dining Area	6:55AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC02-04	Hall outside West Dining Area	6:55AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-WC02-05	Hall outside West Dining Area	6:55AM	<0.50	BA

Young HS-Building A	51568	51568-2-HAL-F06-01	Hall outside West Dining Area Right Fountain	7:00AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F06-02	Hall outside West Dining Area Right Fountain	7:00AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F06-03	Hall outside West Dining Area Right Fountain	7:00AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F06-04	Hall outside West Dining Area Right Fountain	7:00AM	<0.50	BA
Young HS-Building A	51568	51568-2-HAL-F06-05	Hall outside West Dining Area Right Fountain	7:00AM	<0.50	BA
Young HS-Building A	51568	51568-2-210C-S02-01	rm 210C Storage	7:05AM	170	AA
Young HS-Building A	51568	51568-2-210C-S02-02	rm 210C Storage	7:05AM	26	AA
Young HS-Building A	51568	51568-2-210C-S02-03	rm 210C Storage	7:05AM	10	BA
Young HS-Building A	51568	51568-2-210C-S02-04	rm 210C Storage	7:05AM	7.7	BA
Young HS-Building A	51568	51568-2-210C-S02-05	rm 210C Storage	7:05AM	4.5	BA
Young HS-Building A	51568	51568-2-HAL-F07-01	Hall outside Storage RM Left	7:10AM	0.96	BA
Young HS-Building A	51568	51568-2-HAL-F07-02	Hall outside Storage RM Left	7:10AM	74	AA
Young HS-Building A	51568	51568-2-HAL-F07-03	Hall outside Storage RM Left	7:10AM	0.64	BA
Young HS-Building A	51568	51568-2-HAL-F07-04	Hall outside Storage RM Left	7:10AM	0.64	BA
Young HS-Building A	51568	51568-2-HAL-F07-05	Hall outside Storage RM Left	7:10AM	0.6	BA
Young HS-Building A	51568	51568-2-HAL-F08-01	Hall outside Storage RM Right	7:15AM	0.61	BA
Young HS-Building A	51568	51568-2-HAL-F08-02	Hall outside Storage RM Right	7:15AM	0.64	BA
Young HS-Building A	51568	51568-2-HAL-F08-03	Hall outside Storage RM Right	7:15AM	0.57	BA
Young HS-Building A	51568	51568-2-HAL-F08-04	Hall outside Storage RM Right	7:15AM	0.47	BA
Young HS-Building A	51568	51568-2-HAL-F08-05	Hall outside Storage RM Right	7:15AM	0.37	BA
Young HS-Building A	51568	51568-1-HAL-F01-01	Main Entrance Left Fountain	7:20AM	0.71	BA
Young HS-Building A	51568	51568-1-HAL-F01-02	Main Entrance Left Fountain	7:20AM	0.2	BA
Young HS-Building A	51568	51568-1-HAL-F01-03	Main Entrance Left Fountain	7:20AM	0.6	BA
Young HS-Building A	51568	51568-1-HAL-F01-04	Main Entrance Left Fountain	7:20AM	0.64	BA
Young HS-Building A	51568	51568-1-HAL-F01-05	Main Entrance Left Fountain	7:20AM	0.27	BA
Young HS-Building A	51568	51568-1-HAL-WC01-01	Main Entrance Water Cooler	7:25AM	<0.50	BA

Young HS-Building A	51568	51568-1-HAL-WC01-02	Main Entrance Water Cooler	7:25AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-WC01-03	Main Entrance Water Cooler	7:25AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-WC01-04	Main Entrance Water Cooler	7:25AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-WC01-05	Main Entrance Water Cooler	7:25AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F02-01	Main Entrance Right Fountain	7:30AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F02-02	Main Entrance Right Fountain	7:30AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F02-03	Main Entrance Right Fountain	7:30AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F02-04	Main Entrance Right Fountain	7:30AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F02-05	Main Entrance Right Fountain	7:30AM	<0.50	BA
Young HS-Building A	51568	51568-1-HAL-F03-01	Outside RM 128-Attendance office	7:35AM	4.1	BA
Young HS-Building A	51568	51568-1-HAL-F03-02	Outside RM 128-Attendance office	7:35AM	4.4	BA
Young HS-Building A	51568	51568-1-HAL-F03-03	Outside RM 128-Attendance office	7:35AM	3.2	BA
Young HS-Building A	51568	51568-1-HAL-F03-04	Outside RM 128-Attendance office	7:35AM	2.5	BA
Young HS-Building A	51568	51568-1-HAL-F03-05	Outside RM 128-Attendance office	7:35AM	2.5	BA
Young HS-Building A	51568	51568-1-HAL-F04-01	Outside Counseling Dept	7:40AM	0.66	BA
Young HS-Building A	51568	51568-1-HAL-F04-02	Outside Counseling Dept	7:40AM	0.54	BA
Young HS-Building A	51568	51568-1-HAL-F04-03	Outside Counseling Dept	7:40AM	0.67	BA
Young HS-Building A	51568	51568-1-HAL-F04-04	Outside Counseling Dept	7:40AM	0.7	BA
Young HS-Building A	51568	51568-1-HAL-F04-05	Outside Counseling Dept	7:40AM	0.75	BA
Young HS-Building A	51568	51568-1-HAL-F05-01	Entrance 3	7:45AM	2.1	BA
Young HS-Building A	51568	51568-1-HAL-F05-02	Entrance 3	7:45AM	1.7	BA
Young HS-Building A	51568	51568-1-HAL-F05-03	Entrance 3	7:45AM	1.4	BA
Young HS-Building A	51568	51568-1-HAL-F05-04	Entrance 3	7:45AM	1.2	BA
Young HS-Building A	51568	51568-1-HAL-F05-05	Entrance 3	7:45AM	1.3	BA
Young HS-Building A	51568	51568-3-HAL-F01-01	South East Corner of Hall Left Fount	8:00AM	2.1	BA
Young HS-Building A	51568	51568-3-HAL-F01-02	South East Corner of Hall Left Fount	8:00AM	0.67	BA

Young HS-Building A	51568	51568-3-HAL-F01-03	South East Corner of Hall Left Fount	8:00AM	1.1	BA
Young HS-Building A	51568	51568-3-HAL-F01-04	South East Corner of Hall Left Fount	8:00AM	1.4	BA
Young HS-Building A	51568	51568-3-HAL-F01-05	South East Corner of Hall Left Fount	8:00AM	1.5	BA
Young HS-Building A	51568	51568-3-HAL-F02-01	Southeast Corner of Hall Right Fount	8:05AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-F02-02	Southeast Corner of Hall Right Fount	8:05AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-F02-03	Southeast Corner of Hall Right Fount	8:05AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-F02-04	Southeast Corner of Hall Right Fount	8:05AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-F02-05	Southeast Corner of Hall Right Fount	8:05AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-WC01-01	Southeast Corner of Hall Water Cooler	8:10AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-WC01-02	Southeast Corner of Hall Water Cooler	8:10AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-WC01-03	Southeast Corner of Hall Water Cooler	8:10AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-WC01-04	Southeast Corner of Hall Water Cooler	8:10AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-WC01-05	Southeast Corner of Hall Water Cooler	8:10AM	<0.50	BA
Young HS-Building A	51568	51568-3-HAL-F05-01	North West End of Hall left	8:15AM	1.6	BA
Young HS-Building A	51568	51568-3-HAL-F05-02	North West End of Hall left	8:15AM	1.3	BA
Young HS-Building A	51568	51568-3-HAL-F05-03	North West End of Hall left	8:15AM	1	BA
Young HS-Building A	51568	51568-3-HAL-F05-04	North West End of Hall left	8:15AM	0.79	BA
Young HS-Building A	51568	51568-3-HAL-F05-05	North West End of Hall left	8:15AM	0.6	BA
Young HS-Building A	51568	51568-3-HAL-F06-01	North West End of Hall Right Fount	8:20AM	2.3	BA
Young HS-Building A	51568	51568-3-HAL-F06-02	North West End of Hall Right Fount	8:20AM	1	BA
Young HS-Building A	51568	51568-3-HAL-F06-03	North West End of Hall Right Fount	8:20AM	0.78	BA
Young HS-Building A	51568	51568-3-HAL-F06-04	North West End of Hall Right Fount	8:20AM	0.68	BA
Young HS-Building A	51568	51568-3-HAL-F06-05	North West End of Hall Right Fount	8:20AM	0.66	BA
Young HS-Building A	51568	51568-3-HAL-F07-01	Northeast End of Hall Left	8:15AM	2.1	BA
Young HS-Building A	51568	51568-3-HAL-F07-02	Northeast End of Hall Left	8:15AM	2.5	BA
Young HS-Building A	51568	51568-3-HAL-F07-03	Northeast End of Hall Left	8:15AM	2.7	BA

Young HS-Building A	51568	51568-3-HAL-F07-04	Northeast End of Hall Left	8:15AM	2.4	BA
Young HS-Building A	51568	51568-3-HAL-F07-05	Northeast End of Hall Left	8:15AM	1.8	BA
Young HS-Building A	51568	51568-3-HAL-F08-01	Northeast End of Hall Right	8:20AM	1.8	BA
Young HS-Building A	51568	51568-3-HAL-F08-02	Northeast End of Hall Right	8:20AM	1.5	BA
Young HS-Building A	51568	51568-3-HAL-F08-03	Northeast End of Hall Right	8:20AM	1.5	BA
Young HS-Building A	51568	51568-3-HAL-F08-04	Northeast End of Hall Right	8:20AM	1.5	BA
Young HS-Building A	51568	51568-3-HAL-F08-05	Northeast End of Hall Right	8:20AM	1.4	BA
Young HS Building B	52376	52376-1-POL-F01-01	East Side pool area	7:05AM	1.4	BA
Young HS Building B	52376	52376-1-POL-F01-02	East Side pool area	7:05AM	0.72	BA
Young HS Building B	52376	52376-1-POL-F01-03	East Side pool area	7:05AM	0.68	BA
Young HS Building B	52376	52376-1-POL-F01-04	East Side pool area	7:05AM	0.61	BA
Young HS Building B	52376	52376-1-POL-F01-05	East Side pool area	7:05AM	0.57	BA
Young HS Building B	52376	52376-1-POL-F02-01	West End of Pool	7:10AM	0.21	BA
Young HS Building B	52376	52376-1-POL-F02-02	West End of Pool	7:10AM	0.23	BA
Young HS Building B	52376	52376-1-POL-F02-03	West End of Pool	7:10AM	0.22	BA
Young HS Building B	52376	52376-1-POL-F02-04	West End of Pool	7:10AM	0.22	BA
Young HS Building B	52376	52376-1-POL-F02-05	West End of Pool	7:10AM	0.21	BA
Young HS Building B	52376	52376-1-HAL-F03-01	Gym Hall 3rd Fountain	7:15AM	0.74	BA
Young HS Building B	52376	52376-1-HAL-F03-02	Gym Hall 3rd Fountain	7:15AM	0.47	BA
Young HS Building B	52376	52376-1-HAL-F03-03	Gym Hall 3rd Fountain	7:15AM	0.42	BA
Young HS Building B	52376	52376-1-HAL-F03-04	Gym Hall 3rd Fountain	7:15AM	0.39	BA
Young HS Building B	52376	52376-1-HAL-F03-05	Gym Hall 3rd Fountain	7:15AM	0.51	BA
Young HS Building B	52376	52376-1-HAL-F04-01	Gym Hall 4th Fountain	7:20AM	0.34	BA
Young HS Building B	52376	52376-1-HAL-F04-02	Gym Hall 4th Fountain	7:20AM	0.25	BA
Young HS Building B	52376	52376-1-HAL-F04-03	Gym Hall 4th Fountain	7:20AM	0.23	BA
Young HS Building B	52376	52376-1-HAL-F04-04	Gym Hall 4th Fountain	7:20AM	0.27	BA

Young HS Building B	52376	52376-1-HAL-F04-05	Gym Hall 4th Fountain	7:20AM	0.17	BA
Young HS Building B	52376	52376-1-HAL-F05-01	Gym Hall 5th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F05-02	Gym Hall 5th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F05-03	Gym Hall 5th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F05-04	Gym Hall 5th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F05-05	Gym Hall 5th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F06-01	Gym Hall 6th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F06-02	Gym Hall 6th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F06-03	Gym Hall 6th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F06-04	Gym Hall 6th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-F06-05	Gym Hall 6th Fountain	7:25AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC01-01	Gym Hall Left Water Cooler	7:30AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC01-02	Gym Hall Left Water Cooler	7:30AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC01-03	Gym Hall Left Water Cooler	7:30AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC01-04	Gym Hall Left Water Cooler	7:30AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC01-05	Gym Hall Left Water Cooler	7:30AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC02-01	Gym Hall Right Water Cooler	7:35AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC02-02	Gym Hall Right Water Cooler	7:35AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC02-03	Gym Hall Right Water Cooler	7:35AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC02-04	Gym Hall Right Water Cooler	7:35AM	<0.50	BA
Young HS Building B	52376	52376-1-HAL-WC02-05	Gym Hall Right Water Cooler	7:35AM	<0.50	BA
Young HS Building B	52376	52376-1-CGYM-F01-01	C Gym South Entrance	7:40AM	2.5	BA
Young HS Building B	52376	52376-1-CGYM-F01-02	C Gym South Entrance	7:40AM	1.8	BA
Young HS Building B	52376	52376-1-CGYM-F01-03	C Gym South Entrance	7:40AM	1.7	BA
Young HS Building B	52376	52376-1-CGYM-F01-04	C Gym South Entrance	7:40AM	1.6	BA
Young HS Building B	52376	52376-1-CGYM-F01-05	C Gym South Entrance	7:40AM	1.7	BA

Young HS Building B	52376	52376-1-CGYM-F02-01	C Gym North Entrance	7:45AM	1.6	BA
Young HS Building B	52376	52376-1-CGYM-F02-02	C Gym North Entrance	7:45AM	1.2	BA
Young HS Building B	52376	52376-1-CGYM-F02-03	C Gym North Entrance	7:45AM	1.6	BA
Young HS Building B	52376	52376-1-CGYM-F02-04	C Gym North Entrance	7:45AM	1.4	BA
Young HS Building B	52376	52376-1-CGYM-F02-05	C Gym North Entrance	7:45AM	1.5	BA
Young HS Building B	52376	52376-B-HAL-F01-01	Basement Hall	7:50AM	1	BA
Young HS Building B	52376	52376-B-HAL-F01-02	Basement Hall	7:50AM	0.84	BA
Young HS Building B	52376	52376-B-HAL-F01-03	Basement Hall	7:50AM	0.84	BA
Young HS Building B	52376	52376-B-HAL-F01-04	Basement Hall	7:50AM	0.9	BA
Young HS Building B	52376	52376-B-HAL-F01-05	Basement Hall	7:50AM	0.94	BA
Young HS Building B	52376	52376-2-HAL-F01-01	West End of Hall Left Fount	7:56AM	0.41	BA
Young HS Building B	52376	52376-2-HAL-F01-02	West End of Hall Left Fount	7:56AM	0.51	BA
Young HS Building B	52376	52376-2-HAL-F01-03	West End of Hall Left Fount	7:56AM	0.32	BA
Young HS Building B	52376	52376-2-HAL-F01-04	West End of Hall Left Fount	7:56AM	0.37	BA
Young HS Building B	52376	52376-2-HAL-F01-05	West End of Hall Left Fount	7:56AM	0.37	BA
Young HS Building B	52376	52376-2-HAL-F04-01	East End Hall Right Fountain	7:55AM	1.6	BA
Young HS Building B	52376	52376-2-HAL-F04-02	East End Hall Right Fountain	7:55AM	1.8	BA
Young HS Building B	52376	52376-2-HAL-F04-03	East End Hall Right Fountain	7:55AM	1.2	BA
Young HS Building B	52376	52376-2-HAL-F04-04	East End Hall Right Fountain	7:55AM	1.3	BA
Young HS Building B	52376	52376-2-HAL-F04-05	East End Hall Right Fountain	7:55AM	1.2	BA
Young HS Building B	52376	52376-2-GLR-F02-01	Girls Locker RM Right Fountain	8:05AM	2.5	BA
Young HS Building B	52376	52376-2-GLR-F02-02	Girls Locker RM Right Fountain	8:05AM	1.1	BA
Young HS Building B	52376	52376-2-GLR-F02-03	Girls Locker RM Right Fountain	8:05AM	0.85	BA
Young HS Building B	52376	52376-2-GLR-F02-04	Girls Locker RM Right Fountain	8:05AM	0.65	BA
Young HS Building B	52376	52376-2-GLR-F02-05	Girls Locker RM Right Fountain	8:05AM	0.7	BA
Young Building C	52377	52377-2-HAL-F01-01	West end of Hall	6:26AM	<0.50	BA

Young Building C	52378	52377-2-HAL-F01-02	West end of Hall	6:26AM	<0.50	BA
Young Building C	52379	52377-2-HAL-F01-03	West end of Hall	6:26AM	<0.50	BA
Young Building C	52380	52377-2-HAL-F01-04	West end of Hall	6:26AM	<0.50	BA
Young Building C	52381	52377-2-HAL-F01-05	West end of Hall	6:26AM	<0.50	BA
Young Building C	52382	52377-2-HAL-WC01-01	Water Cooler West End of Hall	6:30AM	<0.50	BA
Young Building C	52383	52377-2-HAL-WC01-02	Water Cooler West End of Hall	6:30AM	<0.50	BA
Young Building C	52384	52377-2-HAL-WC01-03	Water Cooler West End of Hall	6:30AM	<0.50	BA
Young Building C	52385	52377-2-HAL-WC01-04	Water Cooler West End of Hall	6:30AM	<0.50	BA
Young Building C	52386	52377-2-HAL-WC01-05	Water Cooler West End of Hall	6:30AM	<0.50	BA
Young Building C	52387	52377-2-HAL-F02-01	East End of Hall	6:35AM	0.48	BA
Young Building C	52388	52377-2-HAL-F02-02	East End of Hall	6:35AM	0.54	BA
Young Building C	52389	52377-2-HAL-F02-03	East End of Hall	6:35AM	0.48	BA
Young Building C	52390	52377-2-HAL-F02-04	East End of Hall	6:35AM	0.54	BA
Young Building C	52391	52377-2-HAL-F02-05	East End of Hall	6:35AM	0.54	BA
Young Building C	52392	52377-1-HAL-F01-01	West end of Hall	6:40AM	<0.50	BA
Young Building C	52393	52377-1-HAL-F01-02	West end of Hall	6:40AM	<0.50	BA
Young Building C	52394	52377-1-HAL-F01-03	West end of Hall	6:40AM	<0.50	BA
Young Building C	52395	52377-1-HAL-F01-04	West end of Hall	6:40AM	<0.50	BA
Young Building C	52396	52377-1-HAL-F01-05	West end of Hall	6:40AM	<0.50	BA
Young Building C	52397	52377-1-HAL-WC01-01	Water Cooler West End of Hall	6:45AM	<0.50	BA
Young Building C	52398	52377-1-HAL-WC01-02	Water Cooler West End of Hall	6:45AM	<0.50	BA
Young Building C	52399	52377-1-HAL-WC01-03	Water Cooler West End of Hall	6:45AM	<0.50	BA
Young Building C	52400	52377-1-HAL-WC01-04	Water Cooler West End of Hall	6:45AM	<0.50	BA
Young Building C	52401	52377-1-HAL-WC01-05	Water Cooler West End of Hall	6:45AM	<0.50	BA
Young Building C	52402	52377-1-HAL-F02-01	East End of Hall	6:47AM	0.68	BA
Young Building C	52403	52377-1-HAL-F02-02	East End of Hall	6:47AM	0.76	BA

Young Building C	52404	52377-1-HAL-F02-03	East End of Hall	6:47AM	0.6	BA
Young Building C	52405	52377-1-HAL-F02-04	East End of Hall	6:47AM	0.59	BA
Young Building C	52406	52377-1-HAL-F02-05	East End of Hall	6:47AM	0.62	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations