



October 19, 2016

Dear Wells families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Wells samples were tested from 47 sites and the water sampled from two drinking fountains were above the action level of 15 ppb: A fountain on the first floor outside of Room 116 and a fountain on the second floor outside of Room 211. The water from the fountains have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only two of the samples at Wells returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for those fountains and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





19 de octubre de 2016

Estimadas familias de la escuela Wells,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Wells se tomaron muestras en 47 lugares y el agua de dos bebederos tenía rastros de plomo por encima del nivel de acción de 15 ppb: un bebedero del primer piso, afuera del salón 116, y otro del segundo piso, afuera del salón 211. El suministro de agua de esos dispositivos fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente dos de las muestras de Wells registraron niveles elevados. Este no es problema general sino específico de las cañerías de esos dispositivos y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Wells High School**

Date of test **10/04/16**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51555-1-KIT-KS01-001	Main- Kitchen South, Left Sink	10/4/16 6:00 AM	0.375	BA
51555-1-KIT-KS01-002	Main- Kitchen South, Left Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS01-003	Main- Kitchen South, Left Sink	10/4/16 6:00 AM	0.163	BA
51555-1-KIT-KS01-004	Main- Kitchen South, Left Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS01-005	Main- Kitchen South, Left Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS02-001	Main- Kitchen South, Center Sink	10/4/16 6:00 AM	0.141	BA
51555-1-KIT-KS02-002	Main- Kitchen South, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS02-003	Main- Kitchen South, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS02-004	Main- Kitchen South, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS02-005	Main- Kitchen South, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS03-001	Main- Kitchen South, Right Sink	10/4/16 6:00 AM	0.242	BA
51555-1-KIT-KS03-002	Main- Kitchen South, Right Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS03-003	Main- Kitchen South, Right Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS03-004	Main- Kitchen South, Right Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS03-005	Main- Kitchen South, Right Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS04-001	Main- Kitchen North, Left Sink	10/4/16 6:00 AM	0.241	BA
51555-1-KIT-KS04-002	Main- Kitchen North, Left Sink	10/4/16 6:00 AM	0.181	BA
51555-1-KIT-KS04-003	Main- Kitchen North, Left Sink	10/4/16 6:00 AM	0.124	BA
51555-1-KIT-KS04-004	Main- Kitchen North, Left Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS04-005	Main- Kitchen North, Left Sink	10/4/16 6:00 AM	0.169	BA
51555-KIT-KS05-001	Main- Kitchen North, Center Sink	10/4/16 6:00 AM	0.509	BA
51555-KIT-KS05-002	Main- Kitchen North, Center Sink	10/4/16 6:00 AM	0.714	BA
51555-KIT-KS05-003	Main- Kitchen North, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-KIT-KS05-004	Main- Kitchen North, Center Sink	10/4/16 6:00 AM	<0.120	ND
51555-KIT-KS05-005	Main- Kitchen North, Center Sink	10/4/16 6:00 AM	0.128	BA
51555-1-KIT-KS06-001	Main- Kitchen North, Right Sink	10/4/16 6:00 AM	0.316	BA
51555-1-KIT-KS06-002	Main- Kitchen North, Right Sink	10/4/16 6:00 AM	0.158	BA
51555-1-KIT-KS06-003	Main- Kitchen North, Right Sink	10/4/16 6:00 AM	0.123	BA
51555-1-KIT-KS06-004	Main- Kitchen North, Right Sink	10/4/16 6:00 AM	0.172	BA
51555-1-KIT-KS06-005	Main- Kitchen North, Right Sink	10/4/16 6:00 AM	0.164	BA
51555-1-KIT-KS07-001	Main- Kitchen East Sink	10/4/16 6:00 AM	0.804	BA
51555-1-KIT-KS07-002	Main- Kitchen East Sink	10/4/16 6:00 AM	1.06	BA
51555-1-KIT-KS07-003	Main- Kitchen East Sink	10/4/16 6:00 AM	1.26	BA
51555-1-KIT-KS07-004	Main- Kitchen East Sink	10/4/16 6:00 AM	1.1	BA
51555-1-KIT-KS07-005	Main- Kitchen East Sink	10/4/16 6:00 AM	0.407	BA
51555-1-KIT-KS08-001	Main- Kitchen West Sink	10/4/16 6:00 AM	0.912	BA
51555-1-KIT-KS08-002	Main- Kitchen West Sink	10/4/16 6:00 AM	0.364	BA
51555-1-KIT-KS08-003	Main- Kitchen West Sink	10/4/16 6:00 AM	<0.120	ND
51555-1-KIT-KS08-004	Main- Kitchen West Sink	10/4/16 6:00 AM	0.147	BA
51555-1-KIT-KS08-005	Main- Kitchen West Sink	10/4/16 6:00 AM	1.89	BA
51555-1-HAL-F09-001	Main- Outside Room 116, Left Fountain	10/4/16 6:00 AM	43.4	AA

51555-1-HAL-F09-002	Main- Outside Room 116, Left Fountain	10/4/16 6:00 AM	4.07	BA
51555-1-HAL-F09-003	Main- Outside Room 116, Left Fountain	10/4/16 6:00 AM	7.61	BA
51555-1-HAL-F09-004	Main- Outside Room 116, Left Fountain	10/4/16 6:00 AM	8.64	BA
51555-1-HAL-F09-005	Main- Outside Room 116, Left Fountain	10/4/16 6:00 AM	7.68	BA
51555-1-HAL-F10-001	Main- Outside Room 116, Right Fountain	10/4/16 6:00 AM	1.83	BA
51555-1-HAL-F10-002	Main- Outside Room 116, Right Fountain	10/4/16 6:00 AM	1.99	BA
51555-1-HAL-F10-003	Main- Outside Room 116, Right Fountain	10/4/16 6:00 AM	1.79	BA
51555-1-HAL-F10-004	Main- Outside Room 116, Right Fountain	10/4/16 6:00 AM	1.89	BA
51555-1-HAL-F10-005	Main- Outside Room 116, Right Fountain	10/4/16 6:00 AM	2.06	BA
51555-1-HAL-F11-001	Main-Outside Room 110, Left Fountain	10/4/16 6:00 AM	1.83	BA
51555-1-HAL-F11-002	Main-Outside Room 110, Left Fountain	10/4/16 6:00 AM	1.93	BA
51555-1-HAL-F11-003	Main-Outside Room 110, Left Fountain	10/4/16 6:00 AM	1.27	BA
51555-1-HAL-F11-004	Main-Outside Room 110, Left Fountain	10/4/16 6:00 AM	0.669	BA
51555-1-HAL-F11-005	Main-Outside Room 110, Left Fountain	10/4/16 6:00 AM	0.721	BA
51555-1-HAL-F12-001	Main-Outside Room 110, Right Fountain	10/4/16 6:00 AM	1.57	BA
51555-1-HAL-F12-002	Main-Outside Room 110, Right Fountain	10/4/16 6:00 AM	0.765	BA
51555-1-HAL-F12-003	Main-Outside Room 110, Right Fountain	10/4/16 6:00 AM	0.783	BA
51555-1-HAL-F12-004	Main-Outside Room 110, Right Fountain	10/4/16 6:00 AM	0.896	BA
51555-1-HAL-F12-005	Main-Outside Room 110, Right Fountain	10/4/16 6:00 AM	0.804	BA
51555-1-HAL-F13-001	Main-Across Room 104, Left Fountain	10/4/16 6:00 AM	2.29	BA
51555-1-HAL-F13-002	Main-Across Room 104, Left Fountain	10/4/16 6:00 AM	2	BA
51555-1-HAL-F13-003	Main-Across Room 104, Left Fountain	10/4/16 6:00 AM	1.97	BA
51555-1-HAL-F13-004	Main-Across Room 104, Left Fountain	10/4/16 6:00 AM	2.01	BA
51555-1-HAL-F13-005	Main-Across Room 104, Left Fountain	10/4/16 6:00 AM	1.9	BA
51555-1-HAL-F14-001	Main-Across Room 104, Right Fountain	10/4/16 6:00 AM	6.28	BA
51555-1-HAL-F14-002	Main-Across Room 104, Right Fountain	10/4/16 6:00 AM	7.16	BA
51555-1-HAL-F14-003	Main-Across Room 104, Right Fountain	10/4/16 6:00 AM	6.4	BA
51555-1-HAL-F14-004	Main-Across Room 104, Right Fountain	10/4/16 6:00 AM	4.8	BA
51555-1-HAL-F14-005	Main-Across Room 104, Right Fountain	10/4/16 6:00 AM	4.72	BA
51555-1-HAL-F15-001	Main-Outside Room 127, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F15-002	Main-Outside Room 127, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F15-003	Main-Outside Room 127, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F15-004	Main-Outside Room 127, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F15-005	Main-Outside Room 127, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F16-001	Main-Outside Room 127, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F16-002	Main-Outside Room 127, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F16-003	Main-Outside Room 127, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F16-004	Main-Outside Room 127, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F16-005	Main-Outside Room 127, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-1-HAL-F17-001	Main-Across Room 115, Left Fountain	10/4/16 6:00 AM	1.88	BA
51555-1-HAL-F17-002	Main-Across Room 115, Left Fountain	10/4/16 6:00 AM	0.883	BA
51555-1-HAL-F17-003	Main-Across Room 115, Left Fountain	10/4/16 6:00 AM	0.607	BA
51555-1-HAL-F17-004	Main-Across Room 115, Left Fountain	10/4/16 6:00 AM	0.475	BA
51555-1-HAL-F17-005	Main-Across Room 115, Left Fountain	10/4/16 6:00 AM	0.389	BA
51555-1-HAL-F18-001	Main-Across Room 115, Right Fountain	10/4/16 6:00 AM	1.52	BA
51555-1-HAL-F18-002	Main-Across Room 115, Right Fountain	10/4/16 6:00 AM	0.379	BA
51555-1-HAL-F18-003	Main-Across Room 115, Right Fountain	10/4/16 6:00 AM	0.293	BA
51555-1-HAL-F18-004	Main-Across Room 115, Right Fountain	10/4/16 6:00 AM	0.282	BA
51555-1-HAL-F18-005	Main-Across Room 115, Right Fountain	10/4/16 6:00 AM	0.267	BA
51555-2-HAL-F01-001	Main-Outside Room 220, Left Fountain	10/4/16 6:00 AM	1.92	BA
51555-2-HAL-F01-002	Main-Outside Room 220, Left Fountain	10/4/16 6:00 AM	1.81	BA
51555-2-HAL-F01-003	Main-Outside Room 220, Left Fountain	10/4/16 6:00 AM	1.66	BA
51555-2-HAL-F01-004	Main-Outside Room 220, Left Fountain	10/4/16 6:00 AM	1.68	BA
51555-2-HAL-F01-005	Main-Outside Room 220, Left Fountain	10/4/16 6:00 AM	1.61	BA
51555-2-HAL-F02-001	Main-Outside Room 220, Right Fountain	10/4/16 6:00 AM	2.1	BA

51555-2-HAL-F02-002	Main-Outside Room 220, Right Fountain	10/4/16 6:00 AM	2.23	BA
51555-2-HAL-F02-003	Main-Outside Room 220, Right Fountain	10/4/16 6:00 AM	2.05	BA
51555-2-HAL-F02-004	Main-Outside Room 220, Right Fountain	10/4/16 6:00 AM	2.64	BA
51555-2-HAL-F02-005	Main-Outside Room 220, Right Fountain	10/4/16 6:00 AM	2.29	BA
51555-2-HAL-F03-001	Main-Outside Room 212, Left Fountain	10/4/16 6:00 AM	1.58	BA
51555-2-HAL-F03-002	Main-Outside Room 212, Left Fountain	10/4/16 6:00 AM	2.8	BA
51555-2-HAL-F03-003	Main-Outside Room 212, Left Fountain	10/4/16 6:00 AM	1.42	BA
51555-2-HAL-F03-004	Main-Outside Room 212, Left Fountain	10/4/16 6:00 AM	1.23	BA
51555-2-HAL-F03-005	Main-Outside Room 212, Left Fountain	10/4/16 6:00 AM	1.44	BA
51555-2-HAL-F04-001	Main-Outside Room 212, Right Fountain	10/4/16 6:00 AM	1.19	BA
51555-2-HAL-F04-002	Main-Outside Room 212, Right Fountain	10/4/16 6:00 AM	0.636	BA
51555-2-HAL-F04-003	Main-Outside Room 212, Right Fountain	10/4/16 6:00 AM	0.599	BA
51555-2-HAL-F04-004	Main-Outside Room 212, Right Fountain	10/4/16 6:00 AM	0.564	BA
51555-2-HAL-F04-005	Main-Outside Room 212, Right Fountain	10/4/16 6:00 AM	0.61	BA
51555-2-HAL-F05-001	Main-Across Room 206, Left Fountain	10/4/16 6:00 AM	3.35	BA
51555-2-HAL-F05-002	Main-Across Room 206, Left Fountain	10/4/16 6:00 AM	1.96	BA
51555-2-HAL-F05-003	Main-Across Room 206, Left Fountain	10/4/16 6:00 AM	2.07	BA
51555-2-HAL-F05-004	Main-Across Room 206, Left Fountain	10/4/16 6:00 AM	1.41	BA
51555-2-HAL-F05-005	Main-Across Room 206, Left Fountain	10/4/16 6:00 AM	1.39	BA
51555-2-HAL-F06-001	Main-Across Room 206, Right Fountain	10/4/16 6:00 AM	3.11	BA
51555-2-HAL-F06-002	Main-Across Room 206, Right Fountain	10/4/16 6:00 AM	1.32	BA
51555-2-HAL-F06-003	Main-Across Room 206, Right Fountain	10/4/16 6:00 AM	2.04	BA
51555-2-HAL-F06-004	Main-Across Room 206, Right Fountain	10/4/16 6:00 AM	2.09	BA
51555-2-HAL-F06-005	Main-Across Room 206, Right Fountain	10/4/16 6:00 AM	1.81	BA
51555-2-HAL-F07-001	Main-Outside Room 211, Right Fountain	10/4/16 6:00 AM	40.7	AA
51555-2-HAL-F07-002	Main-Outside Room 211, Right Fountain	10/4/16 6:00 AM	58.8	AA
51555-2-HAL-F07-003	Main-Outside Room 211, Right Fountain	10/4/16 6:00 AM	65.2	AA
51555-2-HAL-F07-004	Main-Outside Room 211, Right Fountain	10/4/16 6:00 AM	67.9	AA
51555-2-HAL-F07-005	Main-Outside Room 211, Right Fountain	10/4/16 6:00 AM	59.4	AA
51555-2-HAL-F08-001	Main-Outside Room 215, Left Fountain	10/4/16 6:00 AM	0.247	BA
51555-2-HAL-F08-002	Main-Outside Room 215, Left Fountain	10/4/16 6:00 AM	0.141	BA
51555-2-HAL-F08-003	Main-Outside Room 215, Left Fountain	10/4/16 6:00 AM	<0.120	ND
51555-2-HAL-F08-004	Main-Outside Room 215, Left Fountain	10/4/16 6:00 AM	<0.120	ND
51555-2-HAL-F08-005	Main-Outside Room 215, Left Fountain	10/4/16 6:00 AM	0.125	BA
51555-2-HAL-F09-001	Main-Outside Room 215, Right Fountain	10/4/16 6:00 AM	0.464	BA
51555-2-HAL-F09-002	Main-Outside Room 215, Right Fountain	10/4/16 6:00 AM	0.791	BA
51555-2-HAL-F09-003	Main-Outside Room 215, Right Fountain	10/4/16 6:00 AM	0.704	BA
51555-2-HAL-F09-004	Main-Outside Room 215, Right Fountain	10/4/16 6:00 AM	0.874	BA
51555-2-HAL-F09-005	Main-Outside Room 215, Right Fountain	10/4/16 6:00 AM	1.31	BA
51555-3-HAL-F01-001	Main-Outside Room 314, Left Fountain	10/4/16 6:00 AM	4.45	BA
51555-3-HAL-F01-002	Main-Outside Room 314, Left Fountain	10/4/16 6:00 AM	3.58	BA
51555-3-HAL-F01-003	Main-Outside Room 314, Left Fountain	10/4/16 6:00 AM	2.47	BA
51555-3-HAL-F01-004	Main-Outside Room 314, Left Fountain	10/4/16 6:00 AM	2.51	BA
51555-3-HAL-F01-005	Main-Outside Room 314, Left Fountain	10/4/16 6:00 AM	2.53	BA
51555-3-HAL-F03-001	Main-Outside Room 310, Left Fountain	10/4/16 6:00 AM	2.59	BA
51555-3-HAL-F03-002	Main-Outside Room 310, Left Fountain	10/4/16 6:00 AM	4.02	BA
51555-3-HAL-F03-003	Main-Outside Room 310, Left Fountain	10/4/16 6:00 AM	3.35	BA
51555-3-HAL-F03-004	Main-Outside Room 310, Left Fountain	10/4/16 6:00 AM	2.36	BA
51555-3-HAL-F03-005	Main-Outside Room 310, Left Fountain	10/4/16 6:00 AM	2.45	BA
51555-3-HAL-F04-001	Main-Outside Room 310, Right Fountain	10/4/16 6:00 AM	2.45	BA
51555-3-HAL-F04-002	Main-Outside Room 310, Right Fountain	10/4/16 6:00 AM	1.88	BA
51555-3-HAL-F04-003	Main-Outside Room 310, Right Fountain	10/4/16 6:00 AM	1.8	BA
51555-3-HAL-F04-004	Main-Outside Room 310, Right Fountain	10/4/16 6:00 AM	1.59	BA
51555-3-HAL-F04-005	Main-Outside Room 310, Right Fountain	10/4/16 6:00 AM	1.15	BA
51555-3-HAL-F05-001	Main-Across Room 304, Left Fountain	10/4/16 6:00 AM	2.92	BA

51555-3-HAL-F05-002	Main-Across Room 304, Left Fountain	10/4/16 6:00 AM	6.47	BA
51555-3-HAL-F05-003	Main-Across Room 304, Left Fountain	10/4/16 6:00 AM	5.27	BA
51555-3-HAL-F05-004	Main-Across Room 304, Left Fountain	10/4/16 6:00 AM	3.28	BA
51555-3-HAL-F05-005	Main-Across Room 304, Left Fountain	10/4/16 6:00 AM	2.46	BA
51555-3-HAL-F06-001	Main-Across Room 304, Right Fountain	10/4/16 6:00 AM	2.37	BA
51555-3-HAL-F06-002	Main-Across Room 304, Right Fountain	10/4/16 6:00 AM	2.27	BA
51555-3-HAL-F06-003	Main-Across Room 304, Right Fountain	10/4/16 6:00 AM	5.13	BA
51555-3-HAL-F06-004	Main-Across Room 304, Right Fountain	10/4/16 6:00 AM	3.65	BA
51555-3-HAL-F06-005	Main-Across Room 304, Right Fountain	10/4/16 6:00 AM	3.26	BA
51555-3-HAL-WC07-001	Main-Across Room 307, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC07-002	Main-Across Room 307, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC07-003	Main-Across Room 307, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC07-004	Main-Across Room 307, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC07-005	Main-Across Room 307, Fountain/Bottle Filler	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC08-001	Main-Across Room 307, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC08-002	Main-Across Room 307, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC08-003	Main-Across Room 307, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC08-004	Main-Across Room 307, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-WC08-005	Main-Across Room 307, Fountain	10/4/16 6:00 AM	<0.120	ND
51555-3-HAL-F09-001	Main-Outside Room 315, Left Fountain	10/4/16 6:00 AM	0.375	BA
51555-3-HAL-F09-002	Main-Outside Room 315, Left Fountain	10/4/16 6:00 AM	0.335	BA
51555-3-HAL-F09-003	Main-Outside Room 315, Left Fountain	10/4/16 6:00 AM	0.333	BA
51555-3-HAL-F09-004	Main-Outside Room 315, Left Fountain	10/4/16 6:00 AM	0.394	BA
51555-3-HAL-F09-005	Main-Outside Room 315, Left Fountain	10/4/16 6:00 AM	0.353	BA
51555-3-HAL-F10-001	Main-Outside Room 315, Right Fountain	10/4/16 6:00 AM	1.07	BA
51555-3-HAL-F10-002	Main-Outside Room 315, Right Fountain	10/4/16 6:00 AM	0.926	BA
51555-3-HAL-F10-003	Main-Outside Room 315, Right Fountain	10/4/16 6:00 AM	0.736	BA
51555-3-HAL-F10-004	Main-Outside Room 315, Right Fountain	10/4/16 6:00 AM	0.876	BA
51555-3-HAL-F10-005	Main-Outside Room 315, Right Fountain	10/4/16 6:00 AM	0.785	BA
51555-3-GYM-F11-001	Main-Boys Gym Third Floor	10/4/16 6:00 AM	2.31	BA
51555-3-GYM-F11-002	Main-Boys Gym Third Floor	10/4/16 6:00 AM	2.36	BA
51555-3-GYM-F11-003	Main-Boys Gym Third Floor	10/4/16 6:00 AM	2.55	BA
51555-3-GYM-F11-004	Main-Boys Gym Third Floor	10/4/16 6:00 AM	3.47	BA
51555-3-GYM-F11-005	Main-Boys Gym Third Floor	10/4/16 6:00 AM	6.88	BA
51555-4-HAL-F01-001	Main-Outside Room 416, Left Fountain	10/4/16 6:00 AM	5.36	BA
51555-4-HAL-F01-002	Main-Outside Room 416, Left Fountain	10/4/16 6:00 AM	9.58	BA
51555-4-HAL-F01-003	Main-Outside Room 416, Left Fountain	10/4/16 6:00 AM	4.25	BA
51555-4-HAL-F01-004	Main-Outside Room 416, Left Fountain	10/4/16 6:00 AM	3.04	BA
51555-4-HAL-F01-005	Main-Outside Room 416, Left Fountain	10/4/16 6:00 AM	2.63	BA
51555-4-HAL-F02-001	Main-Outside Room 416, Right Fountain	10/4/16 6:00 AM	2.89	BA
51555-4-HAL-F02-002	Main-Outside Room 416, Right Fountain	10/4/16 6:00 AM	2.78	BA
51555-4-HAL-F02-003	Main-Outside Room 416, Right Fountain	10/4/16 6:00 AM	2.54	BA
51555-4-HAL-F02-004	Main-Outside Room 416, Right Fountain	10/4/16 6:00 AM	3.11	BA
51555-4-HAL-F02-005	Main-Outside Room 416, Right Fountain	10/4/16 6:00 AM	2.33	BA
51555-4-HAL-F03-001	Main-Outside Room 410, Left Fountain	10/4/16 6:00 AM	1.32	BA
51555-4-HAL-F03-002	Main-Outside Room 410, Left Fountain	10/4/16 6:00 AM	2.73	BA
51555-4-HAL-F03-003	Main-Outside Room 410, Left Fountain	10/4/16 6:00 AM	3.26	BA
51555-4-HAL-F03-004	Main-Outside Room 410, Left Fountain	10/4/16 6:00 AM	2.3	BA
51555-4-HAL-F03-005	Main-Outside Room 410, Left Fountain	10/4/16 6:00 AM	3.44	BA
51555-4-HAL-F04-001	Main-Outside Room 410, Right Fountain	10/4/16 6:00 AM	1.78	BA
51555-4-HAL-F04-002	Main-Outside Room 410, Right Fountain	10/4/16 6:00 AM	1.51	BA
51555-4-HAL-F04-003	Main-Outside Room 410, Right Fountain	10/4/16 6:00 AM	2.06	BA
51555-4-HAL-F04-004	Main-Outside Room 410, Right Fountain	10/4/16 6:00 AM	2.99	BA
51555-4-HAL-F04-005	Main-Outside Room 410, Right Fountain	10/4/16 6:00 AM	3.54	BA
51555-4-HAL-F05-001	Main-Across Room 404, Left Fountain	10/4/16 6:00 AM	1.16	BA

51555-4-HAL-F05-002	Main-Across Room 404, Left Fountain	10/4/16 6:00 AM	1.17	BA
51555-4-HAL-F05-003	Main-Across Room 404, Left Fountain	10/4/16 6:00 AM	1.21	BA
51555-4-HAL-F05-004	Main-Across Room 404, Left Fountain	10/4/16 6:00 AM	0.999	BA
51555-4-HAL-F05-005	Main-Across Room 404, Left Fountain	10/4/16 6:00 AM	0.616	BA
51555-4-HAL-F06-001	Main-Across Room 404, Right Fountain	10/4/16 6:00 AM	1.36	BA
51555-4-HAL-F06-002	Main-Across Room 404, Right Fountain	10/4/16 6:00 AM	0.897	BA
51555-4-HAL-F06-003	Main-Across Room 404, Right Fountain	10/4/16 6:00 AM	0.755	BA
51555-4-HAL-F06-004	Main-Across Room 404, Right Fountain	10/4/16 6:00 AM	0.605	BA
51555-4-HAL-F06-005	Main-Across Room 404, Right Fountain	10/4/16 6:00 AM	0.589	BA
51555-4-HAL-F07-001	Main-Across Room 407, Right Fountain	10/4/16 6:00 AM	3.38	BA
51555-4-HAL-F07-002	Main-Across Room 407, Right Fountain	10/4/16 6:00 AM	2.59	BA
51555-4-HAL-F07-003	Main-Across Room 407, Right Fountain	10/4/16 6:00 AM	2.24	BA
51555-4-HAL-F07-004	Main-Across Room 407, Right Fountain	10/4/16 6:00 AM	2.18	BA
51555-4-HAL-F07-005	Main-Across Room 407, Right Fountain	10/4/16 6:00 AM	2.78	BA
51555-4-HAL-F08-001	Main-Across Room 407, Left Fountain	10/4/16 6:00 AM	2.91	BA
51555-4-HAL-F08-002	Main-Across Room 407, Left Fountain	10/4/16 6:00 AM	2.55	BA
51555-4-HAL-F08-003	Main-Across Room 407, Left Fountain	10/4/16 6:00 AM	2.59	BA
51555-4-HAL-F08-004	Main-Across Room 407, Left Fountain	10/4/16 6:00 AM	4.1	BA
51555-4-HAL-F08-005	Main-Across Room 407, Left Fountain	10/4/16 6:00 AM	3.13	BA
51555-4-HAL-F09-001	Main-Across Room 417, Left Fountain	10/4/16 6:00 AM	1.64	BA
51555-4-HAL-F09-002	Main-Across Room 417, Left Fountain	10/4/16 6:00 AM	1.65	BA
51555-4-HAL-F09-003	Main-Across Room 417, Left Fountain	10/4/16 6:00 AM	1.6	BA
51555-4-HAL-F09-004	Main-Across Room 417, Left Fountain	10/4/16 6:00 AM	1.35	BA
51555-4-HAL-F09-005	Main-Across Room 417, Left Fountain	10/4/16 6:00 AM	1.49	BA
51555-4-HAL-F10-001	Main-Outside Room 417, Right Fountain	10/4/16 6:00 AM	2.11	BA
51555-4-HAL-F10-002	Main-Outside Room 417, Right Fountain	10/4/16 6:00 AM	0.982	BA
51555-4-HAL-F10-003	Main-Outside Room 417, Right Fountain	10/4/16 6:00 AM	0.737	BA
51555-4-HAL-F10-004	Main-Outside Room 417, Right Fountain	10/4/16 6:00 AM	0.632	BA
51555-4-HAL-F10-005	Main-Outside Room 417, Right Fountain	10/4/16 6:00 AM	0.672	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations