

## School Lead Water Testing - Data Collection Form

School Short Name **Haugan**

Length of time water remained in pipes before sampled (hours) 8 hrs

Date of test 05/27/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
I-C-S01-01	1st Floor Kitchen	5/27/16 6:10 AM	None Detected	NO
I-C-S01-02	1st Floor Kitchen	5/27/16 6:10 AM	None Detected	NO
I-C-S01-03	1st Floor Kitchen	5/27/16 6:10 AM	None Detected	NO
I-C-S01-04	1st Floor Kitchen	5/27/16 6:10 AM	None Detected	NO
I-C-S01-05	1st Floor Kitchen	5/27/16 6:10 AM	None Detected	NO
I-C-S01-06	1st Floor Kitchen	5/27/16 6:11 AM	None Detected	NO
I-C-S01-07	1st Floor Kitchen	5/27/16 6:12 AM	None Detected	NO
I-C-S01-08	1st Floor Kitchen	5/27/16 6:12 AM	None Detected	NO
I-C-S01-09	1st Floor Kitchen	5/27/16 6:12 AM	None Detected	NO
I-C-S01-10	1st Floor Kitchen	5/27/16 6:12 AM	None Detected	NO
I-N-S01-11	Pk#K Room 102	5/27/16 6:15 AM	None Detected	NO
I-N-S01-12	Pk#K Room 102	5/27/16 6:15 AM	None Detected	NO
I-N-S01-13	Pk#K Room 102	5/27/16 6:15 AM	None Detected	NO
I-N-S01-14	Pk#K Room 102	5/27/16 6:15 AM	None Detected	NO
I-N-S01-15	Pk#K Room 102	5/27/16 6:15 AM	None Detected	NO
I-W-S01-16	1st Floor Boys Restroom	5/27/16 6:20 AM	None Detected	NO
I-W-S01-17	1st Floor Boys Restroom	5/27/16 6:20 AM	None Detected	NO
I-W-S01-18	1st Floor Boys Restroom	5/27/16 6:20 AM	None Detected	NO
I-W-S01-19	1st Floor Boys Restroom	5/27/16 6:20 AM	None Detected	NO
I-W-S01-20	1st Floor Boys Restroom	5/27/16 6:20 AM	None Detected	NO
I-W-S01-21	1st Floor Boys Restroom	5/27/16 6:21 AM	None Detected	NO
I-W-S01-22	1st Floor Boys Restroom	5/27/16 6:21 AM	None Detected	NO
I-W-S01-23	1st Floor Boys Restroom	5/27/16 6:21 AM	None Detected	NO
I-W-S01-24	1st Floor Boys Restroom	5/27/16 6:21 AM	None Detected	NO
I-W-S01-25	1st Floor Boys Restroom	5/27/16 6:21 AM	None Detected	NO
I-W-S01-26	1st Floor Boys Restroom	5/27/16 6:22 AM	None Detected	NO
I-W-S01-27	1st Floor Boys Restroom	5/27/16 6:22 AM	None Detected	NO
I-W-S01-28	1st Floor Boys Restroom	5/27/16 6:22 AM	None Detected	NO
I-W-S01-29	1st Floor Boys Restroom	5/27/16 6:22 AM	None Detected	NO
I-W-S01-30	1st Floor Boys Restroom	5/27/16 6:22 AM	None Detected	NO
I-E-F01-31	1st Floor near Classroom 104	5/27/16 6:25 AM	None Detected	NO
I-E-F01-32	1st Floor near Classroom 104	5/27/16 6:25 AM	None Detected	NO
I-E-F01-33	1st Floor near Classroom 104	5/27/16 6:25 AM	None Detected	NO
I-E-F01-34	1st Floor near Classroom 104	5/27/16 6:25 AM	None Detected	NO
I-E-F01-35	1st Floor near Classroom 104	5/27/16 6:25 AM	None Detected	NO
I-F02-36	1st Floor near Classroom 104	5/27/16 6:26 AM	None Detected	NO
I-F02-37	1st Floor near Classroom 104	5/27/16 6:26 AM	None Detected	NO
I-F02-38	1st Floor near Classroom 104	5/27/16 6:26 AM	None Detected	NO
I-F02-39	1st Floor near Classroom 104	5/27/16 6:26 AM	None Detected	NO
I-M-O01-40	Main Office 103	5/27/16 6:30 AM	None Detected	NO
I-M-S01-41	Main Office 103	5/27/16 6:30 AM	None Detected	NO
I-M-S01-42	Main Office 103	5/27/16 6:30 AM	None Detected	NO
I-M-S01-43	Main Office 103	5/27/16 6:30 AM	None Detected	NO
I-M-S01-44	Main Office 103	5/27/16 6:30 AM	None Detected	NO
I-H-A01-45	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F01-46	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F01-47	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F01-48	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F01-49	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F01-50	S. Hall Across from Teacher's Lounge	5/27/16 6:35 AM	None Detected	NO
I-S-F02-51	S. Hall Across from Teacher's Lounge	5/27/16 6:36 AM	None Detected	NO
I-S-F02-52	S. Hall Across from Teacher's Lounge	5/27/16 6:36 AM	None Detected	NO
I-S-F02-53	S. Hall Across from Teacher's Lounge	5/27/16 6:36 AM	None Detected	NO
I-S-F02-54	S. Hall Across from Teacher's Lounge	5/27/16 6:36 AM	None Detected	NO
I-S-F02-55	S. Hall Across from Teacher's Lounge	5/27/16 6:36 AM	None Detected	NO
I-S-S01-56	S. Hall across from Girls Restroom	5/27/16 6:37 AM	None Detected	NO
I-S-S01-57	S. Hall across from Girls Restroom	5/27/16 6:37 AM	None Detected	NO
I-S-S01-58	S. Hall across from Girls Restroom	5/27/16 6:37 AM	None Detected	NO
I-S-S01-59	S. Hall across from Girls Restroom	5/27/16 6:37 AM	None Detected	NO
I-S-S01-60	S. Hall across from Girls Restroom	5/27/16 6:37 AM	None Detected	NO
I-S-S01-61	S. Hall near Girls Restroom	5/27/16 6:40 AM	None Detected	NO
I-S-S01-62	S. Hall near Girls Restroom	5/27/16 6:40 AM	None Detected	NO
I-S-S01-63	S. Hall near Girls Restroom	5/27/16 6:40 AM	None Detected	NO
I-S-S01-64	S. Hall near Girls Restroom	5/27/16 6:40 AM	None Detected	NO
I-S-S01-65	S. Hall near Girls Restroom	5/27/16 6:40 AM	None Detected	NO
I-C-S01-66	1st Floor Boiler Room	5/27/16 6:45 AM	None Detected	NO
I-C-S01-67	1st Floor Boiler Room	5/27/16 6:45 AM	None Detected	NO
I-C-S01-68	1st Floor Boiler Room	5/27/16 6:45 AM	None Detected	NO
I-C-S01-69	1st Floor Boiler Room	5/27/16 6:45 AM	None Detected	NO
I-C-S01-70	1st Floor Boiler Room	5/27/16 6:45 AM	None Detected	NO
I-C-S01-71	1st Floor across from Boys Restroom	5/27/16 7:02 AM	None Detected	NO
I-C-S01-72	1st Floor across from Boys Restroom	5/27/16 7:02 AM	None Detected	NO
I-C-S01-73	1st Floor across from Boys Restroom	5/27/16 7:02 AM	None Detected	NO
I-C-S01-74	1st Floor across from Boys Restroom	5/27/16 7:02 AM	None Detected	NO
I-C-S01-75	1st Floor across from Boys Restroom	5/27/16 7:02 AM	None Detected	NO
I-C-F01-76	1st Floor across from Boys Restroom	5/27/16 7:03 AM	None Detected	NO
I-C-F01-77	1st Floor across from Boys Restroom	5/27/16 7:03 AM	None Detected	NO
I-C-F01-78	1st Floor across from Boys Restroom	5/27/16 7:03 AM	None Detected	NO
I-C-F01-79	1st Floor across from Boys Restroom	5/27/16 7:03 AM	None Detected	NO
I-C-F01-80	1st Floor across from Boys Restroom	5/27/16 7:03 AM	None Detected	NO
I-C-F02-81	1st Floor across from Boys Restroom	5/27/16 7:04 AM	None Detected	NO
I-C-F02-82	1st Floor across from Boys Restroom	5/27/16 7:04 AM	None Detected	NO
I-C-F02-83	1st Floor across from Boys Restroom	5/27/16 7:04 AM	None Detected	NO
I-C-F02-84	1st Floor across from Boys Restroom	5/27/16 7:04 AM	None Detected	NO
I-C-F02-85	1st Floor across from Boys Restroom	5/27/16 7:04 AM	None Detected	NO
I-C-S01-86	1st Floor Boys Restroom	5/27/16 7:05 AM	None Detected	NO
I-C-S01-87	1st Floor Boys Restroom	5/27/16 7:05 AM	None Detected	NO
I-C-S01-88	1st Floor Boys Restroom	5/27/16 7:05 AM	None Detected	NO
I-C-S01-89	1st Floor Boys Restroom	5/27/16 7:05 AM	None Detected	NO
I-C-S01-90	1st Floor Boys Restroom	5/27/16 7:05 AM	None Detected	NO
I-C-S02-91	1st Floor Boys Restroom	5/27/16 7:06 AM	None Detected	NO
I-C-S02-92	1st Floor Boys Restroom	5/27/16 7:06 AM	None Detected	NO
I-C-S02-93	1st Floor Boys Restroom	5/27/16 7:06 AM	None Detected	NO
I-C-S02-94	1st Floor Boys Restroom	5/27/16 7:06 AM	None Detected	NO
I-C-S02-95	1st Floor Boys Restroom	5/27/16 7:06 AM	None Detected	NO
I-S-S01-96	Room 112	5/27/16 7:08 AM	None Detected	NO
I-S-S01-97	Room 112	5/27/16 7:08 AM	None Detected	NO
I-S-S01-98	Room 112	5/27/16 7:08 AM	None Detected	NO
I-S-S01-99	Room 112	5/27/16 7:08 AM	None Detected	NO
I-S-S01-100	Room 112	5/27/16 7:08 AM	None Detected	NO
I-S-S01-101	S. Hall Girls Room across from Room 115	5/27/16 7:18 AM	None Detected	NO
I-S-S01-102	S. Hall Girls Room across from Room 115	5/27/16 7:18 AM	None Detected	NO
I-S-S01-103	S. Hall Girls Room across from Room 115	5/27/16 7:18 AM	None Detected	NO
I-S-S01-104	S. Hall Girls Room across from Room 115	5/27/16 7:18 AM	None Detected	NO

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/l

### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

RA: Below EPA Action Level

BA-Below EPA Action Level  
AA-Above EPA Action Level