



School Lead Water Testing - Data Collection Form

School Short Name **Ray**
Address **5361 S. Kimbark Avenue**

Length of time water remained in pipes before sampled (hours) **13.00**
Report based on lab results dated **6/3/16**
Date of test **05/24/16**
Water last used (Time and date) **Approx 4 PM 5/23/16**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
25071-2-N02-F-001	2nd floor Across from room 202	5/24/16 5:00 AM	7.85	BA
25071-2-N02-F-002	2nd floor Across from room 202	5/24/16 5:00 AM	4.81	BA
25071-2-N02-F-003	2nd floor Across from room 202	5/24/16 5:00 AM	5.59	BA
25071-2-N02-F-004	2nd floor Across from room 202	5/24/16 5:00 AM	7.73	BA
25071-2-N02-F-005	2nd floor Across from room 202	5/24/16 5:00 AM	7.44	BA
25071-3-N02-F-001	3rd floor Across from room 314	5/24/16 5:00 AM	1.38	BA
25071-3-N02-F-002	3rd floor Across from room 314	5/24/16 5:00 AM	0.42	BA
25071-3-N02-F-003	3rd floor Across from room 314	5/24/16 5:00 AM	0.384	BA
25071-3-N02-F-004	3rd floor Across from room 314	5/24/16 5:00 AM	0.378	BA
25071-3-N02-F-005	3rd floor Across from room 314	5/24/16 5:00 AM	0.49	BA
25071-1-N02-F-001	1st floor Across from room 202	5/24/16 5:00 AM	4.38	BA
25071-1-N02-F-002	1st floor Across from room 202	5/24/16 5:00 AM	4.41	BA
25071-1-N02-F-003	1st floor Across from room 202	5/24/16 5:00 AM	3.54	BA
25071-1-N02-F-004	1st floor Across from room 202	5/24/16 5:00 AM	2.69	BA
25071-1-N02-F-005	1st floor Across from room 202	5/24/16 5:00 AM	2.17	BA
25071-2-N01-F-001	2nd floor Across from room 214	5/24/16 5:00 AM	4.69	BA
25071-2-N01-F-002	2nd floor Across from room 214	5/24/16 5:00 AM	0.446	BA
25071-2-N01-F-003	2nd floor Across from room 214	5/24/16 5:00 AM	0.5	BA
25071-2-N01-F-004	2nd floor Across from room 214	5/24/16 5:00 AM	0.388	BA
25071-2-N01-F-005	2nd floor Across from room 214	5/24/16 5:00 AM	0.367	BA
25071-B-N02-F-001	Basement Acroom from room 007	5/24/16 5:00 AM	2.77	BA
25071-B-N02-F-002	Basement Acroom from room 007	5/24/16 5:00 AM	2.64	BA
25071-B-N02-F-003	Basement Acroom from room 007	5/24/16 5:00 AM	1.68	BA
25071-B-N02-F-004	Basement Acroom from room 007	5/24/16 5:00 AM	1.25	BA
25071-B-N02-F-005	Basement Acroom from room 007	5/24/16 5:00 AM	1.1	BA
25071-2-E01-F-001	Annex 2nd floor by room 512	5/24/16 5:00 AM	0.184	BA
25071-2-E01-F-002	Annex 2nd floor by room 512	5/24/16 5:00 AM	0.178	BA
25071-2-E01-F-003	Annex 2nd floor by room 512	5/24/16 5:00 AM	0.147	BA
25071-2-E01-F-004	Annex 2nd floor by room 512	5/24/16 5:00 AM	0.182	BA
25071-2-E01-F-005	Annex 2nd floor by room 512	5/24/16 5:00 AM	0.133	BA
25071-B-N01-F-001	Basement by Playroom 004	5/24/16 5:00 AM	0.417	BA
25071-B-N01-F-002	Basement by Playroom 004	5/24/16 5:00 AM	0.434	BA
25071-B-N01-F-003	Basement by Playroom 004	5/24/16 5:00 AM	0.33	BA
25071-B-N01-F-004	Basement by Playroom 004	5/24/16 5:00 AM	0.444	BA
25071-B-N01-F-005	Basement by Playroom 004	5/24/16 5:00 AM	0.471	BA
25071-1-N01-F-001	1st floor Across room 102	5/24/16 5:00 AM	2.84	BA
25071-1-N01-F-002	1st floor Across room 102	5/24/16 5:00 AM	2.26	BA
25071-1-N01-F-003	1st floor Across room 102	5/24/16 5:00 AM	1.71	BA
25071-1-N01-F-004	1st floor Across room 102	5/24/16 5:00 AM	1.65	BA
25071-1-N01-F-005	1st floor Across room 102	5/24/16 5:00 AM	1.89	BA
25071-1-E01-5-001	Annex 1st floor across from room 405	5/24/16 5:00 AM	0.167	BA

25071-1-E01-5-002	Annex 1st floor across from room 405	5/24/16 5:00 AM	0.166	BA
25071-1-E01-5-003	Annex 1st floor across from room 405	5/24/16 5:00 AM	0.167	BA
25071-1-E01-5-004	Annex 1st floor across from room 405	5/24/16 5:00 AM	<0.120	ND
25071-1-E01-5-005	Annex 1st floor across from room 405	5/24/16 5:00 AM	<0.120	ND
25071-3-N01-F-001	3rd floor Across from room 302	5/24/16 5:00 AM	8.12	BA
25071-3-N01-F-002	3rd floor Across from room 302	5/24/16 5:00 AM	3.35	BA
25071-3-N01-F-003	3rd floor Across from room 302	5/24/16 5:00 AM	3.03	BA
25071-3-N01-F-004	3rd floor Across from room 302	5/24/16 5:00 AM	2.99	BA
25071-3-N01-F-005	3rd floor Across from room 302	5/24/16 5:00 AM	2.89	BA
25071-1-S01-S-001	Annex 1st floor room 411	5/24/16 5:00 AM	<0.120	ND
25071-1-S01-S-002	Annex 1st floor room 411	5/24/16 5:00 AM	<0.120	ND
25071-1-S01-S-003	Annex 1st floor room 411	5/24/16 5:00 AM	<0.120	ND
25071-1-S01-S-004	Annex 1st floor room 411	5/24/16 5:00 AM	<0.120	ND
25071-1-S01-S-005	Annex 1st floor room 411	5/24/16 5:00 AM	<0.120	ND
25071-1-N01-S-001	Annex 1st floor room 413	5/24/16 5:00 AM	<0.120	ND
25071-1-N01-S-002	Annex 1st floor room 413	5/24/16 5:00 AM	<0.120	ND
25071-1-N01-S-003	Annex 1st floor room 413	5/24/16 5:00 AM	<0.120	ND
25071-1-N01-S-004	Annex 1st floor room 413	5/24/16 5:00 AM	<0.120	ND
25071-1-N01-S-005	Annex 1st floor room 413	5/24/16 5:00 AM	<0.120	ND
25071-1-N02-F-001	1st floor by room 423	5/24/16 5:00 AM	<0.120	ND
25071-1-N02-F-002	1st floor by room 423	5/24/16 5:00 AM	<0.120	ND
25071-1-N02-F-003	1st floor by room 423	5/24/16 5:00 AM	<0.120	ND
25071-1-N02-F-004	1st floor by room 423	5/24/16 5:00 AM	<0.120	ND
25071-1-N02-F-005	1st floor by room 423	5/24/16 5:00 AM	<0.120	ND
25071-B-E01-S-001	Annex 1st floor Kitchen	5/24/16 5:00 AM	<0.120	ND
25071-B-E01-S-00	Annex 1st floor Kitchen	5/24/16 5:00 AM	<0.120	ND
25071-B-E01-S-00	Annex 1st floor Kitchen	5/24/16 5:00 AM	<0.120	ND
25071-B-E01-S-00	Annex 1st floor Kitchen	5/24/16 5:00 AM	<0.120	ND
25071-B-E01-S-00	Annex 1st floor Kitchen	5/24/16 5:00 AM	<0.120	ND

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations