



October 26, 2016

Dear Clemente families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Clemente samples were tested from 45 sites and the water sampled from 4 sinks and 3 drinking fountains were above the action level of 15 ppb: 4 sinks on the eighth floor in Room 801, two drinking fountains on the lower level near the north and south corridors, and one drinking fountain on the first floor. The water from the sinks and fountains have been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. Seven of the samples at Clemente returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for those sinks and fountains and will be addressed through the remediation plan. The full results of every school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health





26 de octubre de 2016

Estimadas familias de la escuela Clemente,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Clemente se tomaron muestras en 45 lugares y el agua de 4 piletas y 3 bebederos tenía rastros de plomo por encima del nivel de acción de 15 ppb: 4 piletas del octavo piso, en el salón 801; dos bebederos de la planta baja, cerca de los corredores norte y sur, y otro en el primer piso. El suministro de agua de esos dispositivos fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Siete de las muestras de Clemente registraron niveles elevados. Este no es problema general, sino específico de las cañerías de esos dispositivos, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en [cps.edu/leadtesting](http://cps.edu/leadtesting).

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](http://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool  
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago





## School Lead Water Testing - Data Collection Form

School Short Name **Clemente HS**

Date of test 10/13/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Clemente	51556	51556-LL-KIT-KS01-01	Kitchen West Wall 2-Basin sink on LEFT	6:00AM	0.31	BA
Clemente	51556	51556-LL-KIT-KS01-02	Kitchen West Wall 2-Basin sink on LEFT	6:00AM	0.36	BA
Clemente	51556	51556-LL-KIT-KS01-03	Kitchen West Wall 2-Basin sink on LEFT	6:00AM	0.52	BA
Clemente	51556	51556-LL-KIT-KS01-04	Kitchen West Wall 2-Basin sink on LEFT	6:00AM	0.57	BA
Clemente	51556	51556-LL-KIT-KS01-05	Kitchen West Wall 2-Basin sink on LEFT	6:00AM	0.62	BA
Clemente	51556	51556-LL-KIT-KS02-01	Kitchen West Wall 2-Basin sink on RIGHT	6:05AM	0.54	BA
Clemente	51556	51556-LL-KIT-KS02-02	Kitchen West Wall 2-Basin sink on RIGHT	6:05AM	0.57	BA
Clemente	51556	51556-LL-KIT-KS02-03	Kitchen West Wall 2-Basin sink on RIGHT	6:05AM	0.55	BA
Clemente	51556	51556-LL-KIT-KS02-04	Kitchen West Wall 2-Basin sink on RIGHT	6:05AM	0.54	BA
Clemente	51556	51556-LL-KIT-KS02-05	Kitchen West Wall 2-Basin sink on RIGHT	6:05AM	0.62	BA
Clemente	51556	51556-LL-KIT-KS03-01	Kitchen West Wall 3-Basin sink on left	6:10AM	0.42	BA
Clemente	51556	51556-LL-KIT-KS03-02	Kitchen West Wall 3-Basin sink on left	6:10AM	0.54	BA
Clemente	51556	51556-LL-KIT-KS03-03	Kitchen West Wall 3-Basin sink on left	6:10AM	0.38	BA
Clemente	51556	51556-LL-KIT-KS03-04	Kitchen West Wall 3-Basin sink on left	6:10AM	0.48	BA
Clemente	51556	51556-LL-KIT-KS03-05	Kitchen West Wall 3-Basin sink on left	6:10AM	0.58	BA
Clemente	51556	51556-LL-KIT-KS04-01	Kitchen West Wall 3-Basin sink Middle	6:15AM	2.8	BA
Clemente	51556	51556-LL-KIT-KS04-02	Kitchen West Wall 3-Basin sink Middle	6:15AM	0.79	BA
Clemente	51556	51556-LL-KIT-KS04-03	Kitchen West Wall 3-Basin sink Middle	6:15AM	0.51	BA
Clemente	51556	51556-LL-KIT-KS04-04	Kitchen West Wall 3-Basin sink Middle	6:15AM	0.37	BA
Clemente	51556	51556-LL-KIT-KS04-05	Kitchen West Wall 3-Basin sink Middle	6:15AM	0.42	BA
Clemente	51556	51556-LL-KIT-KS05-01	Kitchen West Wall 3-Basin sink Left	6:18AM	5.8	BA
Clemente	51556	51556-LL-KIT-KS05-02	Kitchen West Wall 3-Basin sink Left	6:18AM	0.55	BA
Clemente	51556	51556-LL-KIT-KS05-03	Kitchen West Wall 3-Basin sink Left	6:18AM	0.47	BA
Clemente	51556	51556-LL-KIT-KS05-04	Kitchen West Wall 3-Basin sink Left	6:18AM	0.22	BA
Clemente	51556	51556-LL-KIT-KS05-05	Kitchen West Wall 3-Basin sink Left	6:18AM	0.22	BA
Clemente	51556	51556-LL-HAL-F01-01	Lower level North Corridor	6:22AM	18	AA
Clemente	51556	51556-LL-HAL-F01-02	Lower level North Corridor	6:22AM	2.9	BA
Clemente	51556	51556-LL-HAL-F01-03	Lower level North Corridor	6:22AM	4.5	BA
Clemente	51556	51556-LL-HAL-F01-04	Lower level North Corridor	6:22AM	5.2	BA
Clemente	51556	51556-LL-HAL-F01-05	Lower level North Corridor	6:22AM	6	BA
Clemente	51556	51556-LL-HAL-F02-01	Lower Level South Corridor	6:25AM	40	BA
Clemente	51556	51556-LL-HAL-F02-02	Lower Level South Corridor	6:25AM	4.6	BA
Clemente	51556	51556-LL-HAL-F02-03	Lower Level South Corridor	6:25AM	5.1	BA
Clemente	51556	51556-LL-HAL-F02-04	Lower Level South Corridor	6:25AM	7	BA
Clemente	51556	51556-LL-HAL-F02-05	Lower Level South Corridor	6:25AM	9	BA
Clemente	51556	51556-1-HAL-F01-01	1st FL Entry North End	6:28AM	2.6	BA
Clemente	51556	51556-1-HAL-F01-02	1st FL Entry North End	6:28AM	6.7	BA
Clemente	51556	51556-1-HAL-F01-03	1st FL Entry North End	6:28AM	4.9	BA

Clemente	51556	51556-1-HAL-F01-04	1st FL Entry North End	6:28AM	6.4	BA
Clemente	51556	51556-1-HAL-F01-05	1st FL Entry North End	6:28AM	6.3	BA
Clemente	51556	51556-1-HAL-F02-01	1st FL Entry South End	6:30AM	12	BA
Clemente	51556	51556-1-HAL-F02-02	1st FL Entry South End	6:30AM	15	AA
Clemente	51556	51556-1-HAL-F02-03	1st FL Entry South End	6:30AM	12	BA
Clemente	51556	51556-1-HAL-F02-04	1st FL Entry South End	6:30AM	9.7	BA
Clemente	51556	51556-1-HAL-F02-05	1st FL Entry South End	6:30AM	18	AA
Clemente	51556	51556-2-HAL-F01-01	North Corridor Left Fountain	6:35AM	1.2	BA
Clemente	51556	51556-2-HAL-F01-02	North Corridor Left Fountain	6:35AM	0.77	BA
Clemente	51556	51556-2-HAL-F01-03	North Corridor Left Fountain	6:35AM	0.69	BA
Clemente	51556	51556-2-HAL-F01-04	North Corridor Left Fountain	6:35AM	0.7	BA
Clemente	51556	51556-2-HAL-F01-05	North Corridor Left Fountain	6:35AM	0.63	BA
Clemente	51556	51556-2-HAL-F02-01	North Corridor Right Fountain	6:42AM	0.71	BA
Clemente	51556	51556-2-HAL-F02-02	North Corridor Right Fountain	6:42AM	0.9	BA
Clemente	51556	51556-2-HAL-F02-03	North Corridor Right Fountain	6:42AM	0.85	BA
Clemente	51556	51556-2-HAL-F02-04	North Corridor Right Fountain	6:42AM	0.82	BA
Clemente	51556	51556-2-HAL-F02-05	North Corridor Right Fountain	6:42AM	0.9	BA
Clemente	51556	51556-2-HAL-F03-01	South Corridor Left Fountain	6:45AM	0.81	BA
Clemente	51556	51556-2-HAL-F03-02	South Corridor Left Fountain	6:45AM	0.76	BA
Clemente	51556	51556-2-HAL-F03-03	South Corridor Left Fountain	6:45AM	0.66	BA
Clemente	51556	51556-2-HAL-F03-04	South Corridor Left Fountain	6:45AM	0.53	BA
Clemente	51556	51556-2-HAL-F03-05	South Corridor Left Fountain	6:45AM	0.48	BA
Clemente	51556	51556-2-HAL-F04-01	South Corridor Right Fountain	6:50AM	0.41	BA
Clemente	51556	51556-2-HAL-F04-02	South Corridor Right Fountain	6:50AM	0.46	BA
Clemente	51556	51556-2-HAL-F04-03	South Corridor Right Fountain	6:50AM	0.44	BA
Clemente	51556	51556-2-HAL-F04-04	South Corridor Right Fountain	6:50AM	0.39	BA
Clemente	51556	51556-2-HAL-F04-05	South Corridor Right Fountain	6:50AM	0.38	BA
Clemente	51556	51556-3-HAL-F01-01	North Corridor Left Fountain	6:55AM	0.87	BA
Clemente	51556	51556-3-HAL-F01-02	North Corridor Left Fountain	6:55AM	0.77	BA
Clemente	51556	51556-3-HAL-F01-03	North Corridor Left Fountain	6:55AM	0.69	BA
Clemente	51556	51556-3-HAL-F01-04	North Corridor Left Fountain	6:55AM	0.65	BA
Clemente	51556	51556-3-HAL-F01-05	North Corridor Left Fountain	6:55AM	0.65	BA
Clemente	51556	51556-3-HAL-F02-01	North Corridor Right Fountain	6:58AM	0.54	BA
Clemente	51556	51556-3-HAL-F02-02	North Corridor Right Fountain	6:58AM	0.64	BA
Clemente	51556	51556-3-HAL-F02-03	North Corridor Right Fountain	6:58AM	0.68	BA
Clemente	51556	51556-3-HAL-F02-04	North Corridor Right Fountain	6:58AM	0.68	BA
Clemente	51556	51556-3-HAL-F02-05	North Corridor Right Fountain	6:58AM	0.68	BA
Clemente	51556	51556-3-HAL-F03-01	South Corridor Left Fountain	7:00AM	0.39	BA
Clemente	51556	51556-3-HAL-F03-02	South Corridor Left Fountain	7:00AM	0.43	BA
Clemente	51556	51556-3-HAL-F03-03	South Corridor Left Fountain	7:00AM	0.46	BA
Clemente	51556	51556-3-HAL-F03-04	South Corridor Left Fountain	7:00AM	0.4	BA
Clemente	51556	51556-3-HAL-F03-05	South Corridor Left Fountain	7:00AM	0.38	BA
Clemente	51556	51556-3-HAL-F04-01	South Corridor Right Fountain	7:05AM	0.29	BA
Clemente	51556	51556-3-HAL-F04-02	South Corridor Right Fountain	7:05AM	0.38	BA
Clemente	51556	51556-3-HAL-F04-03	South Corridor Right Fountain	7:05AM	0.36	BA
Clemente	51556	51556-3-HAL-F04-04	South Corridor Right Fountain	7:05AM	0.37	BA
Clemente	51556	51556-3-HAL-F04-05	South Corridor Right Fountain	7:05AM	0.36	BA
Clemente	51556	51556-4-HAL-F01-01	North End Left Fountain	7:10AM	0.57	BA
Clemente	51556	51556-4-HAL-F01-02	North End Left Fountain	7:10AM	0.53	BA
Clemente	51556	51556-4-HAL-F01-03	North End Left Fountain	7:10AM	0.53	BA
Clemente	51556	51556-4-HAL-F01-04	North End Left Fountain	7:10AM	0.53	BA

Clemente	51556	51556-4-HAL-F01-05	North End Left Fountain	7:10AM	0.5	BA
Clemente	51556	51556-4-HAL-F02-01	North End Right Fountain	7:15AM	0.44	BA
Clemente	51556	51556-4-HAL-F02-02	North End Right Fountain	7:15AM	0.48	BA
Clemente	51556	51556-4-HAL-F02-03	North End Right Fountain	7:15AM	0.47	BA
Clemente	51556	51556-4-HAL-F02-04	North End Right Fountain	7:15AM	0.44	BA
Clemente	51556	51556-4-HAL-F02-05	North End Right Fountain	7:15AM	0.41	BA
Clemente	51556	51556-4-HAL-F03-01	South End Hall Left Fountain	7:20AM	0.36	BA
Clemente	51556	51556-4-HAL-F03-02	South End Hall Left Fountain	7:20AM	0.48	BA
Clemente	51556	51556-4-HAL-F03-03	South End Hall Left Fountain	7:20AM	0.38	BA
Clemente	51556	51556-4-HAL-F03-04	South End Hall Left Fountain	7:20AM	0.45	BA
Clemente	51556	51556-4-HAL-F03-05	South End Hall Left Fountain	7:20AM	0.42	BA
Clemente	51556	51556-4-HAL-F04-01	South End Hall Right Fountain	7:25AM	0.32	BA
Clemente	51556	51556-4-HAL-F04-02	South End Hall Right Fountain	7:25AM	0.4	BA
Clemente	51556	51556-4-HAL-F04-03	South End Hall Right Fountain	7:25AM	0.34	BA
Clemente	51556	51556-4-HAL-F04-04	South End Hall Right Fountain	7:25AM	0.35	BA
Clemente	51556	51556-4-HAL-F04-05	South End Hall Right Fountain	7:25AM	0.43	BA
Clemente	51556	51556-8-HAL-F01-01	North End Hall Left Fountain	6:00AM	0.29	BA
Clemente	51556	51556-8-HAL-F01-02	North End Hall Left Fountain	6:00AM	0.35	BA
Clemente	51556	51556-8-HAL-F01-03	North End Hall Left Fountain	6:00AM	0.35	BA
Clemente	51556	51556-8-HAL-F01-04	North End Hall Left Fountain	6:00AM	0.37	BA
Clemente	51556	51556-8-HAL-F01-05	North End Hall Left Fountain	6:00AM	0.35	BA
Clemente	51556	51556-8-HAL-F02-01	North End Right Fountain	6:05AM	0.22	BA
Clemente	51556	51556-8-HAL-F02-02	North End Right Fountain	6:05AM	0.29	BA
Clemente	51556	51556-8-HAL-F02-03	North End Right Fountain	6:05AM	0.31	BA
Clemente	51556	51556-8-HAL-F02-04	North End Right Fountain	6:05AM	0.33	BA
Clemente	51556	51556-8-HAL-F02-05	North End Right Fountain	6:05AM	0.31	BA
Clemente	51556	51556-8-HAL-F03-01	South End Left Fountain	6:10AM	0.32	BA
Clemente	51556	51556-8-HAL-F03-02	South End Left Fountain	6:10AM	0.46	BA
Clemente	51556	51556-8-HAL-F03-03	South End Left Fountain	6:10AM	0.48	BA
Clemente	51556	51556-8-HAL-F03-04	South End Left Fountain	6:10AM	0.47	BA
Clemente	51556	51556-8-HAL-F03-05	South End Left Fountain	6:10AM	0.57	BA
Clemente	51556	51556-8-HAL-F04-01	South End Right Fountain	6:15AM	0.5	BA
Clemente	51556	51556-8-HAL-F04-02	South End Right Fountain	6:15AM	0.41	BA
Clemente	51556	51556-8-HAL-F04-03	South End Right Fountain	6:15AM	0.42	BA
Clemente	51556	51556-8-HAL-F04-04	South End Right Fountain	6:15AM	0.39	BA
Clemente	51556	51556-8-HAL-F04-05	South End Right Fountain	6:15AM	0.4	BA
Clemente	51556	51556-8-801-S03-01	South Wall East End RM 801	6:22AM	0.77	BA
Clemente	51556	51556-8-801-S03-02	South Wall East End RM 801	6:22AM	0.71	BA
Clemente	51556	51556-8-801-S03-03	South Wall East End RM 801	6:22AM	0.41	BA
Clemente	51556	51556-8-801-S03-04	South Wall East End RM 801	6:22AM	0.43	BA
Clemente	51556	51556-8-801-S03-05	South Wall East End RM 801	6:22AM	0.51	BA
Clemente	51556	51556-8-801-S05-01	West Wall South End RM 801	6:28AM	7.1	BA
Clemente	51556	51556-8-801-S05-02	West Wall South End RM 801	6:28AM	3.3	BA
Clemente	51556	51556-8-801-S05-03	West Wall South End RM 801	6:28AM	2.3	BA
Clemente	51556	51556-8-801-S05-04	West Wall South End RM 801	6:28AM	2.9	BA
Clemente	51556	51556-8-801-S05-05	West Wall South End RM 801	6:28AM	2.1	BA
Clemente	51556	51556-8-801-S06-01	RM 801 West Wall North End	6:30AM	43	AA
Clemente	51556	51556-8-801-S06-02	RM 801 West Wall North End	6:30AM	82	AA
Clemente	51556	51556-8-801-S06-03	RM 801 West Wall North End	6:30AM	43	AA
Clemente	51556	51556-8-801-S06-04	RM 801 West Wall North End	6:30AM	32	AA
Clemente	51556	51556-8-801-S06-05	RM 801 West Wall North End	6:30AM	15	AA

Clemente	51556	51556-8-801-S07-01	RM 801 North Wall West side single basin NW corner of rm	6:32AM	150	AA
Clemente	51556	51556-8-801-S07-02	RM 801 North Wall West side single basin NW corner of rm	6:32AM	67	AA
Clemente	51556	51556-8-801-S07-03	RM 801 North Wall West side single basin NW corner of rm	6:32AM	120	AA
Clemente	51556	51556-8-801-S07-04	RM 801 North Wall West side single basin NW corner of rm	6:32AM	160	AA
Clemente	51556	51556-8-801-S07-05	RM 801 North Wall West side single basin NW corner of rm	6:32AM	200	AA
Clemente	51556	51556-8-801-S08-01	North Wall West side single basin nort of commercial oven	6:35AM	180	AA
Clemente	51556	51556-8-801-S08-02	North Wall West side single basin nort of commercial oven	6:35AM	52	AA
Clemente	51556	51556-8-801-S08-03	North Wall West side single basin nort of commercial oven	6:35AM	34	AA
Clemente	51556	51556-8-801-S08-04	North Wall West side single basin nort of commercial oven	6:35AM	44	AA
Clemente	51556	51556-8-801-S08-05	North Wall West side single basin nort of commercial oven	6:35AM	51	AA
Clemente	51556	51556-8-801-S09-01	N. Wall Middle 3-Basin sink Left faucet	6:40AM	1.3	BA
Clemente	51556	51556-8-801-S09-02	N. Wall Middle 3-Basin sink Left faucet	6:40AM	0.93	BA
Clemente	51556	51556-8-801-S09-03	N. Wall Middle 3-Basin sink Left faucet	6:40AM	0.43	BA
Clemente	51556	51556-8-801-S09-04	N. Wall Middle 3-Basin sink Left faucet	6:40AM	0.38	BA
Clemente	51556	51556-8-801-S09-05	N. Wall Middle 3-Basin sink Left faucet	6:40AM	0.38	BA
Clemente	51556	51556-8-801-S10-01	N Wall Middle 3-Basin Sink Right Faucet	6:43AM	3.2	BA
Clemente	51556	51556-8-801-S10-02	N Wall Middle 3-Basin Sink Right Faucet	6:43AM	2.5	BA
Clemente	51556	51556-8-801-S10-03	N Wall Middle 3-Basin Sink Right Faucet	6:43AM	0.37	BA
Clemente	51556	51556-8-801-S10-04	N Wall Middle 3-Basin Sink Right Faucet	6:43AM	0.24	BA
Clemente	51556	51556-8-801-S10-05	N Wall Middle 3-Basin Sink Right Faucet	6:43AM	0.23	BA
Clemente	51556	51556-8-801-S11-01	Center of RM East of Deep Fryer	6:50AM	230	AA
Clemente	51556	51556-8-801-S11-02	Center of RM East of Deep Fryer	6:50AM	160	AA
Clemente	51556	51556-8-801-S11-03	Center of RM East of Deep Fryer	6:50AM	86	AA
Clemente	51556	51556-8-801-S11-04	Center of RM East of Deep Fryer	6:50AM	53	AA
Clemente	51556	51556-8-801-S11-05	Center of RM East of Deep Fryer	6:50AM	46	AA
Clemente	51556	51556-7-HAL-F01-01	North End Left Fountain	6:53AM	0.37	BA
Clemente	51556	51556-7-HAL-F01-02	North End Left Fountain	6:53AM	0.3	BA
Clemente	51556	51556-7-HAL-F01-03	North End Left Fountain	6:53AM	0.27	BA
Clemente	51556	51556-7-HAL-F01-04	North End Left Fountain	6:53AM	0.26	BA
Clemente	51556	51556-7-HAL-F01-05	North End Left Fountain	6:53AM	0.22	BA
Clemente	51556	51556-7-HAL-F02-01	North End Right Fountain	6:57AM	0.17	BA
Clemente	51556	51556-7-HAL-F02-02	North End Right Fountain	6:57AM	0.17	BA
Clemente	51556	51556-7-HAL-F02-03	North End Right Fountain	6:57AM	0.17	BA
Clemente	51556	51556-7-HAL-F02-04	North End Right Fountain	6:57AM	<0.50	BA
Clemente	51556	51556-7-HAL-F02-05	North End Right Fountain	6:57AM	<0.50	BA
Clemente	51556	51556-7-HAL-F03-01	South End Left Fountain	7:00AM	0.31	BA
Clemente	51556	51556-7-HAL-F03-02	South End Left Fountain	7:00AM	0.22	BA
Clemente	51556	51556-7-HAL-F03-03	South End Left Fountain	7:00AM	0.2	BA
Clemente	51556	51556-7-HAL-F03-04	South End Left Fountain	7:00AM	0.17	BA
Clemente	51556	51556-7-HAL-F03-05	South End Left Fountain	7:00AM	0.16	BA
Clemente	51556	51556-7-HAL-F04-01	South End Right Fountain	7:02AM	0.3	BA
Clemente	51556	51556-7-HAL-F04-02	South End Right Fountain	7:02AM	0.33	BA
Clemente	51556	51556-7-HAL-F04-03	South End Right Fountain	7:02AM	0.33	BA
Clemente	51556	51556-7-HAL-F04-04	South End Right Fountain	7:02AM	0.29	BA



Clemente	51556	51556-7-HAL-F04-05	South End Right Fountain	7:02AM	0.25	BA
Clemente	51556	51556-6-HAL-F01-01	North End Left Fountain	7:05AM	0.23	BA
Clemente	51556	51556-6-HAL-F01-02	North End Left Fountain	7:05AM	0.21	BA
Clemente	51556	51556-6-HAL-F01-03	North End Left Fountain	7:05AM	0.2	BA
Clemente	51556	51556-6-HAL-F01-04	North End Left Fountain	7:05AM	0.18	BA
Clemente	51556	51556-6-HAL-F01-05	North End Left Fountain	7:05AM	0.16	BA
Clemente	51556	51556-6-HAL-F02-01	North End Right Fountain	7:10AM	<0.50	BA
Clemente	51556	51556-6-HAL-F02-02	North End Right Fountain	7:10AM	<0.50	BA
Clemente	51556	51556-6-HAL-F02-03	North End Right Fountain	7:10AM	0.18	BA
Clemente	51556	51556-6-HAL-F02-04	North End Right Fountain	7:10AM	<0.50	BA
Clemente	51556	51556-6-HAL-F02-05	North End Right Fountain	7:10AM	<0.50	BA
Clemente	51556	51556-6-HAL-F03-01	South End Left Fountain	7:13AM	0.24	BA
Clemente	51556	51556-6-HAL-F03-02	South End Left Fountain	7:13AM	0.23	BA
Clemente	51556	51556-6-HAL-F03-03	South End Left Fountain	7:13AM	0.19	BA
Clemente	51556	51556-6-HAL-F03-04	South End Left Fountain	7:13AM	0.19	BA
Clemente	51556	51556-6-HAL-F03-05	South End Left Fountain	7:13AM	0.17	BA
Clemente	51556	51556-6-HAL-F04-01	South End Right Fountain	7:20AM	<0.50	BA
Clemente	51556	51556-6-HAL-F04-02	South End Right Fountain	7:20AM	<0.50	BA
Clemente	51556	51556-6-HAL-F04-03	South End Right Fountain	7:20AM	<0.50	BA
Clemente	51556	51556-6-HAL-F04-04	South End Right Fountain	7:20AM	<0.50	BA
Clemente	51556	51556-6-HAL-F04-05	South End Right Fountain	7:20AM	<0.50	BA
Clemente	51556	51556-5-HAL-F01-01	North End Left Fountain	7:23AM	0.78	BA
Clemente	51556	51556-5-HAL-F01-02	North End Left Fountain	7:23AM	0.44	BA
Clemente	51556	51556-5-HAL-F01-03	North End Left Fountain	7:23AM	0.37	BA
Clemente	51556	51556-5-HAL-F01-04	North End Left Fountain	7:23AM	0.33	BA
Clemente	51556	51556-5-HAL-F01-05	North End Left Fountain	7:23AM	0.33	BA
Clemente	51556	51556-5-HAL-F02-01	North End Right Fountain	7:26AM	0.36	BA
Clemente	51556	51556-5-HAL-F02-02	North End Right Fountain	7:26AM	0.27	BA
Clemente	51556	51556-5-HAL-F02-03	North End Right Fountain	7:26AM	0.26	BA
Clemente	51556	51556-5-HAL-F02-04	North End Right Fountain	7:26AM	0.23	BA
Clemente	51556	51556-5-HAL-F02-05	North End Right Fountain	7:26AM	0.22	BA
Clemente	51556	51556-5-HAL-F03-01	South End Left Fountain	7:30AM	0.33	BA
Clemente	51556	51556-5-HAL-F03-02	South End Left Fountain	7:30AM	0.26	BA
Clemente	51556	51556-5-HAL-F03-03	South End Left Fountain	7:30AM	0.22	BA
Clemente	51556	51556-5-HAL-F03-04	South End Left Fountain	7:30AM	0.19	BA
Clemente	51556	51556-5-HAL-F03-05	South End Left Fountain	7:30AM	0.21	BA
Clemente	51556	51556-5-HAL-F04-01	South End Right Fountain	7:35AM	<0.50	BA
Clemente	51556	51556-5-HAL-F04-02	South End Right Fountain	7:35AM	<0.50	BA
Clemente	51556	51556-5-HAL-F04-03	South End Right Fountain	7:35AM	0.18	BA
Clemente	51556	51556-5-HAL-F04-04	South End Right Fountain	7:35AM	<0.50	BA
Clemente	51556	51556-5-HAL-F04-05	South End Right Fountain	7:35AM	<0.50	BA
Clemente Linked Addition	56551	56551-B-HAL-F01-01	Basment Hall outside Boys Locker RM Left	7:40AM	0.54	BA
Clemente Linked Addition	56551	56551-B-HAL-F01-02	Basment Hall outside Boys Locker RM Left	7:40AM	0.23	BA
Clemente Linked Addition	56551	56551-B-HAL-F01-03	Basment Hall outside Boys Locker RM Left	7:40AM	0.17	BA
Clemente Linked Addition	56551	56551-B-HAL-F01-04	Basment Hall outside Boys Locker RM Left	7:40AM	0.37	BA
Clemente Linked Addition	56551	56551-B-HAL-F01-05	Basment Hall outside Boys Locker RM Left	7:40AM	0.37	BA
Clemente Linked Addition	56551	56551-B-HAL-F02-01	Basement Hall outside Boys Locker RM Right	7:45AM	1.4	BA
Clemente Linked Addition	56551	56551-B-HAL-F02-02	Basement Hall outside Boys Locker RM Right	7:45AM	0.6	BA
Clemente Linked Addition	56551	56551-B-HAL-F02-03	Basement Hall outside Boys Locker RM Right	7:45AM	0.83	BA
Clemente Linked Addition	56551	56551-B-HAL-F02-04	Basement Hall outside Boys Locker RM Right	7:45AM	0.65	BA
Clemente Linked Addition	56551	56551-B-HAL-F02-05	Basement Hall outside Boys Locker RM Right	7:45AM	0.75	BA

Clemente Linked Addition	56551	56551-B-HAL-F03-01	Outside Girls Locker RM Left	7:50AM	6.5	BA
Clemente Linked Addition	56551	56551-B-HAL-F03-02	Outside Girls Locker RM Left	7:50AM	1.2	BA
Clemente Linked Addition	56551	56551-B-HAL-F03-03	Outside Girls Locker RM Left	7:50AM	0.96	BA
Clemente Linked Addition	56551	56551-B-HAL-F03-04	Outside Girls Locker RM Left	7:50AM	0.9	BA
Clemente Linked Addition	56551	56551-B-HAL-F03-05	Outside Girls Locker RM Left	7:50AM	0.81	BA
Clemente Linked Addition	56551	56551-B-HAL-F04-01	Outside Girls Locker RM Right	7:55AM	3.4	BA
Clemente Linked Addition	56551	56551-B-HAL-F04-02	Outside Girls Locker RM Right	7:55AM	1.3	BA
Clemente Linked Addition	56551	56551-B-HAL-F04-03	Outside Girls Locker RM Right	7:55AM	1.1	BA
Clemente Linked Addition	56551	56551-B-HAL-F04-04	Outside Girls Locker RM Right	7:55AM	0.89	BA
Clemente Linked Addition	56551	56551-B-HAL-F04-05	Outside Girls Locker RM Right	7:55AM	0.85	BA
Clemente Linked Addition	56551	56551-1-HAL-F01-01	1st FL Hall North End outside Gym Left	8:00AM	1.4	BA
Clemente Linked Addition	56551	56551-1-HAL-F01-02	1st FL Hall North End outside Gym Left	8:00AM	2.7	BA
Clemente Linked Addition	56551	56551-1-HAL-F01-03	1st FL Hall North End outside Gym Left	8:00AM	2.5	BA
Clemente Linked Addition	56551	56551-1-HAL-F01-04	1st FL Hall North End outside Gym Left	8:00AM	2	BA
Clemente Linked Addition	56551	56551-1-HAL-F01-05	1st FL Hall North End outside Gym Left	8:00AM	1.7	BA
Clemente Linked Addition	56551	56551-1-HAL-F02-01	1st FL Hall North End outside Gym Right	8:05AM	1.3	BA
Clemente Linked Addition	56551	56551-1-HAL-F02-02	1st FL Hall North End outside Gym Right	8:05AM	1.2	BA
Clemente Linked Addition	56551	56551-1-HAL-F02-03	1st FL Hall North End outside Gym Right	8:05AM	1.1	BA
Clemente Linked Addition	56551	56551-1-HAL-F02-04	1st FL Hall North End outside Gym Right	8:05AM	0.98	BA
Clemente Linked Addition	56551	56551-1-HAL-F02-05	1st FL Hall North End outside Gym Right	8:05AM	0.88	BA
Clemente Linked Addition	56551	56551-1-HAL-F03-01	Outside Gym South End Left	8:10AM	0.94	BA
Clemente Linked Addition	56551	56551-1-HAL-F03-02	Outside Gym South End Left	8:10AM	1.7	BA
Clemente Linked Addition	56551	56551-1-HAL-F03-03	Outside Gym South End Left	8:10AM	1.6	BA
Clemente Linked Addition	56551	56551-1-HAL-F03-04	Outside Gym South End Left	8:10AM	1.3	BA
Clemente Linked Addition	56551	56551-1-HAL-F03-05	Outside Gym South End Left	8:10AM	1.1	BA
Clemente Linked Addition	56551	56551-1-HAL-F04-01	Outside Gym South End Right	8:15AM	1.1	BA
Clemente Linked Addition	56551	56551-1-HAL-F04-02	Outside Gym South End Right	8:15AM	0.91	BA
Clemente Linked Addition	56551	56551-1-HAL-F04-03	Outside Gym South End Right	8:15AM	0.9	BA
Clemente Linked Addition	56551	56551-1-HAL-F04-04	Outside Gym South End Right	8:15AM	0.79	BA
Clemente Linked Addition	56551	56551-1-HAL-F04-05	Outside Gym South End Right	8:15AM	0.69	BA
Clemente Linked Addition	56551	56551-1-POL-F01-01	Pool East Wall North End	7:35AM	2.4	BA
Clemente Linked Addition	56551	56551-1-POL-F01-02	Pool East Wall North End	7:35AM	1.1	BA
Clemente Linked Addition	56551	56551-1-POL-F01-03	Pool East Wall North End	7:35AM	1.2	BA
Clemente Linked Addition	56551	56551-1-POL-F01-04	Pool East Wall North End	7:35AM	1.1	BA
Clemente Linked Addition	56551	56551-1-POL-F01-05	Pool East Wall North End	7:35AM	0.9	BA
Clemente Linked Addition	56551	56551-1-POL-F02-01	Pool East Wall South End	7:40AM	0.67	BA
Clemente Linked Addition	56551	56551-1-POL-F02-02	Pool East Wall South End	7:40AM	1.7	BA
Clemente Linked Addition	56551	56551-1-POL-F02-03	Pool East Wall South End	7:40AM	2.7	BA
Clemente Linked Addition	56551	56551-1-POL-F02-04	Pool East Wall South End	7:40AM	1.9	BA
Clemente Linked Addition	56551	56551-1-POL-F02-05	Pool East Wall South End	7:40AM	2	BA
Clemente Linked Addition	56551	56551-2-231-KS01-01	Culinary Art RM 231 N. Wall Left	7:45AM	0.27	BA
Clemente Linked Addition	56551	56551-2-231-KS01-02	Culinary Art RM 231 N. Wall Left	7:45AM	0.4	BA
Clemente Linked Addition	56551	56551-2-231-KS01-03	Culinary Art RM 231 N. Wall Left	7:45AM	1.4	BA
Clemente Linked Addition	56551	56551-2-231-KS01-04	Culinary Art RM 231 N. Wall Left	7:45AM	1.6	BA
Clemente Linked Addition	56551	56551-2-231-KS01-05	Culinary Art RM 231 N. Wall Left	7:45AM	1	BA
Clemente Linked Addition	56551	56551-2-231-KS02-01	Culinary Art RM 231 N. Wall Middle	7:50AM	<0.50	BA
Clemente Linked Addition	56551	56551-2-231-KS02-02	Culinary Art RM 231 N. Wall Middle	7:50AM	1.3	BA
Clemente Linked Addition	56551	56551-2-231-KS02-03	Culinary Art RM 231 N. Wall Middle	7:50AM	1.4	BA
Clemente Linked Addition	56551	56551-2-231-KS02-04	Culinary Art RM 231 N. Wall Middle	7:50AM	0.93	BA
Clemente Linked Addition	56551	56551-2-231-KS02-05	Culinary Art RM 231 N. Wall Middle	7:50AM	0.74	BA
Clemente Linked Addition	56551	56551-2-231-KS03-01	Culinary Arts RM 231 N. Wall Right	7:55AM	1.5	BA



Clemente Linked Addition	56551	56551-2-231-KS03-02	Culinary Arts RM 231 N. Wall Right	7:55AM	1.8	BA
Clemente Linked Addition	56551	56551-2-231-KS03-03	Culinary Arts RM 231 N. Wall Right	7:55AM	1.3	BA
Clemente Linked Addition	56551	56551-2-231-KS03-04	Culinary Arts RM 231 N. Wall Right	7:55AM	1.2	BA
Clemente Linked Addition	56551	56551-2-231-KS03-05	Culinary Arts RM 231 N. Wall Right	7:55AM	0.94	BA
Clemente Linked Addition	56551	56551-2-HAL-F01-01	North End Left Fountain	8:00AM	0.91	BA
Clemente Linked Addition	56551	56551-2-HAL-F01-02	North End Left Fountain	8:00AM	0.71	BA
Clemente Linked Addition	56551	56551-2-HAL-F01-03	North End Left Fountain	8:00AM	0.64	BA
Clemente Linked Addition	56551	56551-2-HAL-F01-04	North End Left Fountain	8:00AM	0.54	BA
Clemente Linked Addition	56551	56551-2-HAL-F01-05	North End Left Fountain	8:00AM	0.55	BA
Clemente Linked Addition	56551	56551-2-HAL-F02-01	North End Right Fountain	8:05AM	0.59	BA
Clemente Linked Addition	56551	56551-2-HAL-F02-02	North End Right Fountain	8:05AM	0.63	BA
Clemente Linked Addition	56551	56551-2-HAL-F02-03	North End Right Fountain	8:05AM	0.59	BA
Clemente Linked Addition	56551	56551-2-HAL-F02-04	North End Right Fountain	8:05AM	0.48	BA
Clemente Linked Addition	56551	56551-2-HAL-F02-05	North End Right Fountain	8:05AM	0.54	BA
Clemente Linked Addition	56551	56551-2-HAL-F03-01	South End Left Fountain	8:10AM	0.9	BA
Clemente Linked Addition	56551	56551-2-HAL-F03-02	South End Left Fountain	8:10AM	1.1	BA
Clemente Linked Addition	56551	56551-2-HAL-F03-03	South End Left Fountain	8:10AM	1.3	BA
Clemente Linked Addition	56551	56551-2-HAL-F03-04	South End Left Fountain	8:10AM	1.2	BA
Clemente Linked Addition	56551	56551-2-HAL-F03-05	South End Left Fountain	8:10AM	1	BA
Clemente Linked Addition	56551	56551-2-HAL-F04-01	South End Right Fountain	8:15AM	0.71	BA
Clemente Linked Addition	56551	56551-2-HAL-F04-02	South End Right Fountain	8:15AM	0.65	BA
Clemente Linked Addition	56551	56551-2-HAL-F04-03	South End Right Fountain	8:15AM	0.7	BA
Clemente Linked Addition	56551	56551-2-HAL-F04-04	South End Right Fountain	8:15AM	0.76	BA
Clemente Linked Addition	56551	56551-2-HAL-F04-05	South End Right Fountain	8:15AM	0.89	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations