



School Lead Water Testing Summary

School Short Name **Kozminski**
Address 936 E. 54th St.
Facility ID 51405
CPS Team Member Craig Edgerley
MEC Team Member Mark Wyco

Length of time water remained in pipes before sampled [Approx 9-10 hours](#)
Water last used (Time and date) [Approx 10 PM 5/3/16](#)
Date of test [5/4/2016](#)
Report based on lab results dated [5/10/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51045-B-S-CS-01	Kitchen	6:53 AM 5/4/16	ND	-
51045-1-S-F-02	Hallway by Main Office	6:55 AM 5/4/16	6.52	BA
51045-2-N-F-03	Hallway by Room 211	7:02 AM 5/4/16	ND	-
51045-3-S-F-04	Hallway by Room 304	7:05 AM 5/4/16	5.57	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations