



School Lead Water Testing - Data Collection Form

School Name

Bridge

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51004-1-N-F01-001	Modular- Outside Girls Toilets, Fountain 1	6/21/6 5:00 AM	<0.120	ND
51004-1-N-F01-002	Modular- Outside Girls Toilets, Fountain 1	6/21/6 5:00 AM	<0.120	ND
51004-1-N-F01-003	Modular- Outside Girls Toilets, Fountain 1	6/21/6 5:00 AM	<0.120	ND
51004-1-N-F01-004	Modular- Outside Girls Toilets, Fountain 1	6/21/6 5:00 AM	<0.120	ND
51004-1-N-F01-005	Modular- Outside Girls Toilets, Fountain 1	6/21/6 5:00 AM	<0.120	ND
51004-1-S-F02-001	Modular- Outside Girls Toilets, Fountain 2	6/21/6 5:00 AM	0.131	BA
51004-1-S-F02-002	Modular- Outside Girls Toilets, Fountain 2	6/21/6 5:00 AM	<0.120	ND
51004-1-S-F02-003	Modular- Outside Girls Toilets, Fountain 2	6/21/6 5:00 AM	<0.120	ND
51004-1-S-F02-004	Modular- Outside Girls Toilets, Fountain 2	6/21/6 5:00 AM	<0.120	ND
51004-1-S-F02-005	Modular- Outside Girls Toilets, Fountain 2	6/21/6 5:00 AM	<0.120	ND
51004-1-N-CS01-001	Main- North Kitchen Sink	6/21/6 5:00 AM	0.673	BA
51004-1-N-CS01-002	Main- North Kitchen Sink	6/21/6 5:00 AM	0.397	BA
51004-1-N-CS01-003	Main- North Kitchen Sink	6/21/6 5:00 AM	0.325	BA
51004-1-N-CS01-004	Main- North Kitchen Sink	6/21/6 5:00 AM	0.309	BA
51004-1-N-CS01-005	Main- North Kitchen Sink	6/21/6 5:00 AM	1.2	BA
51004-1-N-F02-001	Main- 1st FI Corridor Outside Kitchen, Fountain	6/21/6 5:00 AM	1.39	BA
51004-1-N-F02-002	Main- 1st FI Corridor Outside Kitchen, Fountain	6/21/6 5:00 AM	0.165	BA
51004-1-N-F02-003	Main- 1st FI Corridor Outside Kitchen, Fountain	6/21/6 5:00 AM	0.141	BA
51004-1-N-F02-005	Main- 1st FI Corridor Outside Kitchen, Fountain	6/21/6 5:00 AM	<0.120	ND
51004-1-W-F03-001	Main- 1st FI Corridor Outside Main Office Fountain	6/21/6 5:00 AM	1.04	BA
51004-1-W-F03-002	Main- 1st FI Corridor Outside Main Office Fountain	6/21/6 5:00 AM	0.792	BA
51004-1-W-F03-003	Main- 1st FI Corridor Outside Main Office Fountain	6/21/6 5:00 AM	0.436	BA
51004-1-W-F03-004	Main- 1st FI Corridor Outside Main Office Fountain	6/21/6 5:00 AM	0.24	BA
51004-1-W-F03-005	Main- 1st FI Corridor Outside Main Office Fountain	6/21/6 5:00 AM	0.185	BA
51004-1-W-F04-001	Main- 1st FI Corridor Outside Room 103, Fountain	6/21/6 5:00 AM	1.1	BA
51004-1-W-F04-002	Main- 1st FI Corridor Outside Room 103, Fountain	6/21/6 5:00 AM	0.871	BA
51004-1-W-F04-003	Main- 1st FI Corridor Outside Room 103, Fountain	6/21/6 5:00 AM	0.872	BA
51004-1-W-F04-004	Main- 1st FI Corridor Outside Room 103, Fountain	6/21/6 5:00 AM	0.764	BA
51004-1-W-F04-005	Main- 1st FI Corridor Outside Room 103, Fountain	6/21/6 5:00 AM	0.749	BA
51004-2-N-F01-001	Main- 2nd FI Outside Room 212, Fountain	6/21/6 5:00 AM	0.761	BA
51004-2-N-F01-002	Main- 2nd FI Outside Room 212, Fountain	6/21/6 5:00 AM	0.859	BA
51004-2-N-F01-003	Main- 2nd FI Outside Room 212, Fountain	6/21/6 5:00 AM	0.754	BA
51004-2-N-F01-004	Main- 2nd FI Outside Room 212, Fountain	6/21/6 5:00 AM	0.794	BA
51004-2-N-F01-005	Main- 2nd FI Outside Room 212, Fountain	6/21/6 5:00 AM	0.625	BA
51004-2-W-F02-001	Main- 2nd FI Outside Room 204, Fountain	6/21/6 5:00 AM	1.09	BA
51004-2-W-F02-002	Main- 2nd FI Outside Room 204, Fountain	6/21/6 5:00 AM	0.708	BA
51004-2-W-F02-003	Main- 2nd FI Outside Room 204, Fountain	6/21/6 5:00 AM	0.914	BA
51004-2-W-F02-004	Main- 2nd FI Outside Room 204, Fountain	6/21/6 5:00 AM	0.897	BA
51004-2-W-F02-005	Main- 2nd FI Outside Room 204, Fountain	6/21/6 5:00 AM	0.702	BA
51004-2-S-F03-001	Main- 2nd FI Outside Room 203, Fountain	6/21/6 5:00 AM	1.39	BA
51004-2-S-F03-002	Main- 2nd FI Outside Room 203, Fountain	6/21/6 5:00 AM	0.986	BA
51004-2-S-F03-003	Main- 2nd FI Outside Room 203, Fountain	6/21/6 5:00 AM	1.73	BA
51004-2-S-F03-004	Main- 2nd FI Outside Room 203, Fountain	6/21/6 5:00 AM	1.08	BA
51004-2-S-F03-005	Main- 2nd FI Outside Room 203, Fountain	6/21/6 5:00 AM	0.973	BA
51004-1-W-WC01-001	Branch- 1st FL Outside Boys Toilet, Fountain	6/21/6 5:00 AM	0.931	BA
51004-1-W-WC01-002	Branch- 1st FL Outside Boys Toilet, Fountain	6/21/6 5:00 AM	0.346	BA
51004-1-W-WC01-003	Branch- 1st FL Outside Boys Toilet, Fountain	6/21/6 5:00 AM	0.315	BA
51004-1-W-WC01-004	Branch- 1st FL Outside Boys Toilet, Fountain	6/21/6 5:00 AM	0.54	BA
51004-1-W-WC01-005	Branch- 1st FL Outside Boys Toilet, Fountain	6/21/6 5:00 AM	0.294	BA
51004-1-E-WC04-001	Branch- 1st FL Outside Girls Toilet, Fountain	6/21/6 5:00 AM	1.4	BA
51004-1-E-WC04-002	Branch- 1st FL Outside Girls Toilet, Fountain	6/21/6 5:00 AM	1.71	BA
51004-1-E-WC04-003	Branch- 1st FL Outside Girls Toilet, Fountain	6/21/6 5:00 AM	0.698	BA
51004-1-E-WC04-004	Branch- 1st FL Outside Girls Toilet, Fountain	6/21/6 5:00 AM	0.263	BA
51004-1-E-WC04-005	Branch- 1st FL Outside Girls Toilet, Fountain	6/21/6 5:00 AM	0.326	BA
51004-2-S-CS01-001	Branch- Kitchen West Wall, Sink	6/21/6 5:00 AM	0.265	BA
51004-2-S-CS01-002	Branch- Kitchen West Wall, Sink	6/21/6 5:00 AM	0.326	BA
51004-2-S-CS01-003	Branch- Kitchen West Wall, Sink	6/21/6 5:00 AM	0.837	BA
51004-2-S-CS01-004	Branch- Kitchen West Wall, Sink	6/21/6 5:00 AM	0.563	BA
51004-2-S-CS01-005	Branch- Kitchen West Wall, Sink	6/21/6 5:00 AM	0.444	BA
51004-2-E-WC02-001	Branch, 2nd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.24	BA
51004-2-E-WC02-002	Branch, 2nd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.42	BA
51004-2-E-WC02-003	Branch, 2nd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	0.54	BA
51004-2-E-WC02-004	Branch, 2nd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	0.215	BA
51004-2-E-WC02-005	Branch, 2nd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	0.268	BA
51004-2-W-WC03-001	Branch- 2nd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.734	BA
51004-2-W-WC03-002	Branch- 2nd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	1.41	BA
51004-2-W-WC03-003	Branch- 2nd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.942	BA
51004-2-W-WC03-004	Branch- 2nd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.797	BA
51004-2-W-WC03-005	Branch- 2nd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.743	BA
51004-3-W-WC01-001	Branch, 3rd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.94	BA
51004-3-W-WC01-002	Branch, 3rd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.98	BA
51004-3-W-WC01-003	Branch, 3rd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.35	BA
51004-3-W-WC01-004	Branch, 3rd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.65	BA
51004-3-W-WC01-005	Branch, 3rd FL Outside Boys Toilets, Fountain	6/21/6 5:00 AM	1.69	BA
51004-3-W-WC02-001	Branch, 3rd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.925	BA
51004-3-W-WC02-002	Branch, 3rd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.649	BA
51004-3-W-WC02-003	Branch, 3rd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	1.32	BA
51004-3-W-WC02-004	Branch, 3rd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	0.516	BA
51004-3-W-WC02-005	Branch, 3rd FL Outside Girls Toilets, Fountain	6/21/6 5:00 AM	1.77	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations