



School Lead Water Testing - Data Collection Form

School Short Name **Ogden Elementary**

Length of time water remained in pipes before sampled (hours) 7+
Date of test 05/10/16
Water last used (Time and date) 5/9/16

Sample ID #	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-K-CS-01	5/10/16 5:56 AM	ND	None Detected (ND)
1-NE-WC-02	5/10/16 5:59 AM	ND	None Detected (ND)
1-NE-WC-03	5/10/16 6:01 AM	ND	None Detected (ND)
1-NE-WC-04	5/10/16 6:03 AM	ND	None Detected (ND)
1-NE-WC-05	5/10/16 6:06 AM	ND	None Detected (ND)
1-NE-WC-06	5/10/16 6:08 AM	ND	None Detected (ND)
1-C-WC-07	5/10/16 6:10 AM	ND	None Detected (ND)
1-N-WC-08	5/10/16 6:12 AM	ND	None Detected (ND)
1-NW-WC-09	5/10/16 6:14 AM	ND	None Detected (ND)
2-NW-WC-10	5/10/16 6:16 AM	ND	None Detected (ND)
2-NE-WC-11	5/10/16 6:18 AM	ND	None Detected (ND)
3-NW-WC-12	5/10/16 6:21 AM	ND	None Detected (ND)
3-NW-WC-13	5/10/16 6:24 AM	ND	None Detected (ND)
4-NE-WC-14	5/10/16 6:28 AM	ND	None Detected (ND)

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level