



October 21, 2016

Dear Washington HS families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Washington HS, samples were tested from 30 sites and the water sampled from one sink and one drinking fountain on the first floor were above the action level of 15 ppb. The water from the sink and drinking fountain has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only 2 of the samples at Washington HS returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and drinking fountain and will be addressed through the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health





21 de octubre de 2016

Estimadas familias de la escuela Washington HS,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Washington HS, se tomaron muestras en 30 lugares y el agua de una pileta y un dispositivo del piso principal tenía rastros de plomo por encima del nivel de acción de 15 ppb. El suministro de agua de la pileta y el dispositivo fue interrumpido y se están creando medidas para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente dos de las muestras de Washington HS registró un nivel elevado. Este no es problema general, sino específico de la cañería de la pileta, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago





School Lead Water Testing - Data Collection Form

School Short Name **Washington H.S.**
 Date of test 10/06/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Washington H.S.	51633	51633-1-HAL-F01-001	Main- Across From Room 135, Right Fountain	9/28/16 6:00 AM	1.97	BA
Washington H.S.	51633	51633-1-HAL-F01-002	Main- Across From Room 135, Right Fountain	9/28/16 6:00 AM	1.82	BA
Washington H.S.	51633	51633-1-HAL-F01-003	Main- Across From Room 135, Right Fountain	9/28/16 6:00 AM	0.601	BA
Washington H.S.	51633	51633-1-HAL-F01-004	Main- Across From Room 135, Right Fountain	9/28/16 6:00 AM	0.715	BA
Washington H.S.	51633	51633-1-HAL-F01-005	Main- Across From Room 135, Right Fountain	9/28/16 6:00 AM	0.577	BA
Washington H.S.	51633	51633-1-HAL-F02-001	Main- Across From Room 135, Left Fountain	9/28/16 6:00 AM	1.78	BA
Washington H.S.	51633	51633-1-HAL-F02-002	Main- Across From Room 135, Left Fountain	9/28/16 6:00 AM	0.691	BA
Washington H.S.	51633	51633-1-HAL-F02-003	Main- Across From Room 135, Left Fountain	9/28/16 6:00 AM	0.657	BA
Washington H.S.	51633	51633-1-HAL-F02-004	Main- Across From Room 135, Left Fountain	9/28/16 6:00 AM	0.54	BA
Washington H.S.	51633	51633-1-HAL-F02-005	Main- Across From Room 135, Left Fountain	9/28/16 6:00 AM	0.506	BA
Washington H.S.	51633	51633-1-HAL-F03-001	Main- Across From Main Office, Right Fountain	9/28/16 6:00 AM	0.6	BA
Washington H.S.	51633	51633-1-HAL-F03-002	Main- Across From Main Office, Right Fountain	9/28/16 6:00 AM	0.774	BA
Washington H.S.	51633	51633-1-HAL-F03-003	Main- Across From Main Office, Right Fountain	9/28/16 6:00 AM	0.669	BA
Washington H.S.	51633	51633-1-HAL-F03-004	Main- Across From Main Office, Right Fountain	9/28/16 6:00 AM	0.555	BA
Washington H.S.	51633	51633-1-HAL-F03-005	Main- Across From Main Office, Right Fountain	9/28/16 6:00 AM	0.419	BA
Washington H.S.	51633	51633-1-HAL-F04-001	Main- Across From Main Office, Left Fountain	9/28/16 6:00 AM	0.314	BA
Washington H.S.	51633	51633-1-HAL-F04-002	Main- Across From Main Office, Left Fountain	9/28/16 6:00 AM	0.28	BA
Washington H.S.	51633	51633-1-HAL-F04-003	Main- Across From Main Office, Left Fountain	9/28/16 6:00 AM	0.275	BA
Washington H.S.	51633	51633-1-HAL-F04-004	Main- Across From Main Office, Left Fountain	9/28/16 6:00 AM	0.266	BA
Washington H.S.	51633	51633-1-HAL-F04-005	Main- Across From Main Office, Left Fountain	9/28/16 6:00 AM	0.269	BA
Washington H.S.	51633	51633-1-HAL-F05-001	Main- Next to Room 114, Right Fountain	9/28/16 6:00 AM	1.01	BA
Washington H.S.	51633	51633-1-HAL-F05-002	Main- Next to Room 114, Right Fountain	9/28/16 6:00 AM	0.733	BA
Washington H.S.	51633	51633-1-HAL-F05-003	Main- Next to Room 114, Right Fountain	9/28/16 6:00 AM	0.478	BA
Washington H.S.	51633	51633-1-HAL-F05-004	Main- Next to Room 114, Right Fountain	9/28/16 6:00 AM	0.447	BA
Washington H.S.	51633	51633-1-HAL-F05-005	Main- Next to Room 114, Right Fountain	9/28/16 6:00 AM	0.461	BA
Washington H.S.	51633	51633-1-HAL-F06-001	Main- Next to Room 114, Left Fountain	9/28/16 6:00 AM	0.636	BA
Washington H.S.	51633	51633-1-HAL-F06-002	Main- Next to Room 114, Left Fountain	9/28/16 6:00 AM	0.49	BA
Washington H.S.	51633	51633-1-HAL-F06-003	Main- Next to Room 114, Left Fountain	9/28/16 6:00 AM	0.482	BA
Washington H.S.	51633	51633-1-HAL-F06-004	Main- Next to Room 114, Left Fountain	9/28/16 6:00 AM	0.456	BA
Washington H.S.	51633	51633-1-HAL-F06-005	Main- Next to Room 114, Left Fountain	9/28/16 6:00 AM	0.44	BA
Washington H.S.	51633	51633-1-HAL-F07-001	Main- Next to Room 103, Right Fountain	9/28/16 6:00 AM	1.21	BA
Washington H.S.	51633	51633-1-HAL-F07-002	Main- Next to Room 103, Right Fountain	9/28/16 6:00 AM	1.58	BA
Washington H.S.	51633	51633-1-HAL-F07-003	Main- Next to Room 103, Right Fountain	9/28/16 6:00 AM	1.49	BA
Washington H.S.	51633	51633-1-HAL-F07-004	Main- Next to Room 103, Right Fountain	9/28/16 6:00 AM	1.4	BA

Washington H.S.	51633	51633-1-HAL-F07-005	Main- Next to Room 103, Right Fountain	9/28/16 6:00 AM	1.49	BA
Washington H.S.	51633	51633-1-HAL-F09-001	Main- Across From Room 127, Right Fountain	9/28/16 6:00 AM	3.18	BA
Washington H.S.	51633	51633-1-HAL-F09-002	Main- Across From Room 127, Right Fountain	9/28/16 6:00 AM	2.4	BA
Washington H.S.	51633	51633-1-HAL-F09-003	Main- Across From Room 127, Right Fountain	9/28/16 6:00 AM	2.45	BA
Washington H.S.	51633	51633-1-HAL-F09-004	Main- Across From Room 127, Right Fountain	9/28/16 6:00 AM	1.34	BA
Washington H.S.	51633	51633-1-HAL-F09-005	Main- Across From Room 127, Right Fountain	9/28/16 6:00 AM	0.658	BA
Washington H.S.	51633	51633-1-HAL-F11-001	Main- Across From Room 123, Right Fountain	9/28/16 6:00 AM	2.28	BA
Washington H.S.	51633	51633-1-HAL-F11-002	Main- Across From Room 123, Right Fountain	9/28/16 6:00 AM	1.53	BA
Washington H.S.	51633	51633-1-HAL-F11-003	Main- Across From Room 123, Right Fountain	9/28/16 6:00 AM	1.25	BA
Washington H.S.	51633	51633-1-HAL-F11-004	Main- Across From Room 123, Right Fountain	9/28/16 6:00 AM	1.32	BA
Washington H.S.	51633	51633-1-HAL-F11-005	Main- Across From Room 123, Right Fountain	9/28/16 6:00 AM	1.28	BA
Washington H.S.	51633	51633-1-HAL-F12-001	Main- Across From Room 123, Left Fountain	9/28/16 6:00 AM	2.57	BA
Washington H.S.	51633	51633-1-HAL-F12-002	Main- Across From Room 123, Left Fountain	9/28/16 6:00 AM	1.67	BA
Washington H.S.	51633	51633-1-HAL-F12-003	Main- Across From Room 123, Left Fountain	9/28/16 6:00 AM	1.35	BA
Washington H.S.	51633	51633-1-HAL-F12-004	Main- Across From Room 123, Left Fountain	9/28/16 6:00 AM	1.23	BA
Washington H.S.	51633	51633-1-HAL-F12-005	Main- Across From Room 123, Left Fountain	9/28/16 6:00 AM	1.22	BA
Washington H.S.	51633	51633-1-POOL-F13-001	Main- Pool Area, Fountain	9/28/16 6:00 AM	17.8	AA
Washington H.S.	51633	51633-1-POOL-F13-002	Main- Pool Area, Fountain	9/28/16 6:00 AM	6.7	BA
Washington H.S.	51633	51633-1-POOL-F13-003	Main- Pool Area, Fountain	9/28/16 6:00 AM	6.21	BA
Washington H.S.	51633	51633-1-POOL-F13-004	Main- Pool Area, Fountain	9/28/16 6:00 AM	7.17	BA
Washington H.S.	51633	51633-1-POOL-F13-005	Main- Pool Area, Fountain	9/28/16 6:00 AM	5.31	BA
Washington H.S.	51633	51633-1-POOL-F14-001	Main- Upper Pool Area, Fountain	9/28/16 6:00 AM	2.19	BA
Washington H.S.	51633	51633-1-POOL-F14-002	Main- Upper Pool Area, Fountain	9/28/16 6:00 AM	1.03	BA
Washington H.S.	51633	51633-1-POOL-F14-003	Main- Upper Pool Area, Fountain	9/28/16 6:00 AM	0.961	BA
Washington H.S.	51633	51633-1-POOL-F14-004	Main- Upper Pool Area, Fountain	9/28/16 6:00 AM	1.06	BA
Washington H.S.	51633	51633-1-POOL-F14-005	Main- Upper Pool Area, Fountain	9/28/16 6:00 AM	0.996	BA
Washington H.S.	51633	51633-1-GYM-F15-001	Main- Boys Gym, Fountain	9/28/16 6:00 AM	5.73	BA
Washington H.S.	51633	51633-1-GYM-F15-002	Main- Boys Gym, Fountain	9/28/16 6:00 AM	5.03	BA
Washington H.S.	51633	51633-1-GYM-F15-003	Main- Boys Gym, Fountain	9/28/16 6:00 AM	4.37	BA
Washington H.S.	51633	51633-1-GYM-F15-004	Main- Boys Gym, Fountain	9/28/16 6:00 AM	4.24	BA
Washington H.S.	51633	51633-1-GYM-F15-005	Main- Boys Gym, Fountain	9/28/16 6:00 AM	4.41	BA
Washington H.S.	51633	51633-1-HAL-F17-001	Main- Adjacent to Girls Washroom, Right Fountain	9/28/16 6:00 AM	1.15	BA
Washington H.S.	51633	51633-1-HAL-F17-002	Main- Adjacent to Girls Washroom, Right Fountain	9/28/16 6:00 AM	1.55	BA
Washington H.S.	51633	51633-1-HAL-F17-003	Main- Adjacent to Girls Washroom, Right Fountain	9/28/16 6:00 AM	1.51	BA
Washington H.S.	51633	51633-1-HAL-F17-004	Main- Adjacent to Girls Washroom, Right Fountain	9/28/16 6:00 AM	0.843	BA
Washington H.S.	51633	51633-1-HAL-F17-005	Main- Adjacent to Girls Washroom, Right Fountain	9/28/16 6:00 AM	0.373	BA
Washington H.S.	51633	51633-1-GYM-F19-001	Main- North End Girls Gym, Fountain	9/28/16 6:00 AM	4.92	BA
Washington H.S.	51633	51633-1-GYM-F19-002	Main- North End Girls Gym, Fountain	9/28/16 6:00 AM	3.42	BA
Washington H.S.	51633	51633-1-GYM-F19-003	Main- North End Girls Gym, Fountain	9/28/16 6:00 AM	2.51	BA
Washington H.S.	51633	51633-1-GYM-F19-004	Main- North End Girls Gym, Fountain	9/28/16 6:00 AM	2.33	BA
Washington H.S.	51633	51633-1-GYM-F19-005	Main- North End Girls Gym, Fountain	9/28/16 6:00 AM	2.44	BA
Washington H.S.	51633	51633-1-HAL-F20-001	Main- Across From Room 138, Fountain	9/28/16 6:00 AM	4.56	BA
Washington H.S.	51633	51633-1-HAL-F20-002	Main- Across From Room 138, Fountain	9/28/16 6:00 AM	5.2	BA
Washington H.S.	51633	51633-1-HAL-F20-003	Main- Across From Room 138, Fountain	9/28/16 6:00 AM	4.66	BA
Washington H.S.	51633	51633-1-HAL-F20-004	Main- Across From Room 138, Fountain	9/28/16 6:00 AM	5.05	BA
Washington H.S.	51633	51633-1-HAL-F20-005	Main- Across From Room 138, Fountain	9/28/16 6:00 AM	4.88	BA

Washington H.S.	51633	51633-1-KIT-KS21-001	Main- Kitchen, South Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	1.49	BA
Washington H.S.	51633	51633-1-KIT-KS21-002	Main- Kitchen, South Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	1.04	BA
Washington H.S.	51633	51633-1-KIT-KS21-003	Main- Kitchen, South Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	0.935	BA
Washington H.S.	51633	51633-1-KIT-KS21-004	Main- Kitchen, South Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	0.629	BA
Washington H.S.	51633	51633-1-KIT-KS21-005	Main- Kitchen, South Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	0.397	BA
Washington H.S.	51633	51633-1-KIT-KS22-001	Main- Kitchen, South Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	1.6	BA
Washington H.S.	51633	51633-1-KIT-KS22-002	Main- Kitchen, South Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	1.24	BA
Washington H.S.	51633	51633-1-KIT-KS22-003	Main- Kitchen, South Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	0.506	BA
Washington H.S.	51633	51633-1-KIT-KS22-004	Main- Kitchen, South Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	0.922	BA
Washington H.S.	51633	51633-1-KIT-KS22-005	Main- Kitchen, South Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	0.305	BA
Washington H.S.	51633	51633-1-KIT-KS23-001	Main- Kitchen, South Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	5.21	BA
Washington H.S.	51633	51633-1-KIT-KS23-002	Main- Kitchen, South Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	1.85	BA
Washington H.S.	51633	51633-1-KIT-KS23-003	Main- Kitchen, South Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.92	BA
Washington H.S.	51633	51633-1-KIT-KS23-004	Main- Kitchen, South Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.656	BA
Washington H.S.	51633	51633-1-KIT-KS23-005	Main- Kitchen, South Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.433	BA
Washington H.S.	51633	51633-1-KIT-KS24-001	Main- Kitchen, North Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	1.86	BA
Washington H.S.	51633	51633-1-KIT-KS24-002	Main- Kitchen, North Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	1.44	BA
Washington H.S.	51633	51633-1-KIT-KS24-003	Main- Kitchen, North Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	0.941	BA
Washington H.S.	51633	51633-1-KIT-KS24-004	Main- Kitchen, North Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	2.44	BA
Washington H.S.	51633	51633-1-KIT-KS24-005	Main- Kitchen, North Wall 3-Basin, Right Faucet	9/28/16 6:00 AM	3.69	BA
Washington H.S.	51633	51633-1-KIT-KS25-001	Main- Kitchen, North Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	1.7	BA
Washington H.S.	51633	51633-1-KIT-KS25-002	Main- Kitchen, North Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	1.03	BA
Washington H.S.	51633	51633-1-KIT-KS25-003	Main- Kitchen, North Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	0.975	BA
Washington H.S.	51633	51633-1-KIT-KS25-004	Main- Kitchen, North Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	0.94	BA
Washington H.S.	51633	51633-1-KIT-KS25-005	Main- Kitchen, North Wall 3-Basin, Center Faucet	9/28/16 6:00 AM	1.01	BA
Washington H.S.	51633	51633-1-KIT-KS26-001	Main- Kitchen, North Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	1.95	BA
Washington H.S.	51633	51633-1-KIT-KS26-002	Main- Kitchen, North Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.574	BA
Washington H.S.	51633	51633-1-KIT-KS26-003	Main- Kitchen, North Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.316	BA
Washington H.S.	51633	51633-1-KIT-KS26-004	Main- Kitchen, North Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.209	BA
Washington H.S.	51633	51633-1-KIT-KS26-005	Main- Kitchen, North Wall 3-Basin, Left Faucet	9/28/16 6:00 AM	0.176	BA
Washington H.S.	51633	51633-1-KIT-KS27-001	Main- Kitchen, Center Meat Cleaning Sink	9/28/16 6:00 AM	108	AA
Washington H.S.	51633	51633-1-KIT-KS27-002	Main- Kitchen, Center Meat Cleaning Sink	9/28/16 6:00 AM	30.4	AA
Washington H.S.	51633	51633-1-KIT-KS27-003	Main- Kitchen, Center Meat Cleaning Sink	9/28/16 6:00 AM	15.3	AA
Washington H.S.	51633	51633-1-KIT-KS27-004	Main- Kitchen, Center Meat Cleaning Sink	9/28/16 6:00 AM	8.21	BA
Washington H.S.	51633	51633-1-KIT-KS27-005	Main- Kitchen, Center Meat Cleaning Sink	9/28/16 6:00 AM	8.13	BA
Washington H.S.	51633	51633-1-KIT-KS28-001	Main- Kitchen, Center North Sink	9/28/16 6:00 AM	2.34	BA
Washington H.S.	51633	51633-1-KIT-KS28-002	Main- Kitchen, Center North Sink	9/28/16 6:00 AM	1.23	BA
Washington H.S.	51633	51633-1-KIT-KS28-003	Main- Kitchen, Center North Sink	9/28/16 6:00 AM	1.13	BA
Washington H.S.	51633	51633-1-KIT-KS28-004	Main- Kitchen, Center North Sink	9/28/16 6:00 AM	1.36	BA
Washington H.S.	51633	51633-1-KIT-KS28-005	Main- Kitchen, Center North Sink	9/28/16 6:00 AM	1.07	BA
Washington H.S.	51633	51633-1-KIT-KS29-001	Main- Kitchen, Center Sink	9/28/16 6:00 AM	1.12	BA
Washington H.S.	51633	51633-1-KIT-KS29-002	Main- Kitchen, Center Sink	9/28/16 6:00 AM	1.26	BA
Washington H.S.	51633	51633-1-KIT-KS29-003	Main- Kitchen, Center Sink	9/28/16 6:00 AM	1.39	BA
Washington H.S.	51633	51633-1-KIT-KS29-004	Main- Kitchen, Center Sink	9/28/16 6:00 AM	1.21	BA
Washington H.S.	51633	51633-1-KIT-KS29-005	Main- Kitchen, Center Sink	9/28/16 6:00 AM	0.941	BA
Washington H.S.	51633	51633-2-HAL-F01-001	Main- Across From Room 200, Left Fountain	9/28/16 6:00 AM	3.79	BA

Washington H.S.	51633	51633-2-HAL-F01-002	Main- Across From Room 200, Left Fountain	9/28/16 6:00 AM	3.16	BA
Washington H.S.	51633	51633-2-HAL-F01-003	Main- Across From Room 200, Left Fountain	9/28/16 6:00 AM	1.83	BA
Washington H.S.	51633	51633-2-HAL-F01-004	Main- Across From Room 200, Left Fountain	9/28/16 6:00 AM	1.29	BA
Washington H.S.	51633	51633-2-HAL-F01-005	Main- Across From Room 200, Left Fountain	9/28/16 6:00 AM	0.978	BA
Washington H.S.	51633	51633-2-HAL-F02-001	Main- Across From Room 200, Right Fountain	9/28/16 6:00 AM	0.839	BA
Washington H.S.	51633	51633-2-HAL-F02-002	Main- Across From Room 200, Right Fountain	9/28/16 6:00 AM	1.82	BA
Washington H.S.	51633	51633-2-HAL-F02-003	Main- Across From Room 200, Right Fountain	9/28/16 6:00 AM	2.84	BA
Washington H.S.	51633	51633-2-HAL-F02-004	Main- Across From Room 200, Right Fountain	9/28/16 6:00 AM	2.83	BA
Washington H.S.	51633	51633-2-HAL-F02-005	Main- Across From Room 200, Right Fountain	9/28/16 6:00 AM	2.21	BA
Washington H.S.	51633	51633-2-HAL-F03-001	Main- Across From Room 219, Right Fountain	9/28/16 6:00 AM	2.22	BA
Washington H.S.	51633	51633-2-HAL-F03-002	Main- Across From Room 219, Right Fountain	9/28/16 6:00 AM	1.44	BA
Washington H.S.	51633	51633-2-HAL-F03-003	Main- Across From Room 219, Right Fountain	9/28/16 6:00 AM	1.28	BA
Washington H.S.	51633	51633-2-HAL-F03-004	Main- Across From Room 219, Right Fountain	9/28/16 6:00 AM	1.23	BA
Washington H.S.	51633	51633-2-HAL-F03-005	Main- Across From Room 219, Right Fountain	9/28/16 6:00 AM	1.14	BA
Washington H.S.	51633	51633-1-MODU-F01-001	Modular- Across From Room 01, Right Fountain	9/28/16 6:00 AM	0.361	BA
Washington H.S.	51633	51633-1-MODU-F01-002	Modular- Across From Room 01, Right Fountain	9/28/16 6:00 AM	0.259	BA
Washington H.S.	51633	51633-1-MODU-F01-003	Modular- Across From Room 01, Right Fountain	9/28/16 6:00 AM	0.195	BA
Washington H.S.	51633	51633-1-MODU-F01-004	Modular- Across From Room 01, Right Fountain	9/28/16 6:00 AM	0.184	BA
Washington H.S.	51633	51633-1-MODU-F01-005	Modular- Across From Room 01, Right Fountain	9/28/16 6:00 AM	0.152	BA
Washington H.S.	51633	51633-1-MODU-F02-001	Modular- Across From Room 01, Left Fountain	9/28/16 6:00 AM	0.417	BA
Washington H.S.	51633	51633-1-MODU-F02-002	Modular- Across From Room 01, Left Fountain	9/28/16 6:00 AM	0.203	BA
Washington H.S.	51633	51633-1-MODU-F02-003	Modular- Across From Room 01, Left Fountain	9/28/16 6:00 AM	0.172	BA
Washington H.S.	51633	51633-1-MODU-F02-004	Modular- Across From Room 01, Left Fountain	9/28/16 6:00 AM	0.174	BA
Washington H.S.	51633	51633-1-MODU-F02-005	Modular- Across From Room 01, Left Fountain	9/28/16 6:00 AM	0.159	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations