



School Lead Water Testing - Data Collection Form

School Short Name **Jensen**

Sample ID #	Sample Location	Water Last Used (Time & Date)	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-SW-CS01-01	Kitchen	6/7/16 7:30 PM	6/8/16 6:17 AM	None Detected	ND
1-SW-CS01-02	Kitchen	6/7/16 7:30 PM	6/8/16 6:17 AM	None Detected	ND
1-SW-CS01-03	Kitchen	6/7/16 7:30 PM	6/8/16 6:17 AM	None Detected	ND
1-SW-CS01-04	Kitchen	6/7/16 7:30 PM	6/8/16 6:17 AM	None Detected	ND
1-SW-CS01-05	Kitchen	6/7/16 7:30 PM	6/8/16 6:17 AM	None Detected	ND
1-SW-CS02-06	Kitchen	6/7/16 7:30 PM	6/8/16 6:20 AM	None Detected	ND
1-SW-CS02-07	Kitchen	6/7/16 7:30 PM	6/8/16 6:20 AM	None Detected	ND
1-SW-CS02-08	Kitchen	6/7/16 7:30 PM	6/8/16 6:20 AM	None Detected	ND
1-SW-CS02-09	Kitchen	6/7/16 7:30 PM	6/8/16 6:20 AM	None Detected	ND
1-SW-CS02-10	Kitchen	6/7/16 7:30 PM	6/8/16 6:20 AM	None Detected	ND
1-SW-CS03-11	Kitchen	6/7/16 7:30 PM	6/8/16 6:23 AM	None Detected	ND
1-SW-CS03-12	Kitchen	6/7/16 7:30 PM	6/8/16 6:23 AM	None Detected	ND
1-SW-CS03-13	Kitchen	6/7/16 7:30 PM	6/8/16 6:23 AM	None Detected	ND
1-SW-CS03-14	Kitchen	6/7/16 7:30 PM	6/8/16 6:23 AM	None Detected	ND
1-SW-CS03-15	Kitchen	6/7/16 7:30 PM	6/8/16 6:23 AM	None Detected	ND
1-E-CS01-16	Room 105	6/7/16 7:30 PM	6/8/16 6:35 AM	None Detected	ND
1-E-CS01-17	Room 105	6/7/16 7:30 PM	6/8/16 6:35 AM	None Detected	ND
1-E-CS01-18	Room 105	6/7/16 7:30 PM	6/8/16 6:35 AM	None Detected	ND
1-E-CS01-19	Room 105	6/7/16 7:30 PM	6/8/16 6:35 AM	None Detected	ND
1-E-CS01-20	Room 105	6/7/16 7:30 PM	6/8/16 6:35 AM	None Detected	ND
1-N-CS01-21	Room 107	6/7/16 7:30 PM	6/8/16 6:42 AM	11.2	BA
1-N-CS01-22	Room 107	6/7/16 7:30 PM	6/8/16 6:42 AM	6.15	BA
1-N-CS01-23	Room 107	6/7/16 7:30 PM	6/8/16 6:42 AM	7.46	BA
1-N-CS01-24	Room 107	6/7/16 7:30 PM	6/8/16 6:42 AM	7.33	BA
1-N-CS01-25	Room 107	6/7/16 7:30 PM	6/8/16 6:42 AM	5.67	BA
1-SE-CS01-26	Room 103	6/7/16 7:30 PM	6/8/16 6:48 AM	None Detected	ND
1-SE-CS01-27	Room 103	6/7/16 7:30 PM	6/8/16 6:48 AM	None Detected	ND
1-SE-CS01-28	Room 103	6/7/16 7:30 PM	6/8/16 6:48 AM	None Detected	ND
1-SE-CS01-29	Room 103	6/7/16 7:30 PM	6/8/16 6:48 AM	None Detected	ND
1-SE-CS01-30	Room 103	6/7/16 7:30 PM	6/8/16 6:48 AM	None Detected	ND
1-SE-WC01-31	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 6:58 AM	None Detected	ND
1-SE-WC01-32	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 6:58 AM	None Detected	ND
1-SE-WC01-33	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 6:58 AM	None Detected	ND
1-SE-WC01-34	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 6:58 AM	None Detected	ND
1-SE-WC01-35	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 6:58 AM	None Detected	ND
1-SE-WC02-36	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 7:01 AM	None Detected	ND
1-SE-WC02-37	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 7:01 AM	None Detected	ND
1-SE-WC02-38	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 7:01 AM	None Detected	ND
1-SE-WC02-39	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 7:01 AM	None Detected	ND
1-SE-WC02-40	Between Boys Restroom and Room 104	6/7/16 7:30 PM	6/8/16 7:01 AM	None Detected	ND
1-NE-WC01-41	Between Girls Restroom and Room 106	6/7/16 7:30 PM	6/8/16 7:07 AM	None Detected	ND
1-NE-WC01-42	Between Girls Restroom and Room 106	6/7/16 7:30 PM	6/8/16 7:07 AM	None Detected	ND
1-NE-WC01-43	Between Girls Restroom and Room 106	6/7/16 7:30 PM	6/8/16 7:07 AM	None Detected	ND

3-SE-WC03-93	Near Science Lab 304	6/7/16 7:30 PM	6/8/16 8:19 AM	None Detected	ND
3-SE-WC03-94	Near Science Lab 304	6/7/16 7:30 PM	6/8/16 8:19 AM	Sample Not Submitted	N/A
3-SE-WC03-95	Near Science Lab 304	6/7/16 7:30 PM	6/8/16 8:19 AM	None Detected	ND
4-NE-WC02-96	Near Room 406	6/7/16 7:30 PM	6/8/16 8:25 AM	None Detected	ND
4-NE-WC02-97	Near Room 406	6/7/16 7:30 PM	6/8/16 8:25 AM	None Detected	ND
4-NE-WC02-98	Near Room 406	6/7/16 7:30 PM	6/8/16 8:25 AM	None Detected	ND
4-NE-WC02-99	Near Room 406	6/7/16 7:30 PM	6/8/16 8:25 AM	None Detected	ND
4-NE-WC02-100	Near Room 406	6/7/16 7:30 PM	6/8/16 8:25 AM	None Detected	ND
4-NE-WC03-101	Near Room 406	6/7/16 7:30 PM	6/8/16 8:28 AM	None Detected	ND
4-NE-WC03-102	Near Room 406	6/7/16 7:30 PM	6/8/16 8:28 AM	None Detected	ND
4-NE-WC03-103	Near Room 406	6/7/16 7:30 PM	6/8/16 8:28 AM	None Detected	ND
4-NE-WC03-104	Near Room 406	6/7/16 7:30 PM	6/8/16 8:28 AM	None Detected	ND
4-NE-WC03-105	Near Room 406	6/7/16 7:30 PM	6/8/16 8:28 AM	None Detected	ND
4-SE-WC01-106	Near Room 404	6/7/16 7:30 PM	6/8/16 8:34 AM	None Detected	ND
4-SE-WC01-107	Near Room 404	6/7/16 7:30 PM	6/8/16 8:34 AM	None Detected	ND
4-SE-WC01-108	Near Room 404	6/7/16 7:30 PM	6/8/16 8:34 AM	None Detected	ND
4-SE-WC01-109	Near Room 404	6/7/16 7:30 PM	6/8/16 8:34 AM	None Detected	ND
4-SE-WC01-110	Near Room 404	6/7/16 7:30 PM	6/8/16 8:34 AM	None Detected	ND
4-SE-WC02-111	Near Room 404	6/7/16 7:30 PM	6/8/16 8:37 AM	None Detected	ND
4-SE-WC02-112	Near Room 404	6/7/16 7:30 PM	6/8/16 8:37 AM	None Detected	ND
4-SE-WC02-113	Near Room 404	6/7/16 7:30 PM	6/8/16 8:37 AM	None Detected	ND
4-SE-WC02-114	Near Room 404	6/7/16 7:30 PM	6/8/16 8:37 AM	None Detected	ND
4-SE-WC02-115	Near Room 404	6/7/16 7:30 PM	6/8/16 8:37 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations