



November 7, 2016

Dear Schurz families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Schurz samples were tested from 48 sites and the water sampled from a drinking fountain on the first floor outside of Room 138 was above the action level of 15 ppb. The water from the fountain has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only one of the samples at Schurz returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that fountain and will be addressed through the remediation plan. The full results of every school's water samples can be found online at [cps.edu/leadtesting](http://cps.edu/leadtesting).

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit [www.cdc.gov/lead](http://www.cdc.gov/lead).

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool  
CEO, Chicago Public Schools

Dr. Julie Morita  
Commissioner, Chicago Department of Public Health





7 de noviembre de 2016

Estimadas familias de la escuela Schurz,

Ante recientes eventos nacionales que han aumentado la atención sobre el tema de la calidad del agua, la ciudad de Chicago anunció varias medidas de precaución adicionales que se sumarán al protocolo de la ciudad sobre control del agua, en cumplimiento de las regulaciones estatales y federales, así como de los estándares industriales

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a examinar los niveles de plomo en el agua de las escuelas de todo el distrito. Nuestra prioridad máxima es la salud y seguridad de los estudiantes y del personal, y estas pruebas se iniciaron como precaución para estar seguros de la calidad del agua de las escuelas. Las pruebas se realizan según un criterio de prioridad que incluye la edad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas de preescolares), la presencia de una cocina (donde se preparan alimentos) y de cañerías que puedan necesitar reparación o reemplazo.

Los resultados de todas las escuelas se han ido conociendo, y la mayoría registró niveles por debajo del nivel de acción de EPA que es de 15 partículas por billón (ppb). En Schurz se tomaron muestras en 48 lugares y el agua de un bebedero del primer piso, afuera del salón 138, tenía rastros de plomo por encima del nivel de acción de 15 ppb. El suministro de agua del dispositivo fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente una de las muestras de Schurz registró un nivel elevado. Este no es problema general sino específico de la cañería del dispositivo, y será solucionado. Los resultados completos de cada escuela se pueden ver en línea en [cps.edu/leadtesting](http://cps.edu/leadtesting).

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite [www.cdc.gov/lead](http://www.cdc.gov/lead).

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Atentamente,

Forrest Claypool  
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada  
Departamento de Salud Pública de Chicago





## School Lead Water Testing - Data Collection Form

School Short Name **Schurz HS**  
 Date of test 10/21/16

School Short Name	Facility ID	Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
Schurz HS	51537	51537-1-HAL-F01-001	Main- Outside Room 100, Right Fountain	10/21/16 6:00 AM	4.83	BA
Schurz HS	51537	51537-1-HAL-F01-002	Main- Outside Room 100, Right Fountain	10/21/16 6:00 AM	2.91	BA
Schurz HS	51537	51537-1-HAL-F01-003	Main- Outside Room 100, Right Fountain	10/21/16 6:00 AM	4.76	BA
Schurz HS	51537	51537-1-HAL-F01-004	Main- Outside Room 100, Right Fountain	10/21/16 6:00 AM	5.95	BA
Schurz HS	51537	51537-1-HAL-F01-005	Main- Outside Room 100, Right Fountain	10/21/16 6:00 AM	6.61	BA
Schurz HS	51537	51537-1-HAL-F02-001	Main- Outside Room 100, Left Fountain	10/21/16 6:00 AM	5.65	BA
Schurz HS	51537	51537-1-HAL-F02-002	Main- Outside Room 100, Left Fountain	10/21/16 6:00 AM	5.97	BA
Schurz HS	51537	51537-1-HAL-F02-003	Main- Outside Room 100, Left Fountain	10/21/16 6:00 AM	6.88	BA
Schurz HS	51537	51537-1-HAL-F02-004	Main- Outside Room 100, Left Fountain	10/21/16 6:00 AM	5.83	BA
Schurz HS	51537	51537-1-HAL-F02-005	Main- Outside Room 100, Left Fountain	10/21/16 6:00 AM	5.32	BA
Schurz HS	51537	51537-1-HAL-F03-001	Main- Across Stairway #05, Fountain	10/21/16 6:00 AM	0.26	BA
Schurz HS	51537	51537-1-HAL-F03-002	Main- Across Stairway #05, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F03-003	Main- Across Stairway #05, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F03-004	Main- Across Stairway #05, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F03-005	Main- Across Stairway #05, Fountain	10/21/16 6:00 AM	0.817	BA
Schurz HS	51537	51537-1-HAL-F04-001	Main- Across From Room 109, Fountain	10/21/16 6:00 AM	0.587	BA
Schurz HS	51537	51537-1-HAL-F04-002	Main- Across From Room 109, Fountain	10/21/16 6:00 AM	0.884	BA
Schurz HS	51537	51537-1-HAL-F04-003	Main- Across From Room 109, Fountain	10/21/16 6:00 AM	0.825	BA
Schurz HS	51537	51537-1-HAL-F04-004	Main- Across From Room 109, Fountain	10/21/16 6:00 AM	0.846	BA
Schurz HS	51537	51537-1-HAL-F04-005	Main- Across From Room 109, Fountain	10/21/16 6:00 AM	0.884	BA
Schurz HS	51537	51537-1-HAL-F05-001	Main- Outside Gym Room 126, Right Fountain	10/21/16 6:00 AM	0.29	BA
Schurz HS	51537	51537-1-HAL-F05-002	Main- Outside Gym Room 126, Right Fountain	10/21/16 6:00 AM	0.479	BA
Schurz HS	51537	51537-1-HAL-F05-003	Main- Outside Gym Room 126, Right Fountain	10/21/16 6:00 AM	0.218	BA
Schurz HS	51537	51537-1-HAL-F05-004	Main- Outside Gym Room 126, Right Fountain	10/21/16 6:00 AM	0.137	BA
Schurz HS	51537	51537-1-HAL-F05-005	Main- Outside Gym Room 126, Right Fountain	10/21/16 6:00 AM	0.15	BA
Schurz HS	51537	51537-1-HAL-F06-001	Main- Outside Gym Room 126, Left Fountain	10/21/16 6:00 AM	0.204	BA
Schurz HS	51537	51537-1-HAL-F06-002	Main- Outside Gym Room 126, Left Fountain	10/21/16 6:00 AM	0.161	BA
Schurz HS	51537	51537-1-HAL-F06-003	Main- Outside Gym Room 126, Left Fountain	10/21/16 6:00 AM	0.146	BA
Schurz HS	51537	51537-1-HAL-F06-004	Main- Outside Gym Room 126, Left Fountain	10/21/16 6:00 AM	0.174	BA
Schurz HS	51537	51537-1-HAL-F06-005	Main- Outside Gym Room 126, Left Fountain	10/21/16 6:00 AM	0.176	BA
Schurz HS	51537	51537-1-HAL-F07-001	Main- By Stairway 12, Left Foutnain	10/21/16 6:00 AM	0.144	BA
Schurz HS	51537	51537-1-HAL-F07-002	Main- By Stairway 12, Left Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F07-003	Main- By Stairway 12, Left Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F07-004	Main- By Stairway 12, Left Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F07-005	Main- By Stairway 12, Left Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F08-001	Main- By Stairway 12, Right Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F08-002	Main- By Stairway 12, Right Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F08-003	Main- By Stairway 12, Right Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F08-004	Main- By Stairway 12, Right Foutnain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-1-HAL-F08-005	Main- By Stairway 12, Right Foutnain	10/21/16 6:00 AM	<0.120	ND

Schurz HS	51537	51537-1-HAL-F09-001	Main- Across From Room 129, Fountain	10/21/16 6:00 AM	2.5	BA
Schurz HS	51537	51537-1-HAL-F09-002	Main- Across From Room 129, Fountain	10/21/16 6:00 AM	1.08	BA
Schurz HS	51537	51537-1-HAL-F09-003	Main- Across From Room 129, Fountain	10/21/16 6:00 AM	0.709	BA
Schurz HS	51537	51537-1-HAL-F09-004	Main- Across From Room 129, Fountain	10/21/16 6:00 AM	0.74	BA
Schurz HS	51537	51537-1-HAL-F09-005	Main- Across From Room 129, Fountain	10/21/16 6:00 AM	0.717	BA
Schurz HS	51537	51537-2-KIT-KS01-001	Main- Kitchen South Wall, Sink	10/21/16 6:00 AM	0.266	BA
Schurz HS	51537	51537-2-KIT-KS01-002	Main- Kitchen South Wall, Sink	10/21/16 6:00 AM	0.12	BA
Schurz HS	51537	51537-2-KIT-KS01-003	Main- Kitchen South Wall, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS01-004	Main- Kitchen South Wall, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS01-005	Main- Kitchen South Wall, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS02-001	Main- Kitchen, Northwest Corner, Sink	10/21/16 6:00 AM	0.225	BA
Schurz HS	51537	51537-2-KIT-KS02-002	Main- Kitchen, Northwest Corner, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS02-003	Main- Kitchen, Northwest Corner, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS02-004	Main- Kitchen, Northwest Corner, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS02-005	Main- Kitchen, Northwest Corner, Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS03-001	Main- Kitchen, Center Island Sink	10/21/16 6:00 AM	0.254	BA
Schurz HS	51537	51537-2-KIT-KS03-002	Main- Kitchen, Center Island Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS03-003	Main- Kitchen, Center Island Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS03-004	Main- Kitchen, Center Island Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-KIT-KS03-005	Main- Kitchen, Center Island Sink	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-CAF-F04-001	Main- Cafeteria, Right Fountain	10/21/16 6:00 AM	1.37	BA
Schurz HS	51537	51537-2-CAF-F04-002	Main- Cafeteria, Right Fountain	10/21/16 6:00 AM	0.801	BA
Schurz HS	51537	51537-2-CAF-F04-003	Main- Cafeteria, Right Fountain	10/21/16 6:00 AM	0.743	BA
Schurz HS	51537	51537-2-CAF-F04-004	Main- Cafeteria, Right Fountain	10/21/16 6:00 AM	0.635	BA
Schurz HS	51537	51537-2-CAF-F04-005	Main- Cafeteria, Right Fountain	10/21/16 6:00 AM	0.397	BA
Schurz HS	51537	51537-2-CAF-F05-001	Main- Cafeteria, Left Fountain	10/21/16 6:00 AM	0.655	BA
Schurz HS	51537	51537-2-CAF-F05-002	Main- Cafeteria, Left Fountain	10/21/16 6:00 AM	1.36	BA
Schurz HS	51537	51537-2-CAF-F05-003	Main- Cafeteria, Left Fountain	10/21/16 6:00 AM	0.873	BA
Schurz HS	51537	51537-2-CAF-F05-004	Main- Cafeteria, Left Fountain	10/21/16 6:00 AM	0.65	BA
Schurz HS	51537	51537-2-CAF-F05-005	Main- Cafeteria, Left Fountain	10/21/16 6:00 AM	0.939	BA
Schurz HS	51537	51537-2-HAL-F06-001	Main- Across From Room 201, Fountain	10/21/16 6:00 AM	1.79	BA
Schurz HS	51537	51537-2-HAL-F06-002	Main- Across From Room 201, Fountain	10/21/16 6:00 AM	2.78	BA
Schurz HS	51537	51537-2-HAL-F06-003	Main- Across From Room 201, Fountain	10/21/16 6:00 AM	1.94	BA
Schurz HS	51537	51537-2-HAL-F06-004	Main- Across From Room 201, Fountain	10/21/16 6:00 AM	1.53	BA
Schurz HS	51537	51537-2-HAL-F06-005	Main- Across From Room 201, Fountain	10/21/16 6:00 AM	1.35	BA
Schurz HS	51537	51537-2-HAL-F07-001	Main- Across From Room 210, Left Fountain	10/21/16 6:00 AM	0.631	BA
Schurz HS	51537	51537-2-HAL-F07-002	Main- Across From Room 210, Left Fountain	10/21/16 6:00 AM	0.48	BA
Schurz HS	51537	51537-2-HAL-F07-003	Main- Across From Room 210, Left Fountain	10/21/16 6:00 AM	0.53	BA
Schurz HS	51537	51537-2-HAL-F07-004	Main- Across From Room 210, Left Fountain	10/21/16 6:00 AM	0.36	BA
Schurz HS	51537	51537-2-HAL-F07-005	Main- Across From Room 210, Left Fountain	10/21/16 6:00 AM	0.263	BA
Schurz HS	51537	51537-2-HAL-F08-001	Main- Across From Room 210, Right Fountain	10/21/16 6:00 AM	0.257	BA
Schurz HS	51537	51537-2-HAL-F08-002	Main- Across From Room 210, Right Fountain	10/21/16 6:00 AM	0.213	BA
Schurz HS	51537	51537-2-HAL-F08-003	Main- Across From Room 210, Right Fountain	10/21/16 6:00 AM	0.236	BA
Schurz HS	51537	51537-2-HAL-F08-004	Main- Across From Room 210, Right Fountain	10/21/16 6:00 AM	0.275	BA
Schurz HS	51537	51537-2-HAL-F08-005	Main- Across From Room 210, Right Fountain	10/21/16 6:00 AM	0.433	BA
Schurz HS	51537	51537-2-HAL-F09-001	Main- Next to Room 212, Fountain	10/21/16 6:00 AM	0.873	BA
Schurz HS	51537	51537-2-HAL-F09-002	Main- Next to Room 212, Fountain	10/21/16 6:00 AM	0.688	BA
Schurz HS	51537	51537-2-HAL-F09-003	Main- Next to Room 212, Fountain	10/21/16 6:00 AM	0.513	BA
Schurz HS	51537	51537-2-HAL-F09-004	Main- Next to Room 212, Fountain	10/21/16 6:00 AM	0.436	BA
Schurz HS	51537	51537-2-HAL-F09-005	Main- Next to Room 212, Fountain	10/21/16 6:00 AM	0.417	BA
Schurz HS	51537	51537-2-HAL-F10-001	Main- Across From Room 219A, Right Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F10-002	Main- Across From Room 219A, Right Fountain	10/21/16 6:00 AM	0.513	BA
Schurz HS	51537	51537-2-HAL-F10-003	Main- Across From Room 219A, Right Fountain	10/21/16 6:00 AM	0.536	BA

[illegible]

Schurz HS	51537	51537-3-HAL-F10-002	Main- Across From Room 351, Fountain	10/21/16 6:00 AM	0.133	BA
Schurz HS	51537	51537-3-HAL-F10-003	Main- Across From Room 351, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-3-HAL-F10-004	Main- Across From Room 351, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-3-HAL-F10-005	Main- Across From Room 351, Fountain	10/21/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-3-HAL-F11-001	Main- Across From Room 334, Left Fountain	10/21/16 6:00 AM	1.02	BA
Schurz HS	51537	51537-3-HAL-F11-002	Main- Across From Room 334, Left Fountain	10/21/16 6:00 AM	1.01	BA
Schurz HS	51537	51537-3-HAL-F11-003	Main- Across From Room 334, Left Fountain	10/21/16 6:00 AM	0.714	BA
Schurz HS	51537	51537-3-HAL-F11-004	Main- Across From Room 334, Left Fountain	10/21/16 6:00 AM	0.558	BA
Schurz HS	51537	51537-3-HAL-F11-005	Main- Across From Room 334, Left Fountain	10/21/16 6:00 AM	0.923	BA
Schurz HS	51537	51537-3-HAL-F12-001	Main- Across From Room 334, Right Fountain	10/21/16 6:00 AM	0.77	BA
Schurz HS	51537	51537-3-HAL-F12-002	Main- Across From Room 334, Right Fountain	10/21/16 6:00 AM	0.558	BA
Schurz HS	51537	51537-3-HAL-F12-003	Main- Across From Room 334, Right Fountain	10/21/16 6:00 AM	0.403	BA
Schurz HS	51537	51537-3-HAL-F12-004	Main- Across From Room 334, Right Fountain	10/21/16 6:00 AM	0.502	BA
Schurz HS	51537	51537-3-HAL-F12-005	Main- Across From Room 334, Right Fountain	10/21/16 6:00 AM	0.554	BA
Schurz HS	51537	51537-4-HAL-F01-001	Main- Near Room 416, Fountain	10/21/16 6:00 AM	1.7	BA
Schurz HS	51537	51537-4-HAL-F01-002	Main- Near Room 416, Fountain	10/21/16 6:00 AM	0.994	BA
Schurz HS	51537	51537-4-HAL-F01-003	Main- Near Room 416, Fountain	10/21/16 6:00 AM	0.741	BA
Schurz HS	51537	51537-4-HAL-F01-004	Main- Near Room 416, Fountain	10/21/16 6:00 AM	0.557	BA
Schurz HS	51537	51537-4-HAL-F01-005	Main- Near Room 416, Fountain	10/21/16 6:00 AM	0.609	BA
Schurz HS	51537	51537-4-HAL-F02-001	Main- Across From Room 425, Right Fountain	10/21/16 6:00 AM	0.493	BA
Schurz HS	51537	51537-4-HAL-F02-002	Main- Across From Room 425, Right Fountain	10/21/16 6:00 AM	1.82	BA
Schurz HS	51537	51537-4-HAL-F02-003	Main- Across From Room 425, Right Fountain	10/21/16 6:00 AM	0.952	BA
Schurz HS	51537	51537-4-HAL-F02-004	Main- Across From Room 425, Right Fountain	10/21/16 6:00 AM	0.658	BA
Schurz HS	51537	51537-4-HAL-F02-005	Main- Across From Room 425, Right Fountain	10/21/16 6:00 AM	0.527	BA
Schurz HS	51537	51537-4-HAL-F03-001	Main- Across From Room 425, Left Fountain	10/21/16 6:00 AM	0.42	BA
Schurz HS	51537	51537-4-HAL-F03-002	Main- Across From Room 425, Left Fountain	10/21/16 6:00 AM	0.38	BA
Schurz HS	51537	51537-4-HAL-F03-003	Main- Across From Room 425, Left Fountain	10/21/16 6:00 AM	0.334	BA
Schurz HS	51537	51537-4-HAL-F03-004	Main- Across From Room 425, Left Fountain	10/21/16 6:00 AM	0.279	BA
Schurz HS	51537	51537-4-HAL-F03-005	Main- Across From Room 425, Left Fountain	10/21/16 6:00 AM	0.201	BA
Schurz HS	51537	51537-1-HAL-F10-001	Main- Outside Room 138 (Assembly Hall), East Wall Fountain	10/25/16 6:00 AM	1.1	BA
Schurz HS	51537	51537-1-HAL-F10-002	Main- Outside Room 138 (Assembly Hall), East Wall Fountain	10/25/16 6:00 AM	1.11	BA
Schurz HS	51537	51537-1-HAL-F10-003	Main- Outside Room 138 (Assembly Hall), East Wall Fountain	10/25/16 6:00 AM	1.13	BA
Schurz HS	51537	51537-1-HAL-F10-004	Main- Outside Room 138 (Assembly Hall), East Wall Fountain	10/25/16 6:00 AM	1.28	BA
Schurz HS	51537	51537-1-HAL-F10-005	Main- Outside Room 138 (Assembly Hall), East Wall Fountain	10/25/16 6:00 AM	1.36	BA
Schurz HS	51537	51537-1-HAL-F11-001	Main- Outside Room 138 (Assembly Hall), West Wall Fountain	10/25/16 6:00 AM	66.8	AA
Schurz HS	51537	51537-1-HAL-F11-002	Main- Outside Room 138 (Assembly Hall), West Wall Fountain	10/25/16 6:00 AM	58.8	AA
Schurz HS	51537	51537-1-HAL-F11-003	Main- Outside Room 138 (Assembly Hall), West Wall Fountain	10/25/16 6:00 AM	50.9	AA
Schurz HS	51537	51537-1-HAL-F11-004	Main- Outside Room 138 (Assembly Hall), West Wall Fountain	10/25/16 6:00 AM	19	AA
Schurz HS	51537	51537-1-HAL-F11-005	Main- Outside Room 138 (Assembly Hall), West Wall Fountain	10/25/16 6:00 AM	18.2	AA
Schurz HS	51537	51537-1-GYM-F12-001	Main- Inside Gym Room 165, Mens locker, Left Fountain	10/25/16 6:00 AM	0.942	BA
Schurz HS	51537	51537-1-GYM-F12-002	Main- Inside Gym Room 165, Mens locker, Left Fountain	10/25/16 6:00 AM	0.275	BA
Schurz HS	51537	51537-1-GYM-F12-003	Main- Inside Gym Room 165, Mens locker, Left Fountain	10/25/16 6:00 AM	0.215	BA
Schurz HS	51537	51537-1-GYM-F12-004	Main- Inside Gym Room 165, Mens locker, Left Fountain	10/25/16 6:00 AM	0.191	BA
Schurz HS	51537	51537-1-GYM-F12-005	Main- Inside Gym Room 165, Mens locker, Left Fountain	10/25/16 6:00 AM	0.185	BA
Schurz HS	51537	51537-1-GYM-F13-001	Main- Inside Gym Room 165, Mens locker, Right Fountain	10/25/16 6:00 AM	0.389	BA
Schurz HS	51537	51537-1-GYM-F13-002	Main- Inside Gym Room 165, Mens locker, Right Fountain	10/25/16 6:00 AM	0.245	BA
Schurz HS	51537	51537-1-GYM-F13-003	Main- Inside Gym Room 165, Mens locker, Right Fountain	10/25/16 6:00 AM	0.244	BA
Schurz HS	51537	51537-1-GYM-F13-004	Main- Inside Gym Room 165, Mens locker, Right Fountain	10/25/16 6:00 AM	0.264	BA
Schurz HS	51537	51537-1-GYM-F13-005	Main- Inside Gym Room 165, Mens locker, Right Fountain	10/25/16 6:00 AM	0.347	BA
Schurz HS	51537	51537-1-HAL-F14-001	Main- Across From Gym 165 North Entrance Fountain	10/25/16 6:00 AM	1.68	BA
Schurz HS	51537	51537-1-HAL-F14-002	Main- Across From Gym 165 North Entrance Fountain	10/25/16 6:00 AM	1.08	BA
Schurz HS	51537	51537-1-HAL-F14-003	Main- Across From Gym 165 North Entrance Fountain	10/25/16 6:00 AM	0.606	BA
Schurz HS	51537	51537-1-HAL-F14-004	Main- Across From Gym 165 North Entrance Fountain	10/25/16 6:00 AM	0.522	BA



Schurz HS	51537	51537-1-HAL-F14-005	Main- Across From Gym 165 North Entrance Fountain	10/25/16 6:00 AM	0.464	BA
Schurz HS	51537	51537-1-POOL-F15-001	Main- Inside Pool Area, Left Fountain	10/25/16 6:00 AM	2.85	BA
Schurz HS	51537	51537-1-POOL-F15-002	Main- Inside Pool Area, Left Fountain	10/25/16 6:00 AM	2.9	BA
Schurz HS	51537	51537-1-POOL-F15-003	Main- Inside Pool Area, Left Fountain	10/25/16 6:00 AM	3.43	BA
Schurz HS	51537	51537-1-POOL-F15-004	Main- Inside Pool Area, Left Fountain	10/25/16 6:00 AM	3.51	BA
Schurz HS	51537	51537-1-POOL-F15-005	Main- Inside Pool Area, Left Fountain	10/25/16 6:00 AM	3.56	BA
Schurz HS	51537	51537-1-POOL-F16-001	Main- Inside Pool Area, Right Fountain	10/25/16 6:00 AM	3.5	BA
Schurz HS	51537	51537-1-POOL-F16-002	Main- Inside Pool Area, Right Fountain	10/25/16 6:00 AM	3.52	BA
Schurz HS	51537	51537-1-POOL-F16-003	Main- Inside Pool Area, Right Fountain	10/25/16 6:00 AM	3.57	BA
Schurz HS	51537	51537-1-POOL-F16-004	Main- Inside Pool Area, Right Fountain	10/25/16 6:00 AM	3.52	BA
Schurz HS	51537	51537-1-POOL-F16-005	Main- Inside Pool Area, Right Fountain	10/25/16 6:00 AM	3.55	BA
Schurz HS	51537	51537-2-HAL-F15-001	Main- Across From Room 265A Gym Balcony, Right Fountain	10/25/16 6:00 AM	0.133	BA
Schurz HS	51537	51537-2-HAL-F15-002	Main- Across From Room 265A Gym Balcony, Right Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F15-003	Main- Across From Room 265A Gym Balcony, Right Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F15-004	Main- Across From Room 265A Gym Balcony, Right Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F15-005	Main- Across From Room 265A Gym Balcony, Right Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F16-001	Main- Across From Room 265A Gym Balcony, Left Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F16-002	Main- Across From Room 265A Gym Balcony, Left Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F16-003	Main- Across From Room 265A Gym Balcony, Left Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F16-004	Main- Across From Room 265A Gym Balcony, Left Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-2-HAL-F16-005	Main- Across From Room 265A Gym Balcony, Left Fountain	10/25/16 6:00 AM	<0.120	ND
Schurz HS	51537	51537-3-HAL-F01-001	Main- Next to Room 356, Right Fountain	10/25/16 6:00 AM	1.07	BA
Schurz HS	51537	51537-3-HAL-F01-002	Main- Next to Room 356, Right Fountain	10/25/16 6:00 AM	1.01	BA
Schurz HS	51537	51537-3-HAL-F01-003	Main- Next to Room 356, Right Fountain	10/25/16 6:00 AM	0.88	BA
Schurz HS	51537	51537-3-HAL-F01-004	Main- Next to Room 356, Right Fountain	10/25/16 6:00 AM	6.61	BA
Schurz HS	51537	51537-3-HAL-F01-005	Main- Next to Room 356, Right Fountain	10/25/16 6:00 AM	1.9	BA
Schurz HS	51537	51537-3-HAL-F02-001	Main- Next to Room 356, Left Fountain	10/25/16 6:00 AM	3.6	BA
Schurz HS	51537	51537-3-HAL-F02-002	Main- Next to Room 356, Left Fountain	10/25/16 6:00 AM	3.09	BA
Schurz HS	51537	51537-3-HAL-F02-003	Main- Next to Room 356, Left Fountain	10/25/16 6:00 AM	1.15	BA
Schurz HS	51537	51537-3-HAL-F02-004	Main- Next to Room 356, Left Fountain	10/25/16 6:00 AM	0.774	BA
Schurz HS	51537	51537-3-HAL-F02-005	Main- Next to Room 356, Left Fountain	10/25/16 6:00 AM	0.355	BA
Schurz HS	51537	51537-3-HAL-F03-001	Main- Next to Room 369, Fountain	10/25/16 6:00 AM	2.71	BA
Schurz HS	51537	51537-3-HAL-F03-002	Main- Next to Room 369, Fountain	10/25/16 6:00 AM	2.24	BA
Schurz HS	51537	51537-3-HAL-F03-003	Main- Next to Room 369, Fountain	10/25/16 6:00 AM	2.8	BA
Schurz HS	51537	51537-3-HAL-F03-004	Main- Next to Room 369, Fountain	10/25/16 6:00 AM	2.32	BA
Schurz HS	51537	51537-3-HAL-F03-005	Main- Next to Room 369, Fountain	10/25/16 6:00 AM	4.31	BA
Schurz HS	51537	51537-3-HAL-F13-001	Main- Across From 329, Fountain	10/25/16 6:00 AM	0.279	BA
Schurz HS	51537	51537-3-HAL-F13-002	Main- Across From 329, Fountain	10/25/16 6:00 AM	0.587	BA
Schurz HS	51537	51537-3-HAL-F13-003	Main- Across From 329, Fountain	10/25/16 6:00 AM	0.627	BA
Schurz HS	51537	51537-3-HAL-F13-004	Main- Across From 329, Fountain	10/25/16 6:00 AM	0.461	BA
Schurz HS	51537	51537-3-HAL-F13-005	Main- Across From 329, Fountain	10/25/16 6:00 AM	0.379	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations