



School Lead Water Testing - Data Collection Form

School Short Name
Facility ID

Chappell
S1052

Length of time water remained in pipes before sampled (hours)
Report based on lab results dated
Date of test
Water last used (Time and date)

13 Hours
6/9/16
05/28/16
Approx 4 PM 5/27/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51052-2-S-F01-001	2nd floor fountain by room 209/211	5/28/16 5:00 AM	1.98	BA
51052-2-S-F01-002	2nd floor fountain by room 209/211	5/28/16 5:00 AM	1.72	BA
51052-2-S-F01-003	2nd floor fountain by room 209/211	5/28/16 5:00 AM	1.21	BA
51052-2-S-F01-004	2nd floor fountain by room 209/211	5/28/16 5:00 AM	1.26	BA
51052-2-S-F01-005	2nd floor fountain by room 209/211	5/28/16 5:00 AM	1.26	BA
51052-2-E-F02-001	2nd floor (2) fountain by room 209/211	5/28/16 5:00 AM	0.617	BA
51052-2-E-F02-002	2nd floor (2) fountain by room 209/211	5/28/16 5:00 AM	0.551	BA
51052-2-E-F02-003	2nd floor (2) fountain by room 209/211	5/28/16 5:00 AM	0.25	BA
51052-2-E-F02-004	2nd floor (2) fountain by room 209/211	5/28/16 5:00 AM	0.181	BA
51052-2-E-F02-005	2nd floor (2) fountain by room 209/211	5/28/16 5:00 AM	0.191	BA
51052-2-N-F03-001	2nd floor (3) fountain by room 209/211	5/28/16 5:00 AM	0.725	BA
51052-2-N-F03-002	2nd floor (3) fountain by room 209/211	5/28/16 5:00 AM	1.14	BA
51052-2-N-F03-003	2nd floor (3) fountain by room 209/211	5/28/16 5:00 AM	0.797	BA
51052-2-N-F03-004	2nd floor (3) fountain by room 209/211	5/28/16 5:00 AM	0.583	BA
51052-2-N-F03-005	2nd floor (3) fountain by room 209/211	5/28/16 5:00 AM	0.402	BA
51052-2-NE-F04-001	2nd floor fountain Outside Upper GYM	5/28/16 5:00 AM	2.35	BA
51052-2-NE-F04-002	2nd floor fountain Outside Upper GYM	5/28/16 5:00 AM	2.44	BA
51052-2-NE-F04-003	2nd floor fountain Outside Upper GYM	5/28/16 5:00 AM	3.48	BA
51052-2-NE-F04-004	2nd floor fountain Outside Upper GYM	5/28/16 5:00 AM	3.08	BA
51052-2-NE-F04-005	2nd floor fountain Outside Upper GYM	5/28/16 5:00 AM	2.53	BA
51052-1-S-F01-001	1st floor fountain by room 111	5/28/16 5:00 AM	0.237	BA
51052-1-S-F01-002	1st floor fountain by room 111	5/28/16 5:00 AM	0.257	BA
51052-1-S-F01-003	1st floor fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-S-F01-004	1st floor fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-S-F01-005	1st floor fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-E-F02-001	1st floor (2) fountain by room 111	5/28/16 5:00 AM	0.166	BA
51052-1-E-F02-002	1st floor (2) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-E-F02-003	1st floor (2) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-E-F02-004	1st floor (2) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-E-F02-005	1st floor (2) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-N-F03-001	1st floor (3) fountain by room 111	5/28/16 5:00 AM	0.249	BA
51052-1-N-F03-002	1st floor (3) fountain by room 111	5/28/16 5:00 AM	0.141	BA
51052-1-N-F03-003	1st floor (3) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-N-F03-004	1st floor (3) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-N-F03-005	1st floor (3) fountain by room 111	5/28/16 5:00 AM	<0.120	ND
51052-1-NE-F04-001	1st floor Fountain by entry to Assembly hall	5/28/16 5:00 AM	1.17	BA
51052-1-NE-F04-002	1st floor Fountain by entry to Assembly hall	5/28/16 5:00 AM	1.24	BA
51052-1-NE-F04-003	1st floor Fountain by entry to Assembly hall	5/28/16 5:00 AM	1.23	BA
51052-1-NE-F04-004	1st floor Fountain by entry to Assembly hall	5/28/16 5:00 AM	1.34	BA
51052-1-NE-F04-005	1st floor Fountain by entry to Assembly hall	5/28/16 5:00 AM	2.09	BA
52414-2-SE-F01-001	2nd floor fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F01-002	2nd floor fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F01-003	2nd floor fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F01-004	2nd floor fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F01-005	2nd floor fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F02-001	2nd floor (2) fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F02-002	2nd floor (2) fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F02-003	2nd floor (2) fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F02-004	2nd floor (2) fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SE-F02-005	2nd floor (2) fountain by room 406	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F03-001	2nd floor fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F03-002	2nd floor fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F03-003	2nd floor fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F03-004	2nd floor fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F03-005	2nd floor fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F04-001	2nd floor (2) fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F04-002	2nd floor (2) fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F04-003	2nd floor (2) fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F04-004	2nd floor (2) fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-2-SW-F04-005	2nd floor (2) fountain by room 405	5/28/16 5:00 AM	<0.120	ND
52414-1-N-F01-001	1st floor fountain near GYM	5/28/16 5:00 AM	<0.120	ND
52414-1-N-F01-002	1st floor fountain near GYM	5/28/16 5:00 AM	<0.120	ND
52414-1-N-F01-003	1st floor fountain near GYM	5/28/16 5:00 AM	<0.120	ND
52414-1-N-F01-004	1st floor fountain near GYM	5/28/16 5:00 AM	<0.120	ND
52414-1-N-F01-005	1st floor fountain near GYM	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F02-001	1st floor fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F02-002	1st floor fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F02-003	1st floor fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F02-004	1st floor fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F02-005	1st floor fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F03-001	1st floor (2) fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F03-002	1st floor (2) fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F03-003	1st floor (2) fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F03-004	1st floor (2) fountain outside room 304	5/28/16 5:00 AM	<0.120	ND
52414-1-E-F03-005	1st floor (2) fountain outside room 304	5/28/16 5:00 AM	0.146	BA
52414-1-S-F04-001	1st floor fountain by room 306	5/28/16 5:00 AM	<0.120	ND
52414-1-S-F04-002	1st floor fountain by room 306	5/28/16 5:00 AM	<0.120	ND
52414-1-S-F04-003	1st floor fountain by room 306	5/28/16 5:00 AM	<0.120	ND
52414-1-S-F04-004	1st floor fountain by room 306	5/28/16 5:00 AM	<0.120	ND
52414-1-S-F04-005	1st floor fountain by room 306	5/28/16 5:00 AM	<0.120	ND
52414-1-WF05-001	1st floor fountain by boys toilets	5/28/16 5:00 AM	<0.120	ND
52414-1-WF05-002	1st floor fountain by boys toilets	5/28/16 5:00 AM	<0.120	ND
52414-1-WF05-003	1st floor fountain by boys toilets	5/28/16 5:00 AM	<0.120	ND
52414-1-WF05-004	1st floor fountain by boys toilets	5/28/16 5:00 AM	<0.120	ND
52414-1-WF05-005	1st floor fountain by boys toilets	5/28/16 5:00 AM	<0.120	ND
52414-1-NW-S06-001	1st floor fountain by room 303	5/28/16 5:00 AM	0.229	BA
52414-1-NW-S06-002	1st floor fountain by room 303	5/28/16 5:00 AM	0.302	BA
52414-1-NW-S06-003	1st floor fountain by room 303	5/28/16 5:00 AM	0.258	BA
52414-1-NW-S06-004	1st floor fountain by room 303	5/28/16 5:00 AM	0.197	BA
52414-1-NW-S06-005	1st floor fountain by room 303	5/28/16 5:00 AM	0.177	BA
52414-1-NE-S07-001	1st floor Sink by room 303	5/28/16 5:00 AM	0.748	BA
52414-1-NE-S07-002	1st floor Sink by room 303	5/28/16 5:00 AM	0.265	BA
52414-1-NE-S07-003	1st floor Sink by room 303	5/28/16 5:00 AM	0.163	BA
52414-1-NE-S07-004	1st floor Sink by room 303	5/28/16 5:00 AM	0.19	BA
52414-1-NE-S07-005	1st floor Sink by room 303	5/28/16 5:00 AM	0.124	BA
52414-1-SE-S08-001	1st floor sink by room 301	5/28/16 5:00 AM	0.122	BA
52414-1-SE-S08-002	1st floor sink by room 301	5/28/16 5:00 AM	0.254	BA
52414-1-SE-S08-003	1st floor sink by room 301	5/28/16 5:00 AM	0.124	BA
52414-1-SE-S08-004	1st floor sink by room 301	5/28/16 5:00 AM	0.162	BA
52414-1-SE-S08-005	1st floor sink by room 301	5/28/16 5:00 AM	0.457	BA
52414-1-SW-S09-001	1st floor (2) sink by room 301	5/28/16 5:00 AM	0.779	BA
52414-1-SW-S09-002	1st floor (2) sink by room 301	5/28/16 5:00 AM	1.52	BA
52414-1-SW-S09-003	1st floor (2) sink by room 301	5/28/16 5:00 AM	1.46	BA
52414-1-SW-S09-004	1st floor (2) sink by room 301	5/28/16 5:00 AM	1.84	BA
52414-1-SW-S09-005	1st floor (2) sink by room 301	5/28/16 5:00 AM	0.98	BA
52414-1-NE-S10-001	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	<0.120	ND
52414-1-NE-S10-002	1st floor Kitchen Sink- East wall	5/28/16 5:00 AM	0.5	BA
52414-1-NE-S10-003	1st floor Kitchen Sink- East wall	5/28/16 5:00 AM	0.525	BA
52414-1-NE-S10-004	1st floor Kitchen Sink- East wall	5/28/16 5:00 AM	2.66	BA
52414-1-NE-S10-005	1st floor Kitchen Sink- East wall	5/28/16 5:00 AM	2.53	BA
52414-1-SE-S11-001	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	0.835	BA
52414-1-SE-S11-002	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	17.6	AA
52414-1-SE-S11-003	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	1.86	BA
52414-1-SE-S11-004	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	4.02	BA
52414-1-SE-S11-005	1st floor (2) Kitchen Sink- East wall	5/28/16 5:00 AM	14.3	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level