



## School Lead Water Testing - Data Collection Form

School Short Name **Revere**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/3/16

Date of test

05/25/16

Water last used (Time and date)

Approx 4 PM 5/24/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
25121-3-N03-F-001	Outside room 302, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N03-F-002	Outside room 302, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N03-F-003	Outside room 302, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N03-F-004	Outside room 302, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N03-F-005	Outside room 302, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N04-F-001	Outside room 303, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N04-F-002	Outside room 303, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N04-F-003	Outside room 303, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N04-F-004	Outside room 303, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N04-F-005	Outside room 303, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N03-F-001	Outside room 202, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N03-F-002	Outside room 202, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N03-F-003	Outside room 202, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N03-F-004	Outside room 202, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N03-F-005	Outside room 202, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N04-F-001	Outside room 203, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N04-F-002	Outside room 203, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N04-F-003	Outside room 203, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N04-F-004	Outside room 203, Fountain	5/25/16 5:00 AM	ND	BA
25121-2-N04-F-005	Outside room 203, Fountain	5/25/16 5:00 AM	ND	BA
25121-1-N01-F-001	Fountain 1 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N01-F-002	Fountain 1 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N01-F-003	Fountain 1 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N01-F-004	Fountain 1 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N01-F-005	Fountain 1 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N02-F-001	Fountain 2 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N02-F-002	Fountain 2 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N02-F-003	Fountain 2 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N02-F-004	Fountain 2 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N02-F-005	Fountain 2 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N03-F-001	Fountain 3 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N03-F-002	Fountain 3 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N03-F-003	Fountain 3 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N03-F-004	Fountain 3 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N03-F-005	Fountain 3 across from room 101	5/25/16 5:00 AM	ND	BA
25121-1-N04-S-001	Kitchen, Sink	5/25/16 5:00 AM	ND	BA
25121-1-N04-S-002	Kitchen, Sink	5/25/16 5:00 AM	ND	BA
25121-1-N04-S-003	Kitchen, Sink	5/25/16 5:00 AM	ND	BA
25121-1-N04-S-004	Kitchen, Sink	5/25/16 5:00 AM	ND	BA
25121-1-N04-S-005	Kitchen, Sink	5/25/16 5:00 AM	ND	BA
25121-1-N05-F-001	Fountain 1 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N05-F-002	Fountain 1 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N05-F-003	Fountain 1 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N05-F-004	Fountain 1 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N05-F-005	Fountain 1 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N06-F-001	Fountain 2 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N06-F-002	Fountain 2 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N06-F-003	Fountain 2 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N06-F-004	Fountain 2 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-N06-F-005	Fountain 2 outside janitor's closet 114	5/25/16 5:00 AM	ND	BA
25121-1-E01-S-001	Kindergarten Room 106, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E01-S-002	Kindergarten Room 106, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E01-S-003	Kindergarten Room 106, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E01-S-004	Kindergarten Room 106, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E01-S-005	Kindergarten Room 106, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E02-S-001	Pre-K Rm 105B, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E02-S-002	Pre-K Rm 105B, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E02-S-003	Pre-K Rm 105B, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E02-S-004	Pre-K Rm 105B, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E02-S-005	Pre-K Rm 105B, Sink	5/25/16 5:00 AM	ND	BA
25121-1-E03-F-001	Fountain 1 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E03-F-002	Fountain 1 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E03-F-003	Fountain 1 outside electrical Rm	5/25/16 5:00 AM	ND	BA

25121-1-E03-F-004	Fountain 1 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E03-F-005	Fountain 1 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E04-F-001	Fountain 2 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E04-F-002	Fountain 2 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E04-F-003	Fountain 2 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E04-F-004	Fountain 2 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E04-F-005	Fountain 2 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E05-F-001	Fountain 3 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E05-F-002	Fountain 3 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E05-F-003	Fountain 3 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E05-F-004	Fountain 3 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-1-E05-F-005	Fountain 3 outside electrical Rm	5/25/16 5:00 AM	ND	BA
25121-B-N01-F-001	Outside B32 Lunchroom B, Fountain	5/25/16 5:00 AM	ND	BA
25121-B-N01-F-002	Outside B32 Lunchroom B, Fountain	5/25/16 5:00 AM	ND	BA
25121-B-N01-F-003	Outside B32 Lunchroom B, Fountain	5/25/16 5:00 AM	ND	BA
25121-B-N01-F-004	Outside B32 Lunchroom B, Fountain	5/25/16 5:00 AM	ND	BA
25121-B-N01-F-005	Outside B32 Lunchroom B, Fountain	5/25/16 5:00 AM	ND	BA
25121-3-N01-F-001	Fountain 1 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N01-F-002	Fountain 1 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N01-F-003	Fountain 1 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N01-F-004	Fountain 1 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N01-F-005	Fountain 1 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N02-F-001	Fountain 2 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N02-F-002	Fountain 2 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N02-F-003	Fountain 2 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N02-F-004	Fountain 2 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-3-N02-F-005	Fountain 2 outside Rm 312	5/25/16 5:00 AM	ND	BA
25121-2-N01-F-001	Fountain 1 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N01-F-002	Fountain 1 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N01-F-003	Fountain 1 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N01-F-004	Fountain 1 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N01-F-005	Fountain 1 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N02-F-001	Fountain 2 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N02-F-002	Fountain 2 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N02-F-003	Fountain 2 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N02-F-004	Fountain 2 outside Rm 212	5/25/16 5:00 AM	ND	BA
25121-2-N02-F-005	Fountain 2 outside Rm 212	5/25/16 5:00 AM	ND	BA

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations