



## School Lead Water Testing Summary

**School Short Name** **Tanner**  
**Address** 7350 S. Evans Ave  
**Facility ID** 51484  
**CPS Team Member** Craig Edgerley  
**MEC Team Member** Evan Christian

**Length of time water remained in pipes before sampled** [Approx 10-11 hours](#)  
**Water last used (Time and date)** [Approx 8 PM 5/16/16](#)  
**Date of test** 5/17/2016  
**Report based on lab results dated** 5/13/2016

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51484-1-K-CS-01	Kitchen	6:03 AM 5/6/16	ND	-
51484-1-C-WC-02	Hallway by Gym	6:05 AM 5/6/16	ND	-
51484-1-N-F-03	Hallway by Room 103	6:07 AM 5/6/16	ND	-
51484-2-N-F-04	Hallway by Room 209	6:09 AM 5/6/16	ND	-
51484-3-C-F-05	Hallway by Room 301	6:11 AM 5/6/16	19.8	AA
51484-3-S-F01-01 (Flush Draw)	Hallway by Room 302	6:06 AM 5/17/16	15.4	AA
51484-3-S-F01-02 (Flush Draw)	Hallway by Room 302	6:08 AM 5/17/16	114	AA
51484-3-N-F02-03 (1st Draw)	Hallway by Room 307	6:11 AM 5/17/16	9.96	BA
51484-3-N-F02-04 (Flush Draw)	Hallway by Room 307	6:13 AM 5/17/16	ND	-
51484-3-N-F01-05 (1st Draw)	Hallway by Room 307	6:15 AM 5/17/16	5.44	BA
51484-3-N-F01-06 (Flush Draw)	Hallway by Room 307	6:17 AM 5/17/16	ND	-
51484-2-N-F01-07 (1st Draw)	Hallway by Room 207	6:20 AM 5/17/16	15	AA
51484-2-N-F01-08 (Flush Draw)	Hallway by Room 207	6:22 AM 5/17/16	ND	-
51484-2-N-F02-09 (1st Draw)	Hallway by Room 207	6:24 AM 5/17/16	9.15	BA
51484-2-N-F02-10 (Flush Draw)	Hallway by Room 207	6:26 AM 5/17/16	ND	-
Chicago Public Schools Department of Facility Operations	Hallway by Room 104	6:31 AM 5/17/16	ND	-
51484-1-N-F01-12 (Flush Draw)	Hallway by Room 104	6:33 AM 5/17/16	ND	-
51484-1-N-F02-13 (1st Draw)	Hallway by Room 104	6:35 AM 5/17/16	ND	-
51484-1-N-F02-14 (Flush Draw)	Hallway by Room 104	6:37 AM 5/17/16	ND	-
51484-1-C-F01-15 (1st Draw)	Hallway by Boiler Room	6:40 AM 5/17/16	ND	-
51484-1-C-F01-16 (Flush Draw)	Hallway by Boiler Room	6:42 AM 5/17/16	ND	-
51484-1-C-F02-17 (1st Draw)	Hallway by Boiler Room	6:44 AM 5/17/16	ND	-
51484-1-C-F02-18 (Flush Draw)	Hallway by Boiler Room	6:46 AM 5/17/16	ND	-
51484-2-S-F01-19 (1st Draw)	Hallway by Room 202	6:50 AM 5/17/16	47.5	AA
51484-2-S-F01-20 (Flush Draw)	Hallway by Room 202	6:51 AM 5/17/16	15.8	AA
51484-1-K-F03-21 (1st Draw)	Kitchen	6:55 AM 5/17/16	ND	-
51484-1-K-F03-22 (Flush Draw)	Kitchen	6:56 AM 5/17/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations