



School Lead Water Testing - Data Collection Form

School Name **Locke J.**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24231-1-N-S01-001	Addition- Kitchen, Sink 1 - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-S01-002	Addition- Kitchen, Sink 1 - First Floor	5/26/16 5:00 AM	0.25	BA
24231-1-N-S01-003	Addition- Kitchen, Sink 1 - First Floor	5/26/16 5:00 AM	0.249	BA
24231-1-N-S01-004	Addition- Kitchen, Sink 1 - First Floor	5/26/16 5:00 AM	0.139	BA
24231-1-N-S01-005	Addition- Kitchen, Sink 1 - First Floor	5/26/16 5:00 AM	0.144	BA
24231-1-N-S02-001	Addition- Kitchen, Sink 2 -First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-S02-002	Addition- Kitchen, Sink 2 -First Floor	5/26/16 5:00 AM	0.176	BA
24231-1-N-S02-003	Addition- Kitchen, Sink 2 -First Floor	5/26/16 5:00 AM	0.142	BA
24231-1-N-S02-004	Addition- Kitchen, Sink 2 -First Floor	5/26/16 5:00 AM	0.231	BA
24231-1-N-S02-005	Addition- Kitchen, Sink 2 -First Floor	5/26/16 5:00 AM	0.174	BA
24231-1-N-S03-001	Addition- Kitchen, Sink 3 -First Floor	5/26/16 5:00 AM	2.86	BA
24231-1-N-S03-002	Addition- Kitchen, Sink 3 -First Floor	5/26/16 5:00 AM	2.26	BA
24231-1-N-S03-003	Addition- Kitchen, Sink 3 -First Floor	5/26/16 5:00 AM	2.7	BA
24231-1-N-S03-004	Addition- Kitchen, Sink 3 -First Floor	5/26/16 5:00 AM	3.7	BA
24231-1-N-S03-005	Addition- Kitchen, Sink 3 -First Floor	5/26/16 5:00 AM	2.01	BA
24231-1-N-F04-001	Addition- Inside Room 136, Fountain - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-F04-002	Addition- Inside Room 136, Fountain - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-F04-003	Addition- Inside Room 136, Fountain - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-F04-004	Addition- Inside Room 136, Fountain - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-F04-005	Addition- Inside Room 136, Fountain - First Floor	5/26/16 5:00 AM	0.12	BA
24231-1-N-S05-001	Addition- Inside Room 136, Sink - First Floor	5/26/16 5:00 AM	0.176	BA
24231-1-N-S05-002	Addition- Inside Room 136, Sink - First Floor	5/26/16 5:00 AM	0.124	BA
24231-1-N-S05-003	Addition- Inside Room 136, Sink - First Floor	5/26/16 5:00 AM	0.241	BA
24231-1-N-S05-004	Addition- Inside Room 136, Sink - First Floor	5/26/16 5:00 AM	0.38	BA
24231-1-N-S05-005	Addition- Inside Room 136, Sink - First Floor	5/26/16 5:00 AM	0.263	BA
24231-1-N-F06-001	Addition- Inside Room 138, Fountain - First Floor	5/26/16 5:00 AM	5.31	BA
24231-1-N-F06-002	Addition- Inside Room 138, Fountain - First Floor	5/26/16 5:00 AM	1.68	BA
24231-1-N-F06-003	Addition- Inside Room 138, Fountain - First Floor	5/26/16 5:00 AM	1.37	BA
24231-1-N-F06-004	Addition- Inside Room 138, Fountain - First Floor	5/26/16 5:00 AM	1.22	BA
24231-1-N-F06-005	Addition- Inside Room 138, Fountain - First Floor	5/26/16 5:00 AM	0.649	BA
24231-1-S-S08-001	Inside Room 128, Sink - First Floor	5/26/16 5:00 AM	2.64	BA
24231-1-S-S08-002	Inside Room 128, Sink - First Floor	5/26/16 5:00 AM	1.91	BA
24231-1-S-S08-003	Inside Room 128, Sink - First Floor	5/26/16 5:00 AM	2.02	BA
24231-1-S-S08-004	Inside Room 128, Sink - First Floor	5/26/16 5:00 AM	5.2	BA
24231-1-S-S08-005	Inside Room 128, Sink - First Floor	5/26/16 5:00 AM	3.37	BA
24231-2-S-F01-001	New Addition, 2nd Floor Elevator Lobby, Fountain 1	5/26/16 5:00 AM	0.12	BA
24231-2-S-F01-002	New Addition, 2nd Floor Elevator Lobby, Fountain 1	5/26/16 5:00 AM	0.12	BA
24231-2-S-F01-003	New Addition, 2nd Floor Elevator Lobby, Fountain 1	5/26/16 5:00 AM	0.12	BA
24231-2-S-F01-004	New Addition, 2nd Floor Elevator Lobby, Fountain 1	5/26/16 5:00 AM	0.12	BA
24231-2-S-F01-005	New Addition, 2nd Floor Elevator Lobby, Fountain 1	5/26/16 5:00 AM	0.12	BA
24231-2-S-F02-001	New Addition, 2nd Floor Elevator Lobby, Fountain 2	5/26/16 5:00 AM	0.12	BA
24231-2-S-F02-002	New Addition, 2nd Floor Elevator Lobby, Fountain 2	5/26/16 5:00 AM	0.21	BA
24231-2-S-F02-003	New Addition, 2nd Floor Elevator Lobby, Fountain 2	5/26/16 5:00 AM	0.255	BA
24231-2-S-F02-004	New Addition, 2nd Floor Elevator Lobby, Fountain 2	5/26/16 5:00 AM	0.269	BA
24231-2-S-F02-005	New Addition, 2nd Floor Elevator Lobby, Fountain 2	5/26/16 5:00 AM	0.274	BA
24231-1-S-S07-001	Inside Rm 128 Middle Sink - First Floor	5/26/16 5:00 AM	19.6	AA
24231-1-S-S07-002	Inside Rm 128 Middle Sink - First Floor	5/26/16 5:00 AM	3	BA
24231-1-S-S07-003	Inside Rm 128 Middle Sink - First Floor	5/26/16 5:00 AM	4.13	BA
24231-1-S-S07-004	Inside Rm 128 Middle Sink - First Floor	5/26/16 5:00 AM	3.33	BA
24231-1-S-S07-005	Inside Rm 128 Middle Sink - First Floor	5/26/16 5:00 AM	2.75	BA
51697-1-N-F01-001	Main- Outside Room 107, East Fountain 1	6/22/16 5:00 AM	1.21	BA
51697-1-N-F01-002	Main- Outside Room 107, East Fountain 1	6/22/16 5:00 AM	0.662	BA
51697-1-N-F01-003	Main- Outside Room 107, East Fountain 1	6/22/16 5:00 AM	0.583	BA
51697-1-N-F01-004	Main- Outside Room 107, East Fountain 1	6/22/16 5:00 AM	0.57	BA
51697-1-N-F01-005	Main- Outside Room 107, East Fountain 1	6/22/16 5:00 AM	0.553	BA
51697-1-N-F02-001	Main- Outside Room 107, West Fountain 2	6/22/16 5:00 AM	2.67	BA
51697-1-N-F02-002	Main- Outside Room 107, West Fountain 2	6/22/16 5:00 AM	1.24	BA
51697-1-N-F02-003	Main- Outside Room 107, West Fountain 2	6/22/16 5:00 AM	1.22	BA
51697-1-N-F02-004	Main- Outside Room 107, West Fountain 2	6/22/16 5:00 AM	0.546	BA
51697-1-N-F02-005	Main- Outside Room 107, West Fountain 2	6/22/16 5:00 AM	0.506	BA
51697-1-N-F03-001	Main- Across From Room 110, Fountain	6/22/16 5:00 AM	0.367	BA
51697-1-N-F03-002	Main- Across From Room 110, Fountain	6/22/16 5:00 AM	0.519	BA
51697-1-N-F03-003	Main- Across From Room 110, Fountain	6/22/16 5:00 AM	0.515	BA
51697-1-N-F03-004	Main- Across From Room 110, Fountain	6/22/16 5:00 AM	0.208	BA
51697-1-N-F03-005	Main- Across From Room 110, Fountain	6/22/16 5:00 AM	0.421	BA
51697-1-N-F04-001	Main- Across From Room 124, Fountain	6/22/16 5:00 AM	0.602	BA
51697-1-N-F04-002	Main- Across From Room 124, Fountain	6/22/16 5:00 AM	0.941	BA
51697-1-N-F04-003	Main- Across From Room 124, Fountain	6/22/16 5:00 AM	0.966	BA
51697-1-N-F04-004	Main- Across From Room 124, Fountain	6/22/16 5:00 AM	0.792	BA
51697-1-N-F04-005	Main- Across From Room 124, Fountain	6/22/16 5:00 AM	0.663	BA
51697-2-N-F01-001	Main- Outside Room 207, East Fountain 1	6/22/16 5:00 AM	0.69	BA
51697-2-N-F01-002	Main- Outside Room 207, East Fountain 1	6/22/16 5:00 AM	0.527	BA
51697-2-N-F01-003	Main- Outside Room 207, East Fountain 1	6/22/16 5:00 AM	0.498	BA
51697-2-N-F01-004	Main- Outside Room 207, East Fountain 1	6/22/16 5:00 AM	0.759	BA
51697-2-N-F01-005	Main- Outside Room 207, East Fountain 1	6/22/16 5:00 AM	0.522	BA
51697-2-N-F02-001	Main- Outside Room 207, West Fountain 2	6/22/16 5:00 AM	1.95	BA
51697-2-N-F02-002	Main- Outside Room 207, West Fountain 2	6/22/16 5:00 AM	0.705	BA
51697-2-N-F02-003	Main- Outside Room 207, West Fountain 2	6/22/16 5:00 AM	0.646	BA
51697-2-N-F02-004	Main- Outside Room 207, West Fountain 2	6/22/16 5:00 AM	1.19	BA
51697-2-N-F02-005	Main- Outside Room 207, West Fountain 2	6/22/16 5:00 AM	0.642	BA
51697-2-N-F03-001	Main- Across From Room 210, Fountain	6/22/16 5:00 AM	0.565	BA
51697-2-N-F03-002	Main- Across From Room 210, Fountain	6/22/16 5:00 AM	0.859	BA
51697-2-N-F03-003	Main- Across From Room 210, Fountain	6/22/16 5:00 AM	0.897	BA
51697-2-N-F03-004	Main- Across From Room 210, Fountain	6/22/16 5:00 AM	0.78	BA
51697-2-N-F03-005	Main- Across From Room 210, Fountain	6/22/16 5:00 AM	0.768	BA
51697-2-N-F04-001	Main- Across From Room 222, Fountain	6/22/16 5:00 AM	0.715	BA
51697-2-N-F04-002	Main- Across From Room 222, Fountain	6/22/16 5:00 AM	0.838	BA
51697-2-N-F04-003	Main- Across From Room 222, Fountain	6/22/16 5:00 AM	0.736	BA
51697-2-N-F04-004	Main- Across From Room 222, Fountain	6/22/16 5:00 AM	0.803	BA
51697-2-N-F04-005	Main- Across From Room 222, Fountain	6/22/16 5:00 AM	0.809	BA
51095-1-S-F02-001	Addition- Inside Room 136, Fountain	6/22/16 5:00 AM	<0.120	ND
51095-1-S-F02-002	Addition- Inside Room 136, Fountain	6/22/16 5:00 AM	<0.120	ND
51095-1-S-F02-003	Addition- Inside Room 136, Fountain	6/22/16 5:00 AM	<0.120	ND
51095-1-S-F02-004	Addition- Inside Room 136, Fountain	6/22/16 5:00 AM	<0.120	ND
51095-1-S-F02-005	Addition- Inside Room 136, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-W-F01-001	Modular 1- Inside Room 138, Fountain	6/22/16 5:00 AM	0.251	BA
57961-1-W-F01-002	Modular 1- Inside Room 138, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-W-F01-003	Modular 1- Inside Room 138, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-W-F01-004	Modular 1- Inside Room 138, Fountain	6/22/16 5:00 AM	<0.120	ND

57961-1-W-F01-005	Modular 1- Inside Room 138, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-W-S02-001	Modular 1- Inside Room 138, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-W-S02-002	Modular 1- Inside Room 138, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-W-S02-003	Modular 1- Inside Room 138, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-W-S02-004	Modular 1- Inside Room 138, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-W-S02-005	Modular 1- Inside Room 138, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-E-F03-001	Modular 1- Inside Room 139, Fountain	6/22/16 5:00 AM	0.187	BA
57961-1-E-F03-002	Modular 1- Inside Room 139, Fountain	6/22/16 5:00 AM	0.126	BA
57961-1-E-F03-003	Modular 1- Inside Room 139, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-E-F03-004	Modular 1- Inside Room 139, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-E-F03-005	Modular 1- Inside Room 139, Fountain	6/22/16 5:00 AM	<0.120	ND
57961-1-E-S04-001	Modular 1- Inside Room 139, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-E-S04-002	Modular 1- Inside Room 139, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-E-S04-003	Modular 1- Inside Room 139, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-E-S04-004	Modular 1- Inside Room 139, Sink	6/22/16 5:00 AM	<0.120	ND
57961-1-E-S04-005	Modular 1- Inside Room 139, Sink	6/22/16 5:00 AM	<0.120	ND
59716-1-W-F01-01	Modular 2- Inside Room 140, Fountain	6/22/16 5:00 AM	0.135	BA
59716-1-W-F01-02	Modular 2- Inside Room 140, Fountain	6/22/16 5:00 AM	<0.120	ND
59716-1-W-F01-03	Modular 2- Inside Room 140, Fountain	6/22/16 5:00 AM	0.125	BA
59716-1-W-F01-04	Modular 2- Inside Room 140, Fountain	6/22/16 5:00 AM	0.122	BA
59716-1-W-F01-05	Modular 2- Inside Room 140, Fountain	6/22/16 5:00 AM	<0.120	ND
59716-1-W-S02-01	Modular 2- Inside Room 140, Sink	6/22/16 5:00 AM	0.133	BA
59716-1-W-S02-02	Modular 2- Inside Room 140, Sink	6/22/16 5:00 AM	<0.120	ND
59716-1-W-S02-03	Modular 2- Inside Room 140, Sink	6/22/16 5:00 AM	<0.120	ND
59716-1-W-S02-04	Modular 2- Inside Room 140, Sink	6/22/16 5:00 AM	<0.120	ND
59716-1-W-S02-05	Modular 2- Inside Room 140, Sink	6/22/16 5:00 AM	<0.120	ND
59716-1-E-F03-01	Modular 2- Inside Room 141, Fountain	6/22/16 5:00 AM	0.211	BA
59716-1-E-F03-02	Modular 2- Inside Room 141, Fountain	6/22/16 5:00 AM	1.27	BA
59716-1-E-F03-03	Modular 2- Inside Room 141, Fountain	6/22/16 5:00 AM	1.9	BA
59716-1-E-F03-04	Modular 2- Inside Room 141, Fountain	6/22/16 5:00 AM	3.42	BA
59716-1-E-F03-05	Modular 2- Inside Room 141, Fountain	6/22/16 5:00 AM	2	BA
59716-1-E-S04-01	Modular 2- Inside Room 141, Sink	6/22/16 5:00 AM	0.147	BA
59716-1-E-S04-02	Modular 2- Inside Room 141, Sink	6/22/16 5:00 AM	0.14	BA
59716-1-E-S04-03	Modular 2- Inside Room 141, Sink	6/22/16 5:00 AM	0.138	BA
59716-1-E-S04-04	Modular 2- Inside Room 141, Sink	6/22/16 5:00 AM	0.15	BA
59716-1-E-S04-05	Modular 2- Inside Room 141, Sink	6/22/16 5:00 AM	0.318	BA
56497-1-E-F01-01	Modular 3- Inside Room 142, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F01-02	Modular 3- Inside Room 142, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F01-03	Modular 3- Inside Room 142, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F01-04	Modular 3- Inside Room 142, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F01-05	Modular 3- Inside Room 142, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-S02-01	Modular 3- Inside Room 142, Sink	6/22/16 5:00 AM	0.396	BA
56497-1-E-S02-02	Modular 3- Inside Room 142, Sink	6/22/16 5:00 AM	0.163	BA
56497-1-E-S02-03	Modular 3- Inside Room 142, Sink	6/22/16 5:00 AM	0.246	BA
56497-1-E-S02-04	Modular 3- Inside Room 142, Sink	6/22/16 5:00 AM	0.127	BA
56497-1-E-S02-05	Modular 3- Inside Room 142, Sink	6/22/16 5:00 AM	<0.120	ND
56497-1-E-S03-01	Modular 3- Inside Room 143, Sink	6/22/16 5:00 AM	1.07	BA
56497-1-E-S03-02	Modular 3- Inside Room 143, Sink	6/22/16 5:00 AM	0.286	BA
56497-1-E-S03-03	Modular 3- Inside Room 143, Sink	6/22/16 5:00 AM	0.245	BA
56497-1-E-S03-04	Modular 3- Inside Room 143, Sink	6/22/16 5:00 AM	0.196	BA
56497-1-E-S03-05	Modular 3- Inside Room 143, Sink	6/22/16 5:00 AM	0.188	BA
56497-1-E-F04-01	Modular 3- Inside Room 143, Fountain	6/22/16 5:00 AM	2.84	BA
56497-1-E-F04-02	Modular 3- Inside Room 143, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F04-03	Modular 3- Inside Room 143, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F04-04	Modular 3- Inside Room 143, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-E-F04-05	Modular 3- Inside Room 143, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F05-01	Modular 3- Corridor, West Fountain 2	6/22/16 5:00 AM	0.207	BA
56497-1-S-F05-02	Modular 3- Corridor, West Fountain 2	6/22/16 5:00 AM	0.126	BA
56497-1-S-F05-03	Modular 3- Corridor, West Fountain 2	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F05-04	Modular 3- Corridor, West Fountain 2	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F05-05	Modular 3- Corridor, West Fountain 2	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F06-01	Modular 3- Corridor, East Fountain 1	6/22/16 5:00 AM	0.167	BA
56497-1-S-F06-02	Modular 3- Corridor, East Fountain 1	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F06-03	Modular 3- Corridor, East Fountain 1	6/22/16 5:00 AM	<0.120	ND
56497-1-S-F06-04	Modular 3- Corridor, East Fountain 1	6/22/16 5:00 AM	0.141	BA
56497-1-S-F06-05	Modular 3- Corridor, East Fountain 1	6/22/16 5:00 AM	<0.120	ND
56497-1-W-S07-01	Modular 3- Inside Room 144, Sink	6/22/16 5:00 AM	0.488	BA
56497-1-W-S07-02	Modular 3- Inside Room 144, Sink	6/22/16 5:00 AM	0.161	BA
56497-1-W-S07-03	Modular 3- Inside Room 144, Sink	6/22/16 5:00 AM	0.155	BA
56497-1-W-S07-04	Modular 3- Inside Room 144, Sink	6/22/16 5:00 AM	0.19	BA
56497-1-W-S07-05	Modular 3- Inside Room 144, Sink	6/22/16 5:00 AM	0.327	BA
56497-1-W-F08-01	Modular 3- Inside Room 144, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F08-02	Modular 3- Inside Room 144, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F08-03	Modular 3- Inside Room 144, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F08-04	Modular 3- Inside Room 144, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F08-05	Modular 3- Inside Room 144, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-S09-001	Modular 3- Inside Room 145, Sink	6/22/16 5:00 AM	0.42	BA
56497-1-W-S09-002	Modular 3- Inside Room 145, Sink	6/22/16 5:00 AM	0.312	BA
56497-1-W-S09-003	Modular 3- Inside Room 145, Sink	6/22/16 5:00 AM	0.238	BA
56497-1-W-S09-004	Modular 3- Inside Room 145, Sink	6/22/16 5:00 AM	0.538	BA
56497-1-W-S09-005	Modular 3- Inside Room 145, Sink	6/22/16 5:00 AM	1.08	BA
56497-1-W-F10-001	Modular 3- Inside Room 145, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F10-002	Modular 3- Inside Room 145, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F10-003	Modular 3- Inside Room 145, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F10-004	Modular 3- Inside Room 145, Fountain	6/22/16 5:00 AM	<0.120	ND
56497-1-W-F10-005	Modular 3- Inside Room 145, Fountain	6/22/16 5:00 AM	<0.120	ND