



# School Lead Water Testing - Data Collection Form

School Short Name  
Facility ID

Durkin Park  
51314

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/10/16

Date of test

06/01/16

Water last used (Time and date)

Approx 4 PM 5/31/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51314-1-NW-F01-001	Addition-1st floor by Cafeteria Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F01-002	Addition-1st floor by Cafeteria Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F01-003	Addition-1st floor by Cafeteria Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F01-004	Addition-1st floor by Cafeteria Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F01-005	Addition-1st floor by Cafeteria Fountain 1	6/1/16 5:00 AM	1.05	BA
51314-1-NW-F02-001	Addition-1st floor by Cafeteria Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F02-002	Addition-1st floor by Cafeteria Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F02-003	Addition-1st floor by Cafeteria Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F02-004	Addition-1st floor by Cafeteria Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F02-005	Addition-1st floor by Cafeteria Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F03-001	Addition-1st floor by Cafeteria Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F03-002	Addition-1st floor by Cafeteria Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F03-003	Addition-1st floor by Cafeteria Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F03-004	Addition-1st floor by Cafeteria Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-NW-F03-005	Addition-1st floor by Cafeteria Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F04-001	Addition-1st floor by room 108, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F04-002	Addition-1st floor by room 108, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F04-003	Addition-1st floor by room 108, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F04-004	Addition-1st floor by room 108, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F04-005	Addition-1st floor by room 108, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-001	Addition-1st floor by room 108, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-002	Addition-1st floor by room 108, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-003	Addition-1st floor by room 108, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-004	Addition-1st floor by room 108, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-005	Addition-1st floor by room 108, Fountain 2	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F06-001	Addition-1st floor by room 108, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F06-002	Addition-1st floor by room 108, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F06-003	Addition-1st floor by room 108, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F06-004	Addition-1st floor by room 108, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F06-005	Addition-1st floor by room 108, Fountain 3	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S07-001	Addition-Kitchen cooking sink 1	6/1/16 5:00 AM	0.143	BA
51314-1-NE-S07-002	Addition-Kitchen cooking sink 1	6/1/16 5:00 AM	0.16	BA
51314-1-NE-S07-003	Addition-Kitchen cooking sink 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S07-004	Addition-Kitchen cooking sink 1	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S07-005	Addition-Kitchen cooking sink 1	6/1/16 5:00 AM	0.213	BA
51314-1-NE-S08-001	Addition-Kitchen cleaning sink 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S08-002	Addition-Kitchen cleaning sink 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S08-003	Addition-Kitchen cleaning sink 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S08-004	Addition-Kitchen cleaning sink 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-S08-005	Addition-Kitchen cleaning sink 2	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-F09-001	Addition-1st floor by room 130, Fountain	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-F09-002	Addition-1st floor by room 130, Fountain	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-F09-003	Addition-1st floor by room 130, Fountain	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-F09-004	Addition-1st floor by room 130, Fountain	6/1/16 5:00 AM	<0.120	ND
51314-1-NE-F09-005	Addition-1st floor by room 130, Fountain	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-S01-001	Main-1st floor Inside Room 137	6/1/16 5:00 AM	42.4	AA
51314-1-SW-S01-002	Main-1st floor Inside Room 137	6/1/16 5:00 AM	71.5	AA
51314-1-SW-S01-003	Main-1st floor Inside Room 137	6/1/16 5:00 AM	21.1	AA
51314-1-SW-S01-004	Main-1st floor Inside Room 137	6/1/16 5:00 AM	31.7	AA
51314-1-SW-S01-005	Main-1st floor Inside Room 137	6/1/16 5:00 AM	73.2	AA
51314-1-SW-S02-001	Main-1st floor Inside Room 139	6/1/16 5:00 AM	1.99	BA
51314-1-SW-S02-002	Main-1st floor Inside Room 139	6/1/16 5:00 AM	2.63	BA
51314-1-SW-S02-003	Main-1st floor Inside Room 139	6/1/16 5:00 AM	0.578	BA
51314-1-SW-S02-004	Main-1st floor Inside Room 139	6/1/16 5:00 AM	0.837	BA
51314-1-SW-S02-005	Main-1st floor Inside Room 139	6/1/16 5:00 AM	4.97	BA
51314-1-SW-F03-001	Main-1st floor Outside Main Office, Fountain 1	6/1/16 5:00 AM	1.21	BA
51314-1-SW-F03-002	Main-1st floor Outside Main Office, Fountain 1	6/1/16 5:00 AM	0.729	BA
51314-1-SW-F03-003	Main-1st floor Outside Main Office, Fountain 1	6/1/16 5:00 AM	0.579	BA
51314-1-SW-F03-004	Main-1st floor Outside Main Office, Fountain 1	6/1/16 5:00 AM	0.428	BA
51314-1-SW-F03-005	Main-1st floor Outside Main Office, Fountain 1	6/1/16 5:00 AM	0.389	BA
51314-1-SW-F04-001	Main-1st floor Outside Main Office, Fountain 2	6/1/16 5:00 AM	0.266	BA
51314-1-SW-F04-002	Main-1st floor Outside Main Office, Fountain 2	6/1/16 5:00 AM	0.265	BA
51314-1-SW-F04-003	Main-1st floor Outside Main Office, Fountain 2	6/1/16 5:00 AM	0.317	BA
51314-1-SW-F04-004	Main-1st floor Outside Main Office, Fountain 2	6/1/16 5:00 AM	0.419	BA
51314-1-SW-F04-005	Main-1st floor Outside Main Office, Fountain 2	6/1/16 5:00 AM	0.869	BA
51314-1-SW-F05-001	Main-1st floor by East Entrance, Fountain 1	6/1/16 5:00 AM	0.257	BA
51314-1-SW-F05-002	Main-1st floor by East Entrance, Fountain 1	6/1/16 5:00 AM	<0.120	ND
51314-1-SW-F05-003	Main-1st floor by East Entrance, Fountain 1	6/1/16 5:00 AM	0.274	BA
51314-1-SW-F05-004	Main-1st floor by East Entrance, Fountain 1	6/1/16 5:00 AM	0.271	BA
51314-1-SW-F05-005	Main-1st floor by East Entrance, Fountain 1	6/1/16 5:00 AM	0.373	BA
51314-1-SW-F06-001	Main-1st floor by East Entrance, Fountain 2	6/1/16 5:00 AM	0.889	BA
51314-1-SW-F06-002	Main-1st floor by East Entrance, Fountain 2	6/1/16 5:00 AM	0.27	BA
51314-1-SW-F06-003	Main-1st floor by East Entrance, Fountain 2	6/1/16 5:00 AM	0.912	BA
51314-1-SW-F06-004	Main-1st floor by East Entrance, Fountain 2	6/1/16 5:00 AM	0.936	BA
51314-1-SW-F06-005	Main-1st floor by East Entrance, Fountain 2	6/1/16 5:00 AM	0.464	BA
51314-1-SW-F07-001	Main-1st floor by East Entrance, Fountain 3	6/1/16 5:00 AM	0.23	BA
51314-1-SW-F07-002	Main-1st floor by East Entrance, Fountain 3	6/1/16 5:00 AM	1.02	BA
51314-1-SW-F07-003	Main-1st floor by East Entrance, Fountain 3	6/1/16 5:00 AM	0.216	BA
51314-1-SW-F07-004	Main-1st floor by East Entrance, Fountain 3	6/1/16 5:00 AM	0.212	BA
51314-1-SW-F07-005	Main-1st floor by East Entrance, Fountain 3	6/1/16 5:00 AM	0.268	BA
51314-1-SE-F01-001	Modular- Outside Girls Bathroom, Fountain 1	6/1/16 5:00 AM	0.21	BA
51314-1-SE-F01-002	Modular- Outside Girls Bathroom, Fountain 1	6/1/16 5:00 AM	0.179	BA
51314-1-SE-F01-003	Modular- Outside Girls Bathroom, Fountain 1	6/1/16 5:00 AM	0.163	BA
51314-1-SE-F01-004	Modular- Outside Girls Bathroom, Fountain 1	6/1/16 5:00 AM	0.51	BA
51314-1-SE-F01-005	Modular- Outside Girls Bathroom, Fountain 1	6/1/16 5:00 AM	0.202	BA
51314-1-SE-F02-001	Modular- Outside Girls Bathroom, Fountain 2	6/1/16 5:00 AM	0.578	BA
51314-1-SE-F02-002	Modular- Outside Girls Bathroom, Fountain 2	6/1/16 5:00 AM	0.157	BA
51314-1-SE-F02-003	Modular- Outside Girls Bathroom, Fountain 2	6/1/16 5:00 AM	0.207	BA
51314-1-SE-F02-004	Modular- Outside Girls Bathroom, Fountain 2	6/1/16 5:00 AM	0.19	BA
51314-1-SE-F02-005	Modular- Outside Girls Bathroom, Fountain 2	6/1/16 5:00 AM	0.178	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

## SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-below EPA Action level of 15 ppb

AA-Above EPA Action Level