



School Lead Water Testing - Data Collection Form

School Short Name **Lloyd**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/8/16

Date of test

05/26/16

Water last used (Time and date)

Approx 4 PM 5/25/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24221-3-WF01-001	Fountain next to GYM	5/26/16 5:00 AM	0.737	BA
24221-3-WF01-002	Fountain next to GYM	5/26/16 5:00 AM	0.932	BA
24221-3-WF01-003	Fountain next to GYM	5/26/16 5:00 AM	0.740	BA
24221-3-WF01-004	Fountain next to GYM	5/26/16 5:00 AM	0.707	BA
24221-3-WF01-005	Fountain next to GYM	5/26/16 5:00 AM	0.872	BA
24221-3-N-F02-001	3rd floor Fountain Next to Girls & Boys Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F02-002	3rd floor Fountain Next to Girls & Boys Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F02-003	3rd floor Fountain Next to Girls & Boys Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F02-004	3rd floor Fountain Next to Girls & Boys Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F02-005	3rd floor Fountain Next to Girls & Boys Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F03-001	3rd floor 2nd Fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F03-002	3rd floor 2nd Fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F03-003	3rd floor 2nd Fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F03-004	3rd floor 2nd Fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-3-N-F03-005	3rd floor 2nd Fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F02-001	2nd floor Fountain Next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F02-002	2nd floor Fountain Next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F02-003	2nd floor Fountain Next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F02-004	2nd floor Fountain Next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F02-005	2nd floor Fountain Next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F03-001	2nd floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F03-002	2nd floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F03-003	2nd floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F03-004	2nd floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-2-N-F03-005	2nd floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-W-F01-001	Fountain next to Assembly Hall	5/26/16 5:00 AM	0.628	BA
24221-1-W-F01-002	Fountain next to Assembly Hall	5/26/16 5:00 AM	0.228	BA
24221-1-W-F01-003	Fountain next to Assembly Hall	5/26/16 5:00 AM	0.171	BA
24221-1-W-F01-004	Fountain next to Assembly Hall	5/26/16 5:00 AM	0.156	BA
24221-1-W-F01-005	Fountain next to Assembly Hall	5/26/16 5:00 AM	0.137	BA
24221-1-C-S02-001	Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-C-S02-002	Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-C-S02-003	Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-C-S02-004	Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-W-S03-001	Second Kitchen Sink	5/26/16 5:00 AM	0.302	BA
24221-1-W-S03-002	Second Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-W-S03-003	Second Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-W-S03-004	Second Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-W-S03-005	Second Kitchen Sink	5/26/16 5:00 AM	<0.120	ND
24221-1-F-F04-001	Fountain Across the Kitchen	5/26/16 5:00 AM	0.280	BA
24221-1-F-F04-002	Fountain Across the Kitchen	5/26/16 5:00 AM	<0.120	ND
24221-1-F-F04-003	Fountain Across the Kitchen	5/26/16 5:00 AM	<0.120	ND
24221-1-F-F04-004	Fountain Across the Kitchen	5/26/16 5:00 AM	0.121	BA
24221-1-F-F04-005	Fountain Across the Kitchen	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F06-001	1st floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F06-002	1st floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F06-003	1st floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F06-004	1st floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F06-005	1st floor fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F07-001	1st floor 2nd fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F07-002	1st floor 2nd fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F07-003	1st floor 2nd fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F07-004	1st floor 2nd fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-F07-005	1st floor 2nd fountain next to Boys & Girls Toilets	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S08-001	Sink in Inside room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S08-002	Sink in Inside room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S08-003	Sink in Inside room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S08-004	Sink in Inside room 124	5/26/16 5:00 AM	0.150	BA
24221-1-N-S08-005	Sink in Inside room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S09-001	Second Sink in Room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S09-002	Second Sink in Room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S09-003	Second Sink in Room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S09-004	Second Sink in Room 124	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S10-001	Sink Inside Room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S10-002	Sink Inside Room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S10-003	Sink Inside Room 123	5/26/16 5:00 AM	0.220	BA
24221-1-N-S10-004	Sink Inside Room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S10-005	Sink Inside Room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S11-001	Second Sink in room 123	5/26/16 5:00 AM	0.200	BA
24221-1-N-S11-002	Second Sink in room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S11-003	Second Sink in room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S11-004	Second Sink in room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-N-S11-005	Second Sink in room 123	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S12-001	Sink in room 120	5/26/16 5:00 AM	0.697	BA
24221-1-S-S12-002	Sink in room 120	5/26/16 5:00 AM	0.121	BA
24221-1-S-S12-003	Sink in room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S12-004	Sink in room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S12-005	Sink in room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S13-001	Second sink inside room 120	5/26/16 5:00 AM	0.139	BA
24221-1-S-S13-002	Second sink inside room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S13-003	Second sink inside room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S13-004	Second sink inside room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S13-005	Second sink inside room 120	5/26/16 5:00 AM	<0.120	ND
24221-1-S-S14-001	Sink Inside room 121	5/26/16 5:00 AM	0.359	BA
24221-1-S-S14-002	Sink Inside room 121	5/26/16 5:00 AM	0.340	BA
24221-1-S-S14-003	Sink Inside room 121	5/26/16 5:00 AM	0.219	BA
24221-1-S-S14-004	Sink Inside room 121	5/26/16 5:00 AM	0.362	BA
24221-1-S-S14-005	Sink Inside room 121	5/26/16 5:00 AM	0.317	BA
24221-1-S-S15-001	Second Sink Inside room 121	5/26/16 5:00 AM	0.288	BA
24221-1-S-S15-002	Second Sink Inside room 121	5/26/16 5:00 AM	0.122	BA
24221-1-S-S15-003	Second Sink Inside room 121	5/26/16 5:00 AM	0.209	BA
24221-1-S-S15-004	Second Sink Inside room 121	5/26/16 5:00 AM	0.138	BA
24221-1-S-S15-005	Second Sink Inside room 121	5/26/16 5:00 AM	0.291	BA
24221-B-N-S01-001	Sink Inside Inside room 007	5/26/16 5:00 AM	0.441	BA
24221-B-N-S01-002	Sink Inside Inside room 007	5/26/16 5:00 AM	0.238	BA
24221-B-N-S01-003	Sink Inside Inside room 007	5/26/16 5:00 AM	<0.120	ND
24221-B-N-S01-004	Sink Inside Inside room 007	5/26/16 5:00 AM	<0.120	ND
24221-B-N-S01-005	Sink Inside Inside room 007	5/26/16 5:00 AM	<0.120	ND
24221-B-N-S02-001	Second Sink Inside room 007	5/26/16 5:00 AM	0.201	BA
24221-B-N-S02-002	Second Sink Inside room 007	5/26/16 5:00 AM	0.137	BA
24221-B-N-S02-003	Second Sink Inside room 007	5/26/16 5:00 AM	0.221	BA
24221-B-N-S02-004	Second Sink Inside room 007	5/26/16 5:00 AM	0.400	BA
24221-B-N-S02-005	Second Sink Inside room 007	5/26/16 5:00 AM	0.855	BA
24221-B-N-F03-001	Fountain Inside room 007	5/26/16 5:00 AM	2.24	BA
24221-B-N-F03-002	Fountain Inside room 007	5/26/16 5:00 AM	2.64	BA
24221-B-N-F03-003	Fountain Inside room 007	5/26/16 5:00 AM	3.97	BA
24221-B-N-F03-004	Fountain Inside room 007	5/26/16 5:00 AM	3.97	BA
24221-B-N-F03-005	Fountain Inside room 007	5/26/16 5:00 AM	3.60	BA
24221-B-N-S05-001	Sink Inside room 006	5/26/16 5:00 AM	1.08	BA
24221-B-N-S05-002	Sink Inside room 006	5/26/16 5:00 AM	0.438	BA
24221-B-N-S05-003	Sink Inside room 006	5/26/16 5:00 AM	0.493	BA
24221-B-N-S05-004	Sink Inside room 006	5/26/16 5:00 AM	0.567	BA
24221-B-N-S05-005	Sink Inside room 006	5/26/16 5:00 AM	1.45	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations