



School Lead Water Testing - Data Collection Form

School Short Name **Nightingale**

Length of time water remained in pipes before sampled (hours)  
Report based on lab results dated  
Date of test  
Water last used (Time and date)

13.00  
6/13/16  
05/26/16  
Approx 4 PM 5/25/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
24671-1-N-S01-001	Annex- Kitchen Sink 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-S01-002	Annex- Kitchen Sink 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-S01-003	Annex- Kitchen Sink 1	5/26/16 5:00 AM	0.126	BA
24671-1-N-S01-004	Annex- Kitchen Sink 1	5/26/16 5:00 AM	0.192	BA
24671-1-N-S01-005	Annex- Kitchen Sink 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-S02-001	Annex- Kitchen Sink 2	5/26/16 5:00 AM	0.8	BA
24671-1-N-S02-002	Annex- Kitchen Sink 2	5/26/16 5:00 AM	0.53	BA
24671-1-N-S02-003	Annex- Kitchen Sink 2	5/26/16 5:00 AM	0.579	BA
24671-1-N-S02-004	Annex- Kitchen Sink 2	5/26/16 5:00 AM	0.658	BA
24671-1-N-S02-005	Annex- Kitchen Sink 2	5/26/16 5:00 AM	0.258	BA
24671-1-N-S03-001	Annex- Kitchen Sink 3	5/26/16 5:00 AM	0.475	BA
24671-1-N-S03-002	Annex- Kitchen Sink 3	5/26/16 5:00 AM	0.121	BA
24671-1-N-S03-003	Annex- Kitchen Sink 3	5/26/16 5:00 AM	<0.120	ND
24671-1-N-S03-004	Annex- Kitchen Sink 3	5/26/16 5:00 AM	0.126	BA
24671-1-N-S03-005	Annex- Kitchen Sink 3	5/26/16 5:00 AM	0.128	BA
24671-1-N-ST04-001	Annex- Kitchen Slove Sink	5/26/16 5:00 AM	0.886	BA
24671-1-N-ST04-002	Annex- Kitchen Slove Sink	5/26/16 5:00 AM	0.669	BA
24671-1-N-ST04-003	Annex- Kitchen Slove Sink	5/26/16 5:00 AM	1.4	BA
24671-1-N-ST04-004	Annex- Kitchen Slove Sink	5/26/16 5:00 AM	2.05	BA
24671-1-N-ST04-005	Annex- Kitchen Slove Sink	5/26/16 5:00 AM	0.69	BA
24671-1-N-SK05-001	Annex- Kitchen Steam kettle 1	5/26/16 5:00 AM	0.123	BA
24671-1-N-SK05-002	Annex- Kitchen Steam kettle 1	5/26/16 5:00 AM	0.177	BA
24671-1-N-SK05-003	Annex- Kitchen Steam kettle 1	5/26/16 5:00 AM	0.305	BA
24671-1-N-SK05-004	Annex- Kitchen Steam kettle 1	5/26/16 5:00 AM	0.168	BA
24671-1-N-SK05-005	Annex- Kitchen Steam kettle 1	5/26/16 5:00 AM	0.176	BA
24671-1-N-SK06-001	Annex- Kitchen Steam kettle 2	5/26/16 5:00 AM	0.453	BA
24671-1-N-SK06-002	Annex- Kitchen Steam kettle 2	5/26/16 5:00 AM	0.193	BA
24671-1-N-SK06-003	Annex- Kitchen Steam kettle 2	5/26/16 5:00 AM	0.491	BA
24671-1-N-SK06-004	Annex- Kitchen Steam kettle 2	5/26/16 5:00 AM	0.714	BA
24671-1-N-SK06-005	Annex- Kitchen Steam kettle 2	5/26/16 5:00 AM	0.266	BA
24671-1-N-F07-001	Annex- 1st floor hallway North Fountain	5/26/16 5:00 AM	0.337	BA
24671-1-N-F07-002	Annex- 1st floor hallway North Fountain	5/26/16 5:00 AM	0.492	BA
24671-1-N-F07-003	Annex- 1st floor hallway North Fountain	5/26/16 5:00 AM	0.5	BA
24671-1-N-F07-004	Annex- 1st floor hallway North Fountain	5/26/16 5:00 AM	0.491	BA
24671-1-N-F07-005	Annex- 1st floor hallway North Fountain	5/26/16 5:00 AM	0.496	BA
24671-1-N-F08-001	Annex- 1st floor hallway South Fountain	5/26/16 5:00 AM	0.529	BA
24671-1-N-F08-002	Annex- 1st floor hallway South Fountain	5/26/16 5:00 AM	0.458	BA
24671-1-N-F08-003	Annex- 1st floor hallway South Fountain	5/26/16 5:00 AM	0.553	BA
24671-1-N-F08-004	Annex- 1st floor hallway South Fountain	5/26/16 5:00 AM	0.19	BA
24671-1-N-F08-005	Annex- 1st floor hallway South Fountain	5/26/16 5:00 AM	0.243	BA
24671-2-N-F01-001	Annex- 2nd floor hallway by fan room North Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F01-002	Annex- 2nd floor hallway by fan room North Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F01-003	Annex- 2nd floor hallway by fan room North Fountain	5/26/16 5:00 AM	0.177	BA
24671-2-N-F01-004	Annex- 2nd floor hallway by fan room North Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F01-005	Annex- 2nd floor hallway by fan room North Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F02-001	Annex- 2nd floor hallway by fan room South Fountain	5/26/16 5:00 AM	0.172	BA
24671-2-N-F02-002	Annex- 2nd floor hallway by fan room South Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F02-003	Annex- 2nd floor hallway by fan room South Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F02-004	Annex- 2nd floor hallway by fan room South Fountain	5/26/16 5:00 AM	0.28	BA
24671-2-N-F02-005	Annex- 2nd floor hallway by fan room South Fountain	5/26/16 5:00 AM	0.287	BA
24671-1-N-F01-001	Main- By room 100, North Fountain	5/26/16 5:00 AM	0.152	BA
24671-1-N-F01-002	Main- By room 100, North Fountain	5/26/16 5:00 AM	0.166	BA
24671-1-N-F01-003	Main- By room 100, North Fountain	5/26/16 5:00 AM	0.181	BA
24671-1-N-F01-004	Main- By room 100, North Fountain	5/26/16 5:00 AM	0.14	BA
24671-1-N-F01-005	Main- By room 100, North Fountain	5/26/16 5:00 AM	0.196	BA
24671-1-N-F02-001	Main- By room 100, Center Fountain	5/26/16 5:00 AM	0.246	BA
24671-1-N-F02-002	Main- By room 100, Center Fountain	5/26/16 5:00 AM	0.354	BA
24671-1-N-F02-003	Main- By room 100, Center Fountain	5/26/16 5:00 AM	0.399	BA
24671-1-N-F02-004	Main- By room 100, Center Fountain	5/26/16 5:00 AM	0.29	BA
24671-1-N-F02-005	Main- By room 100, Center Fountain	5/26/16 5:00 AM	0.265	BA
24671-1-N-F03-001	Main- By room 100, South Fountain	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F03-002	Main- By room 100, South Fountain	5/26/16 5:00 AM	0.166	BA
24671-1-N-F03-003	Main- By room 100, South Fountain	5/26/16 5:00 AM	0.175	BA
24671-1-N-F03-004	Main- By room 100, South Fountain	5/26/16 5:00 AM	0.169	BA
24671-1-N-F03-005	Main- By room 100, South Fountain	5/26/16 5:00 AM	0.173	BA
24671-1-S-F04-001	Main- By room 109, North Fountain	5/26/16 5:00 AM	0.332	BA
24671-1-S-F04-002	Main- By room 109, North Fountain	5/26/16 5:00 AM	0.28	BA
24671-1-S-F04-003	Main- By room 109, North Fountain	5/26/16 5:00 AM	0.262	BA
24671-1-S-F04-004	Main- By room 109, North Fountain	5/26/16 5:00 AM	0.246	BA
24671-1-S-F04-005	Main- By room 109, North Fountain	5/26/16 5:00 AM	0.28	BA
24671-1-S-F05-001	Main- By room 109, Center Fountain	5/26/16 5:00 AM	0.174	BA
24671-1-S-F05-002	Main- By room 109, Center Fountain	5/26/16 5:00 AM	0.183	BA
24671-1-S-F05-003	Main- By room 109, Center Fountain	5/26/16 5:00 AM	<0.120	ND
24671-1-S-F05-004	Main- By room 109, Center Fountain	5/26/16 5:00 AM	0.18	BA
24671-1-S-F05-005	Main- By room 109, Center Fountain	5/26/16 5:00 AM	0.185	BA
24671-1-S-F06-001	Main- By room 109, South Fountain	5/26/16 5:00 AM	1.93	BA
24671-1-S-F06-002	Main- By room 109, South Fountain	5/26/16 5:00 AM	0.174	BA
24671-1-S-F06-003	Main- By room 109, South Fountain	5/26/16 5:00 AM	0.164	BA
24671-1-S-F06-004	Main- By room 109, South Fountain	5/26/16 5:00 AM	0.194	BA
24671-1-S-F06-005	Main- By room 109, South Fountain	5/26/16 5:00 AM	0.17	BA
24671-1-S-F07-001	Main- By girls toilet, Fountain	5/26/16 5:00 AM	5.8	BA
24671-1-S-F07-002	Main- By girls toilet, Fountain	5/26/16 5:00 AM	9.56	BA
24671-1-S-F07-003	Main- By girls toilet, Fountain	5/26/16 5:00 AM	4.59	BA
24671-1-S-F07-004	Main- By girls toilet, Fountain	5/26/16 5:00 AM	8.88	BA
24671-1-S-F07-005	Main- By girls toilet, Fountain	5/26/16 5:00 AM	16.2	BA
24671-2-N-F01-001	Main- By room 200, North Fountain	5/26/16 5:00 AM	0.122	BA
24671-2-N-F01-002	Main- By room 200, North Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-N-F01-003	Main- By room 200, North Fountain	5/26/16 5:00 AM	0.277	BA
24671-2-N-F01-004	Main- By room 200, North Fountain	5/26/16 5:00 AM	0.231	BA
24671-2-N-F01-005	Main- By room 200, North Fountain	5/26/16 5:00 AM	0.32	BA
24671-2-N-F02-001	Main- By room 200, Center Fountain	5/26/16 5:00 AM	0.303	BA
24671-2-N-F02-002	Main- By room 200, Center Fountain	5/26/16 5:00 AM	0.445	BA
24671-2-N-F02-003	Main- By room 200, Center Fountain	5/26/16 5:00 AM	0.463	BA
24671-2-N-F02-004	Main- By room 200, Center Fountain	5/26/16 5:00 AM	0.472	BA
24671-2-N-F02-005	Main- By room 200, Center Fountain	5/26/16 5:00 AM	0.473	BA
24671-2-N-F03-001	Main- By room 200, South Fountain	5/26/16 5:00 AM	0.231	BA
24671-2-N-F03-002	Main- By room 200, South Fountain	5/26/16 5:00 AM	0.26	BA
24671-2-N-F03-003	Main- By room 200, South Fountain	5/26/16 5:00 AM	0.483	BA
24671-2-N-F03-004	Main- By room 200, South Fountain	5/26/16 5:00 AM	0.258	BA
24671-2-N-F03-005	Main- By room 200, South Fountain	5/26/16 5:00 AM	0.209	BA
24671-2-S-F04-001	Main- By room 210, North Fountain	5/26/16 5:00 AM	0.24	BA
24671-2-S-F04-002	Main- By room 210, North Fountain	5/26/16 5:00 AM	0.378	BA
24671-2-S-F04-003	Main- By room 210, North Fountain	5/26/16 5:00 AM	0.197	BA
24671-2-S-F04-004	Main- By room 210, North Fountain	5/26/16 5:00 AM	0.321	BA
24671-2-S-F04-005	Main- By room 210, North Fountain	5/26/16 5:00 AM	0.243	BA
24671-2-S-F05-001	Main- By room 210, Center Fountain	5/26/16 5:00 AM	0.144	BA
24671-2-S-F05-002	Main- By room 210, Center Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-S-F05-003	Main- By room 210, Center Fountain	5/26/16 5:00 AM	<0.120	ND
24671-2-S-F05-004	Main- By room 210, Center Fountain	5/26/16 5:00 AM	0.29	BA
24671-2-S-F05-005	Main- By room 210, Center Fountain	5/26/16 5:00 AM	0.268	BA
24671-2-S-F06-001	Main- By room 210, South Fountain	5/26/16 5:00 AM	0.198	BA
24671-2-S-F06-002	Main- By room 210, South Fountain	5/26/16 5:00 AM	0.149	BA
24671-2-S-F06-003	Main- By room 210, South Fountain	5/26/16 5:00 AM	0.225	BA
24671-2-S-F06-004	Main- By room 210, South Fountain	5/26/16 5:00 AM	0.196	BA
24671-2-S-F06-005	Main- By room 210, South Fountain	5/26/16 5:00 AM	0.211	BA
24671-1-S-S01-001	South Modular- Sink 1	5/26/16 5:00 AM	0.145	BA
24671-1-S-S01-002	South Modular- Sink 1	5/26/16 5:00 AM	<0.120	ND
24671-1-S-S01-003	South Modular- Sink 1	5/26/16 5:00 AM	0.187	BA
24671-1-S-S01-004	South Modular- Sink 1	5/26/16 5:00 AM	0.148	BA
24671-1-S-S01-005	South Modular- Sink 1	5/26/16 5:00 AM	<0.120	ND
24671-1-S-S02-001	South Modular- Sink 2	5/26/16 5:00 AM	<0.120	ND
24671-1-S-S02-002	South Modular- Sink 2	5/26/16 5:00 AM	<0.120	ND
24671-1-S-S02-003	South Modular- Sink 2	5/26/16 5:00 AM	0.55	BA
24671-1-S-S02-004	South Modular- Sink 2	5/26/16 5:00 AM	0.292	BA
24671-1-S-S02-005	South Modular- Sink 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-001	Northeast Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-002	Northeast Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-003	Northeast Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND

24671-1-N-F01-004	Northeast Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-005	Northeast Modular- Fountain 1	5/26/16 5:00 AM	0.123	BA
24671-1-N-F02-001	Northeast Modular- Fountain 2	5/26/16 5:00 AM	0.147	BA
24671-1-N-F02-002	Northeast Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F02-003	Northeast Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F02-004	Northeast Modular- Fountain 2	5/26/16 5:00 AM	0.14	BA
24671-1-N-F02-005	Northeast Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-001	Northwest Modular- Fountain 1	5/26/16 5:00 AM	0.141	BA
24671-1-N-F01-002	Northwest Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-003	Northwest Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-004	Northwest Modular- Fountain 1	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F01-005	Northwest Modular- Fountain 1	5/26/16 5:00 AM	0.132	BA
24671-1-N-F02-001	Northwest Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F02-002	Northwest Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F02-003	Northwest Modular- Fountain 2	5/26/16 5:00 AM	0.135	BA
24671-1-N-F02-004	Northwest Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F02-005	Northwest Modular- Fountain 2	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F03-001	Northwest Modular- Fountain 3	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F03-002	Northwest Modular- Fountain 3	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F03-003	Northwest Modular- Fountain 3	5/26/16 5:00 AM	<0.120	ND
24671-1-N-F03-004	Northwest Modular- Fountain 3	5/26/16 5:00 AM	0.151	BA
24671-1-N-F03-005	Northwest Modular- Fountain 3	5/26/16 5:00 AM	<0.120	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations