



School Lead Water Testing Summary

School Short Name **Neil**
Address 8555 S. Michigan Ave
Facility ID 51473
CPS Team Member Prins Sales
MEC Team Member Joe Harrington

Length of time water remained in pipes before sampled [Approx 14-15 hours](#)
Water last used (Time and date) [Approx 5:00 PM 5/5/16](#)
Date of test [5/6/2016](#)
Report based on lab results dated [5/13/2016, 5/18/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51473-1-South-CS-01	Kitchen	6:57 AM 5/6/16	ND	-
51473-1-South-F-02	Hallway by Kitchen	7:01 AM 5/6/16	ND	-
51473-1-Southwest-F-03	Hallway by Room 108	7:03 AM 5/6/16	ND	-
51473-1-East-F-04	Hallway by Room 102	7:05 AM 5/6/16	ND	-
51473-1-Northwest-F-05	Hallway by Room 100	7:07 AM 5/6/16	ND	-
51473-1-Northwest-F-06	Hallway by Room 137	7:10 AM 5/6/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations