



School Lead Water Testing - Data Collection Form

School Short Name **Harvard**
Address 7525 S. Harvard Avenue
Facility ID 51378

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/25/16
Water last used (Time and date) Approx 4 PM 5/24/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23581-B-N-S-001	Lunchroom	5/25/16 5:00 AM	0.41	BA
23581-B-N-S-002	Lunchroom	5/25/16 5:00 AM	0.376	BA
23581-B-N-S-003	Lunchroom	5/25/16 5:00 AM	0.441	BA
23581-B-N-S-004	Lunchroom	5/25/16 5:00 AM	0.381	BA
23581-B-N-S-005	Lunchroom	5/25/16 5:00 AM	0.388	BA
23581-1-E-F-001	Across from Room 101	5/25/16 5:00 AM	1.29	BA
23581-1-E-F-002	Across from Room 101	5/25/16 5:00 AM	1.37	BA
23581-1-E-F-003	Across from Room 101	5/25/16 5:00 AM	0.907	BA
23581-1-E-F-004	Across from Room 101	5/25/16 5:00 AM	0.856	BA
23581-1-E-F-005	Across from Room 101	5/25/16 5:00 AM	0.992	BA
23581-2-W-F-001	Across from Upper Balcony	5/25/16 5:00 AM	<0.120	ND
23581-2-W-F-002	Across from Upper Balcony	5/25/16 5:00 AM	<0.120	ND
23581-2-W-F-003	Across from Upper Balcony	5/25/16 5:00 AM	<0.120	ND
23581-2-W-F-004	Across from Upper Balcony	5/25/16 5:00 AM	<0.120	ND
23581-2-W-F-005	Across from Upper Balcony	5/25/16 5:00 AM	<0.120	ND
23581-2-E-F-001	Next to Room 203	5/25/16 5:00 AM	12.7	BA
23581-2-E-F-002	Next to Room 203	5/25/16 5:00 AM	2.99	BA
23581-2-E-F-003	Next to Room 203	5/25/16 5:00 AM	3.1	BA
23581-2-E-F-004	Next to Room 203	5/25/16 5:00 AM	2.76	BA
23581-2-E-F-005	Next to Room 203	5/25/16 5:00 AM	3.17	BA
23581-3-E-F-001	Next to Room 303	5/25/16 5:00 AM	17	AA
23581-3-E-F-002	Next to Room 303	5/25/16 5:00 AM	3.11	BA
23581-3-E-F-003	Next to Room 303	5/25/16 5:00 AM	1.55	BA
23581-3-E-F-004	Next to Room 303	5/25/16 5:00 AM	1.64	BA
23581-3-E-F-005	Next to Room 303	5/25/16 5:00 AM	1.57	BA
23581-2-S-F-001	Annex - Next to Room 213	5/25/16 5:00 AM	0.787	BA
23581-2-S-F-002	Annex - Next to Room 213	5/25/16 5:00 AM	0.61	BA
23581-2-S-F-003	Annex - Next to Room 213	5/25/16 5:00 AM	0.722	BA
23581-2-S-F-004	Annex - Next to Room 213	5/25/16 5:00 AM	0.965	BA
23581-2-S-F-005	Annex - Next to Room 213	5/25/16 5:00 AM	0.999	BA
23581-2-S02-F-001	Annex - Outside Girls Toilet	5/25/16 5:00 AM	0.163	BA
23581-2-S02-F-002	Annex - Outside Girls Toilet	5/25/16 5:00 AM	1.21	BA
23581-2-S02-F-003	Annex - Outside Girls Toilet	5/25/16 5:00 AM	0.414	BA
23581-2-S02-F-004	Annex - Outside Girls Toilet	5/25/16 5:00 AM	0.496	BA
23581-2-S02-F-005	Annex - Outside Girls Toilet	5/25/16 5:00 AM	0.381	BA
23581-2-E-F-001	Annex - Across from Room 203	5/25/16 5:00 AM	1.17	BA
23581-2-E-F-002	Annex - Across from Room 203	5/25/16 5:00 AM	1.32	BA
23581-2-E-F-003	Annex - Across from Room 203	5/25/16 5:00 AM	1.35	BA
23581-2-E-F-004	Annex - Across from Room 203	5/25/16 5:00 AM	1.18	BA
23581-2-E-F-005	Annex - Across from Room 203	5/25/16 5:00 AM	1	BA
23581-1-S01-F-001	Annex - Next to Room 111	5/25/16 5:00 AM	2.98	BA
23581-1-S01-F-002	Annex - Next to Room 111	5/25/16 5:00 AM	0.84	BA
23581-1-S01-F-003	Annex - Next to Room 111	5/25/16 5:00 AM	0.587	BA
23581-1-S01-F-004	Annex - Next to Room 111	5/25/16 5:00 AM	0.678	BA
23581-1-S01-F-005	Annex - Next to Room 111	5/25/16 5:00 AM	0.668	BA
23581-1-S02-001	Annex - Next to Room 108	5/25/16 5:00 AM	0.278	BA
23581-1-S02-002	Annex - Next to Room 108	5/25/16 5:00 AM	0.797	BA
23581-1-S02-003	Annex - Next to Room 108	5/25/16 5:00 AM	0.479	BA
23581-1-S02-004	Annex - Next to Room 108	5/25/16 5:00 AM	0.456	BA
23581-1-S02-005	Annex - Next to Room 108	5/25/16 5:00 AM	0.423	BA
23581-1-E-F-001	Annex - Across from Room 108	5/25/16 5:00 AM	1.6	BA
23581-1-E-F-002	Annex - Across from Room 108	5/25/16 5:00 AM	0.595	BA
23581-1-E-F-003	Annex - Across from Room 108	5/25/16 5:00 AM	0.489	BA
23581-1-E-F-004	Annex - Across from Room 108	5/25/16 5:00 AM	0.564	BA
23581-1-E-F-005	Annex - Across from Room 108	5/25/16 5:00 AM	0.719	BA
23581-1-N-S-001	Annex - Sink Inside Room 108	5/25/16 5:00 AM	1.3	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
23581-1-N-S-002	Annex - Sink Inside Room 105	5/25/16 5:00 AM	1.13	BA
23581-1-N-S-003	Annex - Sink Inside Room 105	5/25/16 5:00 AM	0.905	BA
23581-1-N-S-004	Annex - Sink Inside Room 105	5/25/16 5:00 AM	0.903	BA
23581-1-N-S-005	Annex - Sink Inside Room 105	5/25/16 5:00 AM	1.03	BA
23581-1-W-F-001	Annex - Fountain Inside Room 105	5/25/16 5:00 AM	0.606	BA
23581-1-W-F-002	Annex - Fountain Inside Room 105	5/25/16 5:00 AM	0.717	BA
23581-1-W-F-003	Annex - Fountain Inside Room 105	5/25/16 5:00 AM	0.716	BA
23581-1-W-F-004	Annex - Fountain Inside Room 105	5/25/16 5:00 AM	0.726	BA
23581-1-W-F-005	Annex - Fountain Inside Room 105	5/25/16 5:00 AM	0.726	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations