



School Lead Water Testing - Data Collection Form

School Short Name **Farmsworth**

Length of time water remained in pipes before sampled (hours)

13.00

Report based on lab results dated

6/16/16

Date of test

06/02/16

Water last used (Time and date)

Approx 4 PM 6/2/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51012-1-N-S01-001	Main- N. Kitchen Sink	6/2/16 5:00 AM	ND	ND
51012-1-N-S01-002	Main- N. Kitchen Sink	6/2/16 5:00 AM	ND	ND
51012-1-N-S01-003	Main- N. Kitchen Sink	6/2/16 5:00 AM	ND	ND
51012-1-N-S01-004	Main- N. Kitchen Sink	6/2/16 5:00 AM	ND	ND
51012-1-N-S01-005	Main- N. Kitchen Sink	6/2/16 5:00 AM	ND	ND
51012-1-W-F02-001	Main- W. Fountain 1 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F02-002	Main- W. Fountain 1 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F02-003	Main- W. Fountain 1 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F02-004	Main- W. Fountain 1 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F02-005	Main- W. Fountain 1 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F03-001	Main- W. Fountain 2 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F03-002	Main- W. Fountain 2 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F03-003	Main- W. Fountain 2 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F03-004	Main- W. Fountain 2 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-F03-005	Main- W. Fountain 2 Outside Office	6/2/16 5:00 AM	ND	ND
51012-1-W-S04-001	Main- W. Sink 1 Inside Room 103	6/2/16 5:00 AM	ND	ND
51012-1-W-S04-002	Main- W. Sink 1 Inside Room 103	6/2/16 5:00 AM	ND	ND
51012-1-W-S04-003	Main- W. Sink 1 Inside Room 103	6/2/16 5:00 AM	ND	ND
51012-1-W-S04-004	Main- W. Sink 1 Inside Room 103	6/2/16 5:00 AM	ND	ND
51012-1-E-S05-001	Main- E. Sink 2 Inside Room 106	6/2/16 5:00 AM	ND	ND
51012-1-E-S05-002	Main- E. Sink 2 Inside Room 106	6/2/16 5:00 AM	ND	ND
51012-1-E-S05-003	Main- E. Sink 2 Inside Room 106	6/2/16 5:00 AM	ND	ND
51012-1-E-S05-004	Main- E. Sink 2 Inside Room 106	6/2/16 5:00 AM	ND	ND
51012-1-W-F06-001	Main- W. Fountain 1 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F06-002	Main- W. Fountain 1 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F06-003	Main- W. Fountain 1 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F06-004	Main- W. Fountain 1 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F06-005	Main- W. Fountain 1 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F07-001	Main- W. Fountain 2 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F07-002	Main- W. Fountain 2 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F07-003	Main- W. Fountain 2 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F07-004	Main- W. Fountain 2 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-1-W-F07-005	Main- W. Fountain 2 Outside Room 112	6/2/16 5:00 AM	ND	ND
51012-3-W-F01-001	Main- W. Fountain 1 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F01-002	Main- W. Fountain 1 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F01-003	Main- W. Fountain 1 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F01-004	Main- W. Fountain 1 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F01-005	Main- W. Fountain 1 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F02-001	Main- W. Fountain 2 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F02-002	Main- W. Fountain 2 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F02-003	Main- W. Fountain 2 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F02-004	Main- W. Fountain 2 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F02-005	Main- W. Fountain 2 Outside Room 204	6/2/16 5:00 AM	ND	ND
51012-3-W-F03-001	Main- W. Fountain 1 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F03-002	Main- W. Fountain 1 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F03-003	Main- W. Fountain 1 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F03-004	Main- W. Fountain 1 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F04-001	Main- W. Fountain 2 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F04-002	Main- W. Fountain 2 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F04-003	Main- W. Fountain 2 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F04-004	Main- W. Fountain 2 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-3-W-F04-005	Main- W. Fountain 2 Outside Room 212	6/2/16 5:00 AM	ND	ND
51012-1-E-S01-001	Modular- E. Sink Inside Room 118	6/2/16 5:00 AM	ND	ND
51012-1-E-S01-002	Modular- E. Sink Inside Room 118	6/2/16 5:00 AM	ND	ND
51012-1-E-S01-003	Modular- E. Sink Inside Room 118	6/2/16 5:00 AM	ND	ND
51012-1-E-S01-004	Modular- E. Sink Inside Room 118	6/2/16 5:00 AM	ND	ND
51012-1-E-S01-005	Modular- E. Sink Inside Room 118	6/2/16 5:00 AM	ND	ND
51012-1-E-S02-001	Modular- E. Sink Inside Room 117	6/2/16 5:00 AM	ND	ND
51012-1-E-S02-002	Modular- E. Sink Inside Room 117	6/2/16 5:00 AM	ND	ND
51012-1-E-S02-003	Modular- E. Sink Inside Room 117	6/2/16 5:00 AM	ND	ND
51012-1-E-S02-004	Modular- E. Sink Inside Room 117	6/2/16 5:00 AM	ND	ND
51012-1-E-S02-005	Modular- E. Sink Inside Room 117	6/2/16 5:00 AM	ND	ND
51012-1-C-F03-001	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F03-002	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F03-003	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F03-004	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F03-005	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F04-001	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F04-002	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F04-003	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F04-004	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-C-F04-005	Modular- Corridor Next To Room 118, Fountain	6/2/16 5:00 AM	ND	ND
51012-1-W-S05-001	Modular- W. Sink Inside Room 116	6/2/16 5:00 AM	ND	ND
51012-1-W-S05-002	Modular- W. Sink Inside Room 116	6/2/16 5:00 AM	ND	ND
51012-1-W-S05-003	Modular- W. Sink Inside Room 116	6/2/16 5:00 AM	ND	ND
51012-1-W-S05-004	Modular- W. Sink Inside Room 116	6/2/16 5:00 AM	ND	ND
51012-1-W-S05-005	Modular- W. Sink Inside Room 116	6/2/16 5:00 AM	ND	ND
51012-1-W-S06-001	Modular- W. Sink Inside Room 115	6/2/16 5:00 AM	ND	ND
51012-1-W-S06-002	Modular- W. Sink Inside Room 115	6/2/16 5:00 AM	ND	ND
51012-1-W-S06-003	Modular- W. Sink Inside Room 115	6/2/16 5:00 AM	ND	ND
51012-1-W-S06-004	Modular- W. Sink Inside Room 115	6/2/16 5:00 AM	ND	ND
51012-1-W-S06-005	Modular- W. Sink Inside Room 115	6/2/16 5:00 AM	ND	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations