



School Lead Water Testing Summary

School Short Name **Nicholson**
Address 6006 S. Peoria
Facility ID 51374
CPS Team Member Craig Edgerley
MEC Team Member Mark Wyco

Length of time water remained in pipes before sampled Approx 8-9 hours
Water last used (Time and date) Approx 10 PM 5/3/16
Date of test 5/4/2016
Report based on lab results dated 5/10/2016

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
51374-1-N-CS-01	Kitchen	6:10 AM 5/4/16	ND	-
51374-1-W-WC-02	Hallway by Elevator	6:12 AM 5/4/16	ND	-
51374-1-W-S-03	Room 102	6:20 AM 5/4/16	5.13	BA
51374-1-S-WC-04	Hallway by Room 117	6:22 AM 5/4/16	ND	-

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations