



School Lead Water Testing - Data Collection Form

School Name

Lawndale

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
51209-1-E-F01-001	Main- 1st floor Outside Gym, Fountain	6/4/16 5:00 AM	1.3	BA
51209-1-E-F01-002	Main- 1st floor Outside Gym, Fountain	6/4/16 5:00 AM	0.747	BA
51209-1-E-F01-003	Main- 1st floor Outside Gym, Fountain	6/4/16 5:00 AM	0.529	BA
51209-1-E-F01-004	Main- 1st floor Outside Gym, Fountain	6/4/16 5:00 AM	0.363	BA
51209-1-E-F01-005	Main- 1st floor Outside Gym, Fountain	6/4/16 5:00 AM	0.436	BA
51209-1-W-F02-001	Main- 1st floor Outside Girls Restroom, Fountain	6/4/16 5:00 AM	2.68	BA
51209-1-W-F02-002	Main- 1st floor Outside Girls Restroom, Fountain	6/4/16 5:00 AM	2.63	BA
51209-1-W-F02-003	Main- 1st floor Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.74	BA
51209-1-W-F02-004	Main- 1st floor Outside Girls Restroom, Fountain	6/4/16 5:00 AM	2.02	BA
51209-1-W-F02-005	Main- 1st floor Outside Girls Restroom, Fountain	6/4/16 5:00 AM	3.11	BA
51209-2-E-F01-001	Main- 2nd floor Outside Room 225, Fountain	6/4/16 5:00 AM	1.96	BA
51209-2-E-F01-002	Main- 2nd floor Outside Room 225, Fountain	6/4/16 5:00 AM	1.21	BA
51209-2-E-F01-003	Main- 2nd floor Outside Room 225, Fountain	6/4/16 5:00 AM	0.73	BA
51209-2-E-F01-004	Main- 2nd floor Outside Room 225, Fountain	6/4/16 5:00 AM	0.758	BA
51209-2-E-F01-005	Main- 2nd floor Outside Room 225, Fountain	6/4/16 5:00 AM	0.705	BA
51209-2-W-F03-001	Main- 2nd floor Outside Room 223, Fountain 1	6/4/16 5:00 AM	5.13	BA
51209-2-W-F03-002	Main- 2nd floor Outside Room 223, Fountain 1	6/4/16 5:00 AM	2.06	BA
51209-2-W-F03-003	Main- 2nd floor Outside Room 223, Fountain 1	6/4/16 5:00 AM	2.99	BA
51209-2-W-F03-004	Main- 2nd floor Outside Room 223, Fountain 1	6/4/16 5:00 AM	3.76	BA
51209-2-W-F03-005	Main- 2nd floor Outside Room 223, Fountain 1	6/4/16 5:00 AM	5.17	BA
51209-2-W-F04-001	Main- 2nd floor Outside Room 223, Fountain 2	6/4/16 5:00 AM	7.96	BA
51209-2-W-F04-002	Main- 2nd floor Outside Room 223, Fountain 2	6/4/16 5:00 AM	3.12	BA
51209-2-W-F04-003	Main- 2nd floor Outside Room 223, Fountain 2	6/4/16 5:00 AM	4.23	BA
51209-2-W-F04-004	Main- 2nd floor Outside Room 223, Fountain 2	6/4/16 5:00 AM	2.1	BA
51209-2-W-F04-005	Main- 2nd floor Outside Room 223, Fountain 2	6/4/16 5:00 AM	1.44	BA
51209-3-E-F02-001	Main- 3rd floor, Outside Room 325, Fountain	6/4/16 5:00 AM	0.284	BA
51209-3-E-F02-002	Main- 3rd floor, Outside Room 325, Fountain	6/4/16 5:00 AM	1.85	BA
51209-3-E-F02-003	Main- 3rd floor, Outside Room 325, Fountain	6/4/16 5:00 AM	1.46	BA
51209-3-E-F02-004	Main- 3rd floor, Outside Room 325, Fountain	6/4/16 5:00 AM	1.36	BA
51209-3-E-F02-005	Main- 3rd floor, Outside Room 325, Fountain	6/4/16 5:00 AM	0.744	BA
51209-3-W-F04-001	Main- 3rd floor, Outside Room 323, Fountain	6/4/16 5:00 AM	0.745	BA
51209-3-W-F04-002	Main- 3rd floor, Outside Room 323, Fountain	6/4/16 5:00 AM	0.546	BA
51209-3-W-F04-003	Main- 3rd floor, Outside Room 323, Fountain	6/4/16 5:00 AM	0.334	BA
51209-3-W-F04-004	Main- 3rd floor, Outside Room 323, Fountain	6/4/16 5:00 AM	0.383	BA
51209-3-W-F04-005	Main- 3rd floor, Outside Room 323, Fountain	6/4/16 5:00 AM	0.409	BA
54718-1-E-F01-001	Annex - 1st floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.54	BA
54718-1-E-F01-002	Annex - 1st floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.58	BA
54718-1-E-F01-003	Annex - 1st floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.49	BA
54718-1-E-F01-004	Annex - 1st floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.21	BA
54718-1-E-F01-005	Annex - 1st floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.05	BA
54718-1-W-F02-001	Annex - 1st floor, Outside Boys Restroom, Fountain	6/4/16 5:00 AM	0.688	BA
54718-1-W-F02-002	Annex - 1st floor, Outside Boys Restroom, Fountain	6/4/16 5:00 AM	0.839	BA
54718-1-W-F02-003	Annex - 1st floor, Outside Boys Restroom, Fountain	6/4/16 5:00 AM	0.804	BA
54718-1-W-F02-004	Annex - 1st floor, Outside Boys Restroom, Fountain	6/4/16 5:00 AM	0.718	BA
54718-1-W-F02-005	Annex - 1st floor, Outside Boys Restroom, Fountain	6/4/16 5:00 AM	0.646	BA
54718-1-W-S03-001	Annex - 1st floor, Inside Room 112, Sink	6/4/16 5:00 AM	0.84	BA
54718-1-W-S03-002	Annex - 1st floor, Inside Room 112, Sink	6/4/16 5:00 AM	1.15	BA
54718-1-W-S03-003	Annex - 1st floor, Inside Room 112, Sink	6/4/16 5:00 AM	0.763	BA
54718-1-W-S03-004	Annex - 1st floor, Inside Room 112, Sink	6/4/16 5:00 AM	0.928	BA
54718-1-W-S03-005	Annex - 1st floor, Inside Room 112, Sink	6/4/16 5:00 AM	0.919	BA
54718-1-C-S04-001	Annex - 1st floor, Inside Room 117, Sink	6/4/16 5:00 AM	0.964	BA
54718-1-C-S04-002	Annex - 1st floor, Inside Room 117, Sink	6/4/16 5:00 AM	0.544	BA
54718-1-C-S04-003	Annex - 1st floor, Inside Room 117, Sink	6/4/16 5:00 AM	0.621	BA
54718-1-C-S04-004	Annex - 1st floor, Inside Room 117, Sink	6/4/16 5:00 AM	0.596	BA
54718-1-C-S04-005	Annex - 1st floor, Inside Room 117, Sink	6/4/16 5:00 AM	0.981	BA
54718-1-C-F05-001	Annex - 1st floor, Inside Room 117, Fountain	6/4/16 5:00 AM	0.584	BA
54718-1-C-F05-002	Annex - 1st floor, Inside Room 117, Fountain	6/4/16 5:00 AM	0.58	BA
54718-1-C-F05-003	Annex - 1st floor, Inside Room 117, Fountain	6/4/16 5:00 AM	0.57	BA
54718-1-C-F05-004	Annex - 1st floor, Inside Room 117, Fountain	6/4/16 5:00 AM	0.549	BA
54718-1-C-F05-005	Annex - 1st floor, Inside Room 117, Fountain	6/4/16 5:00 AM	0.546	BA
54718-1-W-S07-001	Annex - 1st floor, Kitchen, Sink	6/4/16 5:00 AM	1.81	BA
54718-1-W-S07-002	Annex - 1st floor, Kitchen, Sink	6/4/16 5:00 AM	1.16	BA
54718-1-W-S07-003	Annex - 1st floor, Kitchen, Sink	6/4/16 5:00 AM	1.14	BA
54718-1-W-S07-004	Annex - 1st floor, Kitchen, Sink	6/4/16 5:00 AM	1.11	BA
54718-1-W-S07-005	Annex - 1st floor, Kitchen, Sink	6/4/16 5:00 AM	0.977	BA
54718-2-E-F01-001	Annex - 2nd floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.01	BA
54718-2-E-F01-002	Annex - 2nd floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.25	BA
54718-2-E-F01-003	Annex - 2nd floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	1.13	BA
54718-2-E-F01-004	Annex - 2nd floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	0.886	BA
54718-2-E-F01-005	Annex - 2nd floor, Outside Girls Restroom, Fountain	6/4/16 5:00 AM	0.685	BA
51209-1-E-F01-001	Main- 1st floor, Inside Gym, Fountain	6/22/16 5:00 AM	0.944	BA
51209-1-E-F01-002	Main- 1st floor, Inside Gym, Fountain	6/22/16 5:00 AM	0.568	BA
51209-1-E-F01-003	Main- 1st floor, Inside Gym, Fountain	6/22/16 5:00 AM	0.657	BA
51209-1-E-F01-004	Main- 1st floor, Inside Gym, Fountain	6/22/16 5:00 AM	0.561	BA
51209-1-E-F01-005	Main- 1st floor, Inside Gym, Fountain	6/22/16 5:00 AM	0.557	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level