



## School Lead Water Testing - Data Collection Form

School Short Name **Perez**  
Address 1241 W. 19th Street  
Facility ID 52428

Length of time water remained in pipes before sampled (hours) 13.30  
Report based on lab results dated 6/3/16  
Date of test 05/24/16  
Water last used (Time and date) Approx 4 PM 5/16/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22861-1-N-S-001	Kitchen sink 1	5/24/16 5:00 AM	0.155	BA
22861-1-N-S-002	Kitchen sink 1	5/24/16 5:00 AM	<.12	ND
22861-1-N-S-003	Kitchen sink 1	5/24/16 5:00 AM	<.12	ND
22861-1-N-S-004	Kitchen sink 1	5/24/16 5:00 AM	<.12	ND
22861-1-N-S-005	Kitchen sink 1	5/24/16 5:00 AM	<.12	ND
22861-1-N-S-001	Kitchen sink 2	5/24/16 5:00 AM	0.216	BA
22861-1-N-S-002	Kitchen sink 2	5/24/16 5:00 AM	0.207	BA
22861-1-N-S-003	Kitchen sink 2	5/24/16 5:00 AM	0.171	BA
22861-1-N-S-004	Kitchen sink 2	5/24/16 5:00 AM	0.28	BA
22861-1-N-S-005	Kitchen sink 2	5/24/16 5:00 AM	0.209	BA
22861-1-N01-F-001	Cafeteria fountain 1	5/24/16 5:00 AM	<.12	ND
22861-1-N01-F-002	Cafeteria fountain 1	5/24/16 5:00 AM	<.12	ND
22861-1-N01-F-003	Cafeteria fountain 1	5/24/16 5:00 AM	<.12	ND
22861-1-N01-F-004	Cafeteria fountain 1	5/24/16 5:00 AM	<.12	ND
22861-1-N01-F-005	Cafeteria fountain 1	5/24/16 5:00 AM	<.12	ND
22861-1-N02-F-001	Cafeteria fountain 2	5/24/16 5:00 AM	<.12	ND
22861-1-N02-F-002	Cafeteria fountain 2	5/24/16 5:00 AM	<.12	ND
22861-1-N02-F-003	Cafeteria fountain 2	5/24/16 5:00 AM	<.12	ND
22861-1-N02-F-004	Cafeteria fountain 2	5/24/16 5:00 AM	<.12	ND
22861-1-N02-F-005	Cafeteria fountain 2	5/24/16 5:00 AM	<.12	ND
22861-1-N-S-001	KG 101	5/24/16 5:00 AM	2.19	BA
22861-1-N-S-002	KG 101	5/24/16 5:00 AM	0.685	BA
22861-1-N-S-003	KG 101	5/24/16 5:00 AM	1.02	BA
22861-1-N-S-004	KG 101	5/24/16 5:00 AM	1.53	BA
22861-1-N-S-005	KG 101	5/24/16 5:00 AM	1.75	BA
22861-1-N-F-001	Fountain by bathroom	5/24/16 5:00 AM	<.12	ND
22861-1-N-F-002	Fountain by bathroom	5/24/16 5:00 AM	<.12	ND
22861-1-N-F-003	Fountain by bathroom	5/24/16 5:00 AM	<.12	ND
22861-1-N-F-004	Fountain by bathroom	5/24/16 5:00 AM	<.12	ND
22861-1-N-F-005	Fountain by bathroom	5/24/16 5:00 AM	0.817	BA
22861-1-N-S-001	KG 102	5/24/16 5:00 AM	0.339	BA
22861-1-N-S-002	KG 102	5/24/16 5:00 AM	0.157	BA
22861-1-N-S-003	KG 102	5/24/16 5:00 AM	0.166	BA
22861-1-N-S-004	KG 102	5/24/16 5:00 AM	0.239	BA
22861-1-N-S-005	KG 102	5/24/16 5:00 AM	0.719	BA
22861-1-N-S-001	KG 103	5/24/16 5:00 AM	0.305	BA
22861-1-N-S-002	KG 103	5/24/16 5:00 AM	0.17	BA
22861-1-N-S-003	KG 103	5/24/16 5:00 AM	0.345	BA
22861-1-N-S-004	KG 103	5/24/16 5:00 AM	0.488	BA
22861-1-N-S-005	KG 103	5/24/16 5:00 AM	0.406	BA
22861-2-N-F-001	2nd Floor - North Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-N-F-002	2nd Floor - North Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-N-F-003	2nd Floor - North Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-N-F-004	2nd Floor - North Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-N-F-005	2nd Floor - North Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-E-F-001	2nd Floor - East Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-E-F-002	2nd Floor - East Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-E-F-003	2nd Floor - East Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-E-F-004	2nd Floor - East Corridor	5/24/16 5:00 AM	<.12	ND
22861-2-E-F-005	2nd Floor - East Corridor	5/24/16 5:00 AM	<.12	ND
22861-1-E-F-001	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E-F-002	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E-F-003	Annex KG 105	5/24/16 5:00 AM	1.29	BA

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
22861-1-E-F-004	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E-F-005	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E3-S-001	Annex KG 105	5/24/16 5:00 AM	0.288	BA
22861-1-E3-S-002	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E3-S-003	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E3-S-004	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E3-S-005	Annex KG 105	5/24/16 5:00 AM	<.12	ND
22861-1-E2-S-001	Annex KG 103	5/24/16 5:00 AM	0.466	BA
22861-1-E2-S-002	Annex KG 103	5/24/16 5:00 AM	<.12	ND
22861-1-E2-S-003	Annex KG 103	5/24/16 5:00 AM	<.12	ND
22861-1-E2-S-004	Annex KG 103	5/24/16 5:00 AM	0.128	BA
22861-1-E2-S-005	Annex KG 103	5/24/16 5:00 AM	0.147	BA
22861-1-E1-S-001	Annex KG 101	5/24/16 5:00 AM	1.34	BA
22861-1-E1-S-002	Annex KG 101	5/24/16 5:00 AM	1.01	BA
22861-1-E1-S-003	Annex KG 101	5/24/16 5:00 AM	0.692	BA
22861-1-E1-S-004	Annex KG 101	5/24/16 5:00 AM	0.914	BA
22861-1-E1-S-005	Annex KG 101	5/24/16 5:00 AM	0.727	BA
22861-B-E-F-001	Annex Basement	5/24/16 5:00 AM	38.1	AA
22861-B-E-F-002	Annex Basement	5/24/16 5:00 AM	108	AA
22861-B-E-F-003	Annex Basement	5/24/16 5:00 AM	41.5	AA
22861-B-E-F-004	Annex Basement	5/24/16 5:00 AM	29.4	AA
22861-B-E-F-005	Annex Basement	5/24/16 5:00 AM	24.6	AA
22861-2-E-F-001	Annex 2nd Floor	5/24/16 5:00 AM	3.5	BA
22861-2-E-F-002	Annex 2nd Floor	5/24/16 5:00 AM	2.07	BA
22861-2-E-F-003	Annex 2nd Floor	5/24/16 5:00 AM	1.36	BA
22861-2-E-F-004	Annex 2nd Floor	5/24/16 5:00 AM	1.2	BA
22861-2-E-F-005	Annex 2nd Floor	5/24/16 5:00 AM	1.01	BA
22861-3-E-F-001	Annex 3rd Floor	5/24/16 5:00 AM	0.95	BA
22861-3-E-F-002	Annex 3rd Floor	5/24/16 5:00 AM	0.597	BA
22861-3-E-F-003	Annex 3rd Floor	5/24/16 5:00 AM	0.485	BA
22861-3-E-F-004	Annex 3rd Floor	5/24/16 5:00 AM	0.457	BA
22861-3-E-F-005	Annex 3rd Floor	5/24/16 5:00 AM	0.4	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

**SPREADSHEET LEGEND**

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations