![Chicago Public Schools logo]

July 19, 2016

Dear Mason families,

In light of national events that have brought increased attention to the issue of water quality, the City of Chicago announced several additional precautionary measures that will be added to the City's water testing protocol, continuing the City's track record of complying with current state and federal regulations as well as exceeding industry standards.

As part of this announcement, Chicago Public Schools (CPS) began testing the water for levels of lead from all schools across the district. Our top priority is the health and safety of our students and staff, and this testing was initiated out of an abundance of caution to ensure the water in our schools is safe. Schools are being tested based on a priority criteria that includes the age of the school, age of the students (with priority given to schools with pre-K programs), presence of a kitchen (where meals are prepared) and presence of pipes that could need repairs or replacement.

The results of all the schools are coming in on a rolling basis, and the majority have had levels under the EPA's action level of 15 parts per billion (ppb). At Mason samples were tested from 42 sites and the water sampled from one sink was above the action level of 15 ppb: A sink on the first floor read at 15 ppb. The water from the sink has been turned off and remediation plans are being created.

Chicago's water supply is free of lead when it leaves the treatment plant. However, lead can be found in some interior plumbing fixtures and materials, and lead found in tap water usually comes from the corrosion of these items. This explains why only one of the samples at Mason returned with elevated results – the issue is not system-wide, but is specific to the fixtures or pipes for that sink and will be addressed though the remediation plan. The full results of every school's water samples can be found online at cps.edu/leadtesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources, including paint, soil and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends going to your pediatrician or one of the local health care providers listed in the attachment for testing. Additionally, CDPH's lead hotline can address any health related questions you may have or help you in deciding whether to have your child tested; for questions or more information, please call 312-747-5323. For additional information about lead and children, visit www.cdc.gov/lead.

The safety of your children is our highest priority, and we are doing everything in our power to address this situation in a quick and thorough manner. We will continue to keep you and your family informed throughout this process.

Sincerely,

Forrest Claypool
CEO, Chicago Public Schools

Dr. Julie Morita
Commissioner, Chicago Department of Public Health

19 de julio de 2016

Estimadas familias de la escuela Mason,

Ante los eventos nacionales que han incrementado la atención en el tema de la calidad del agua, la Alcaldía de Chicago anunció varias medidas adicionales de precaución que serán agregadas al protocolo de prueba del agua de la ciudad, continuando con el cumplimiento de las regulaciones estatales y federales, que exceden los estándares industriales.

Como parte de este anuncio, las Escuelas Públicas de Chicago (CPS) comenzaron a medir los niveles de plomo en el agua de todas las escuelas del distrito. Nuestra principal prioridad es la salud y seguridad de todos nuestros estudiantes y personal, y estas pruebas fueron iniciadas solamente para extremar las precauciones y estar seguros de que el agua es segura. Las escuelas son examinadas con base a un criterio de prioridad que incluye la antigüedad del edificio, edad de los estudiantes (con prioridad para las escuelas con programas preescolares), presencia de una cocina (donde se preparan alimentos) y la presencia de cañerías que necesiten reparación o reemplazo.

Los resultados de todas las escuelas se están conociendo, y la mayoría ha registrado niveles por debajo del nivel de acción de la EPA, que es de 15 partículas por billón (ppb). En Mason se tomaron muestras en 42 lugares y el agua de una pileta tenía rastros de plomo por encima del nivel de acción de 15 ppb: una pileta del primer piso registró 15 ppb. El suministro de agua de la pileta fue interrumpido y se están creando planes para remediar la situación.

El agua de Chicago no tiene plomo cuando sale de la planta de tratamiento. Sin embargo, el plomo se puede encontrar en algunas cañerías internas y materiales, y el plomo encontrado en el agua potable es provocado usualmente por la corrosión de las cañerías. Esto explica por qué solamente una de las muestras de Mason registró un nivel elevado, un tema que no es general sino específico de la cañería, que será abordado en el plan de remediación. Los resultados completos del agua de cada escuela se pueden ver en línea en cps.edu/leadtesting.

Los lineamientos federales indican que los niños menores de seis años son los que corren mayores riesgos con la exposición al plomo, algo que puede ocurrir de varias fuentes, incluyendo pintura, tierra y algunos productos de consumo. Si están preocupados por la posible exposición de su hijo al plomo, el Departamento de Salud Pública de la ciudad de Chicago (CDPH) recomienda visitar a su pediatra o a alguno de los centros de salud listados en el material adjunto, para una prueba. Además, la línea directa del CDPH puede responder cualquier pregunta que tengan, o ayudarlos a decidir si su niño debe ser examinado; por preguntas o más información, llame por favor al 312-747-5323. Por información adicional sobre el plomo y los niños, visite www.cdc.gov/lead.

La seguridad de sus hijos es nuestra principal prioridad, y hacemos todo lo que está en nuestro poder para resolver esta situación de una manera rápida y rigurosa. Continuaremos informándoles sobre este proceso.

Sincerely,

Forrest Claypool
CEO, Escuelas Públicas de Chicago

Dra. Julie Morita, Comisionada
Departamento de Salud Pública de Chicago

School Lead Water Testing - Data Collection Form

School Name   **Mason**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-E-CS01-01	Kitchen	6/15/16 6:05 AM	None Detected	ND
1-E-CS01-02	Kitchen	6/15/16 6:05 AM	None Detected	ND
1-E-CS01-03	Kitchen	6/15/16 6:05 AM	None Detected	ND
1-E-CS01-04	Kitchen	6/15/16 6:05 AM	None Detected	ND
1-E-CS01-05	Kitchen	6/15/16 6:05 AM	None Detected	ND
1-E-CS02-06	Kitchen	6/15/16 6:07 AM	None Detected	ND
1-E-CS02-07	Kitchen	6/15/16 6:07 AM	None Detected	ND
1-E-CS02-08	Kitchen	6/15/16 6:07 AM	None Detected	ND
1-E-CS02-09	Kitchen	6/15/16 6:07 AM	None Detected	ND
1-E-CS02-10	Kitchen	6/15/16 6:07 AM	None Detected	ND
1-S-CS03-11	Kitchen	6/15/16 6:09 AM	None Detected	ND
1-S-CS03-12	Kitchen	6/15/16 6:09 AM	None Detected	ND
1-S-CS03-13	Kitchen	6/15/16 6:09 AM	None Detected	ND
1-S-CS03-14	Kitchen	6/15/16 6:09 AM	None Detected	ND
1-S-CS03-15	Kitchen	6/15/16 6:09 AM	None Detected	ND
1-S-CS04-16	Kitchen	6/15/16 6:11 AM	None Detected	ND
1-S-CS04-17	Kitchen	6/15/16 6:11 AM	None Detected	ND
1-S-CS04-18	Kitchen	6/15/16 6:11 AM	None Detected	ND
1-S-CS04-19	Kitchen	6/15/16 6:11 AM	None Detected	ND
1-S-CS04-20	Kitchen	6/15/16 6:11 AM	None Detected	ND
1-S-CS05-21	Kitchen	6/15/16 6:13 AM	None Detected	ND
1-S-CS05-22	Kitchen	6/15/16 6:13 AM	None Detected	ND
1-S-CS05-23	Kitchen	6/15/16 6:13 AM	None Detected	ND
1-S-CS05-24	Kitchen	6/15/16 6:13 AM	None Detected	ND
1-S-CS05-25	Kitchen	6/15/16 6:13 AM	None Detected	ND
1-W-CS06-26	Kitchen	6/15/16 6:15 AM	None Detected	ND
1-W-CS06-27	Kitchen	6/15/16 6:15 AM	None Detected	ND
1-W-CS06-28	Kitchen	6/15/16 6:15 AM	None Detected	ND
1-W-CS06-29	Kitchen	6/15/16 6:15 AM	None Detected	ND
1-W-CS06-30	Kitchen	6/15/16 6:15 AM	None Detected	ND
1-N-CS07-31	Pre-K 141	6/15/16 6:17 AM	None Detected	ND
1-N-CS07-32	Pre-K 141	6/15/16 6:17 AM	None Detected	ND
1-N-CS07-33	Pre-K 141	6/15/16 6:17 AM	None Detected	ND
1-N-CS07-34	Pre-K 141	6/15/16 6:17 AM	None Detected	ND
1-N-CS07-35	Pre-K 141	6/15/16 6:17 AM	None Detected	ND
1-N-WC01-36	Pre-K 141	6/15/16 6:19 AM	None Detected	ND
1-N-WC01-37	Pre-K 141	6/15/16 6:19 AM	None Detected	ND
1-N-WC01-38	Pre-K 141	6/15/16 6:19 AM	None Detected	ND
1-N-WC01-39	Pre-K 141	6/15/16 6:19 AM	None Detected	ND
1-N-WC01-40	Pre-K 141	6/15/16 6:19 AM	None Detected	ND
1-S-CS08-41	Pre-K 143	6/15/16 6:21 AM	None Detected	ND
1-S-CS08-42	Pre-K 143	6/15/16 6:21 AM	None Detected	ND
1-S-CS08-43	Pre-K 143	6/15/16 6:21 AM	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-CS08-44	Pre-K 143	6/15/16 6:21 AM	None Detected	ND
1-S-CS08-45	Pre-K 143	6/15/16 6:21 AM	None Detected	ND
1-S-WC02-46	Pre-K 143	6/15/16 6:23 AM	None Detected	ND
1-S-WC02-47	Pre-K 143	6/15/16 6:23 AM	None Detected	ND
1-S-WC02-48	Pre-K 143	6/15/16 6:23 AM	None Detected	ND
1-S-WC02-49	Pre-K 143	6/15/16 6:23 AM	None Detected	ND
1-S-WC02-50	Pre-K 143	6/15/16 6:23 AM	None Detected	ND
2-E-CS09-51	Kindergarten 149	6/15/16 6:25 AM	None Detected	ND
2-E-CS09-52	Kindergarten 149	6/15/16 6:25 AM	None Detected	ND
2-E-CS09-53	Kindergarten 149	6/15/16 6:25 AM	None Detected	ND
2-E-CS09-54	Kindergarten 149	6/15/16 6:25 AM	None Detected	ND
2-E-CS09-55	Kindergarten 149	6/15/16 6:25 AM	None Detected	ND
1-W-CS10-56	Kindergarten 151	6/15/16 6:27 AM	15	AA
1-W-CS10-57	Kindergarten 151	6/15/16 6:27 AM	None Detected	ND
1-W-CS10-58	Kindergarten 151	6/15/16 6:27 AM	None Detected	ND
1-W-CS10-59	Kindergarten 151	6/15/16 6:27 AM	None Detected	ND
1-W-CS10-60	Kindergarten 151	6/15/16 6:27 AM	None Detected	ND
1-N-WC01-61	1st FL Corridor addition Across from 149	6/15/16 6:29 AM	None Detected	ND
1-N-WC01-62	1st FL Corridor addition Across from 149	6/15/16 6:29 AM	None Detected	ND
1-N-WC01-63	1st FL Corridor addition Across from 149	6/15/16 6:29 AM	None Detected	ND
1-N-WC01-64	1st FL Corridor addition Across from 149	6/15/16 6:29 AM	None Detected	ND
1-N-WC01-65	1st FL Corridor addition Across from 149	6/15/16 6:29 AM	None Detected	ND
1-N-WC02-66	1st FL Corridor addition Across from 149	6/15/16 6:31 AM	None Detected	ND
1-N-WC02-67	1st FL Corridor addition Across from 149	6/15/16 6:31 AM	None Detected	ND
1-N-WC02-68	1st FL Corridor addition Across from 149	6/15/16 6:31 AM	None Detected	ND
1-N-WC02-69	1st FL Corridor addition Across from 149	6/15/16 6:31 AM	None Detected	ND
1-N-WC02-70	1st FL Corridor addition Across from 149	6/15/16 6:31 AM	None Detected	ND
2-N-WC01-71	2nd FL Corridor Addition Across from 253	6/15/16 6:33 AM	None Detected	ND
2-N-WC01-72	2nd FL Corridor Addition Across from 253	6/15/16 6:33 AM	None Detected	ND
2-N-WC01-73	2nd FL Corridor Addition Across from 253	6/15/16 6:33 AM	None Detected	ND
2-N-WC01-74	2nd FL Corridor Addition Across from 253	6/15/16 6:33 AM	None Detected	ND
2-N-WC01-75	2nd FL Corridor Addition Across from 253	6/15/16 6:33 AM	None Detected	ND
2-N-WC02-76	2nd FL Corridor Addition Across from 253	6/15/16 6:35 AM	None Detected	ND
2-N-WC02-77	2nd FL Corridor Addition Across from 253	6/15/16 6:35 AM	None Detected	ND
2-N-WC02-78	2nd FL Corridor Addition Across from 253	6/15/16 6:35 AM	None Detected	ND
2-N-WC02-79	2nd FL Corridor Addition Across from 253	6/15/16 6:35 AM	None Detected	ND
2-N-WC02-80	2nd FL Corridor Addition Across from 253	6/15/16 6:35 AM	None Detected	ND
3-N-WC01-81	3rd Fl Corridor Addition Across 353	6/15/16 6:37 AM	None Detected	ND
3-N-WC01-82	3rd Fl Corridor Addition Across 353	6/15/16 6:37 AM	None Detected	ND
3-N-WC01-83	3rd Fl Corridor Addition Across 353	6/15/16 6:37 AM	None Detected	ND
3-N-WC01-84	3rd Fl Corridor Addition Across 353	6/15/16 6:37 AM	None Detected	ND
3-N-WC01-85	3rd Fl Corridor Addition Across 353	6/15/16 6:37 AM	None Detected	ND
3-N-WC02-86	3rd Fl Corridor Addition Across 353	6/15/16 6:39 AM	None Detected	ND
3-N-WC02-87	3rd Fl Corridor Addition Across 353	6/15/16 6:39 AM	None Detected	ND
3-N-WC02-88	3rd Fl Corridor Addition Across 353	6/15/16 6:39 AM	None Detected	ND
3-N-WC02-89	3rd Fl Corridor Addition Across 353	6/15/16 6:39 AM	None Detected	ND
3-N-WC02-90	3rd Fl Corridor Addition Across 353	6/15/16 6:39 AM	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-E-WC01-91	1st Fl SE Corridor by 103 Main Building	6/15/16 6:41 AM	None Detected	ND
1-E-WC01-92	1st Fl SE Corridor by 103 Main Building	6/15/16 6:41 AM	None Detected	ND
1-E-WC01-93	1st Fl SE Corridor by 103 Main Building	6/15/16 6:41 AM	None Detected	ND
1-E-WC01-94	1st Fl SE Corridor by 103 Main Building	6/15/16 6:41 AM	None Detected	ND
1-E-WC01-95	1st Fl SE Corridor by 103 Main Building	6/15/16 6:41 AM	None Detected	ND
1-E-WC02-96	1st Fl SE Corridor by 103 Main Building	6/15/16 6:43 AM	None Detected	ND
1-E-WC02-97	1st Fl SE Corridor by 103 Main Building	6/15/16 6:43 AM	None Detected	ND
1-E-WC02-98	1st Fl SE Corridor by 103 Main Building	6/15/16 6:43 AM	None Detected	ND
1-E-WC02-99	1st Fl SE Corridor by 103 Main Building	6/15/16 6:43 AM	None Detected	ND
1-E-WC02-100	1st Fl SE Corridor by 103 Main Building	6/15/16 6:43 AM	None Detected	ND
1-E-WC01-101	1st FL NE Corridor Across 114 Main Building	6/15/16 6:45 AM	None Detected	ND
1-E-WC01-102	1st FL NE Corridor Across 114 Main Building	6/15/16 6:45 AM	None Detected	ND
1-E-WC01-103	1st FL NE Corridor Across 114 Main Building	6/15/16 6:45 AM	None Detected	ND
1-E-WC01-104	1st FL NE Corridor Across 114 Main Building	6/15/16 6:45 AM	None Detected	ND
1-E-WC01-105	1st FL NE Corridor Across 114 Main Building	6/15/16 6:45 AM	None Detected	ND
1-E-WC02-106	1st FL NE Corridor Across 114 Main Building	6/15/16 6:47 AM	None Detected	ND
1-E-WC02-107	1st FL NE Corridor Across 114 Main Building	6/15/16 6:47 AM	None Detected	ND
1-E-WC02-108	1st FL NE Corridor Across 114 Main Building	6/15/16 6:47 AM	None Detected	ND
1-E-WC02-109	1st FL NE Corridor Across 114 Main Building	6/15/16 6:47 AM	None Detected	ND
1-E-WC02-110	1st FL NE Corridor Across 114 Main Building	6/15/16 6:47 AM	None Detected	ND
2-E-WC01-111	2nd FL SE Corridor by 203 Main Building	6/15/16 6:49 AM	None Detected	ND
2-E-WC01-112	2nd FL SE Corridor by 203 Main Building	6/15/16 6:49 AM	None Detected	ND
2-E-WC01-113	2nd FL SE Corridor by 203 Main Building	6/15/16 6:49 AM	None Detected	ND
2-E-WC01-114	2nd FL SE Corridor by 203 Main Building	6/15/16 6:49 AM	None Detected	ND
2-E-WC01-115	2nd FL SE Corridor by 203 Main Building	6/15/16 6:49 AM	None Detected	ND
2-E-WC02-116	2nd FL SE Corridor by 203 Main Building	6/15/16 6:51 AM	None Detected	ND
2-E-WC02-117	2nd FL SE Corridor by 203 Main Building	6/15/16 6:51 AM	None Detected	ND
2-E-WC02-118	2nd FL SE Corridor by 203 Main Building	6/15/16 6:51 AM	None Detected	ND
2-E-WC02-119	2nd FL SE Corridor by 203 Main Building	6/15/16 6:51 AM	None Detected	ND
2-E-WC02-120	2nd FL SE Corridor by 203 Main Building	6/15/16 6:51 AM	None Detected	ND
3-E-WC01-121	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:53 AM	None Detected	ND
3-E-WC01-122	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:53 AM	None Detected	ND
3-E-WC01-123	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:53 AM	None Detected	ND
3-E-WC01-124	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:53 AM	None Detected	ND
3-E-WC01-125	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:53 AM	None Detected	ND
3-E-WC02-126	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:55 AM	None Detected	ND
3-E-WC02-127	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:55 AM	None Detected	ND
3-E-WC02-128	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:55 AM	None Detected	ND
3-E-WC02-129	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:55 AM	None Detected	ND
3-E-WC02-130	3rd FL SE Corridor Across from 304 Main Building	6/15/16 6:55 AM	None Detected	ND
3-E-WC01-131	3rd FL NE Corridor Across from 314 Main Building	6/15/16 6:57 AM	None Detected	ND
3-E-WC01-132	3rd FL NE Corridor Across from 314 Main Building	6/15/16 6:57 AM	None Detected	ND
3-E-WC01-133	3rd FL NE Corridor Across from 314 Main Building	6/15/16 6:57 AM	None Detected	ND
3-E-WC01-134	3rd FL NE Corridor Across from 314 Main Building	6/15/16 6:57 AM	None Detected	ND
3-E-WC01-135	3rd FL NE Corridor Across from 314 Main Building	6/15/16 6:57 AM	None Detected	ND
1-W-CS01-136	Kitchen 1958 Addition	6/15/16 6:59 AM	8.25	BA
1-W-CS01-137	Kitchen 1958 Addition	6/15/16 6:59 AM	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-W-CS01-138	Kitchen 1958 Addition	6/15/16 6:59 AM	None Detected	ND
1-W-CS01-139	Kitchen 1958 Addition	6/15/16 6:59 AM	None Detected	ND
1-W-CS01-140	Kitchen 1958 Addition	6/15/16 6:59 AM	None Detected	ND
1-W-CS02-141	Kitchen 1958 Addition	6/15/16 7:01 AM	None Detected	ND
1-W-CS02-142	Kitchen 1958 Addition	6/15/16 7:01 AM	None Detected	ND
1-W-CS02-143	Kitchen 1958 Addition	6/15/16 7:01 AM	None Detected	ND
1-W-CS02-144	Kitchen 1958 Addition	6/15/16 7:01 AM	None Detected	ND
1-W-CS02-145	Kitchen 1958 Addition	6/15/16 7:01 AM	None Detected	ND
1-W-CS03-146	Kitchen 1958 Addition	6/15/16 7:03 AM	None Detected	ND
1-W-CS03-147	Kitchen 1958 Addition	6/15/16 7:03 AM	None Detected	ND
1-W-CS03-148	Kitchen 1958 Addition	6/15/16 7:03 AM	None Detected	ND
1-W-CS03-149	Kitchen 1958 Addition	6/15/16 7:03 AM	None Detected	ND
1-W-CS03-150	Kitchen 1958 Addition	6/15/16 7:03 AM	None Detected	ND
1-W-CS04-151	Kitchen 1958 Addition	6/15/16 7:05 AM	None Detected	ND
1-W-CS04-152	Kitchen 1958 Addition	6/15/16 7:05 AM	None Detected	ND
1-W-CS04-153	Kitchen 1958 Addition	6/15/16 7:05 AM	None Detected	ND
1-W-CS04-154	Kitchen 1958 Addition	6/15/16 7:05 AM	None Detected	ND
1-W-CS04-155	Kitchen 1958 Addition	6/15/16 7:05 AM	None Detected	ND
1-S-CS01-156	Pre-K 117 1958 Addition	6/15/16 7:07 AM	5.97	BA
1-S-CS01-157	Pre-K 117 1958 Addition	6/15/16 7:07 AM	None Detected	ND
1-S-CS01-158	Pre-K 117 1958 Addition	6/15/16 7:07 AM	None Detected	ND
1-S-CS01-159	Pre-K 117 1958 Addition	6/15/16 7:07 AM	None Detected	ND
1-S-CS01-160	Pre-K 117 1958 Addition	6/15/16 7:07 AM	None Detected	ND
1-S-F01-161	Pre-K 117 1958 Addition	6/15/16 7:09 AM	None Detected	ND
1-S-F01-162	Pre-K 117 1958 Addition	6/15/16 7:09 AM	None Detected	ND
1-S-F01-163	Pre-K 117 1958 Addition	6/15/16 7:09 AM	None Detected	ND
1-S-F01-164	Pre-K 117 1958 Addition	6/15/16 7:09 AM	None Detected	ND
1-S-F01-165	Pre-K 117 1958 Addition	6/15/16 7:09 AM	None Detected	ND
1-N-CS01-166	Pre-K 119 1958 Addition	6/15/16 7:11 AM	None Detected	ND
1-N-CS01-167	Pre-K 119 1958 Addition	6/15/16 7:11 AM	None Detected	ND
1-N-CS01-168	Pre-K 119 1958 Addition	6/15/16 7:11 AM	None Detected	ND
1-N-CS01-169	Pre-K 119 1958 Addition	6/15/16 7:11 AM	None Detected	ND
1-N-CS01-170	Pre-K 119 1958 Addition	6/15/16 7:11 AM	None Detected	ND
1-N-F01-171	Pre-K 119 1958 Addition	6/15/16 7:13 AM	None Detected	ND
1-N-F01-172	Pre-K 119 1958 Addition	6/15/16 7:13 AM	None Detected	ND
1-N-F01-173	Pre-K 119 1958 Addition	6/15/16 7:13 AM	None Detected	ND
1-N-F01-174	Pre-K 119 1958 Addition	6/15/16 7:13 AM	None Detected	ND
1-N-F01-175	Pre-K 119 1958 Addition	6/15/16 7:13 AM	None Detected	ND
1-S-WC01-176	1st FL Corridor addition Across from 129	6/15/16 7:15 AM	None Detected	ND
1-S-WC01-177	1st FL Corridor addition Across from 129	6/15/16 7:15 AM	None Detected	ND
1-S-WC01-178	1st FL Corridor addition Across from 129	6/15/16 7:15 AM	None Detected	ND
1-S-WC01-179	1st FL Corridor addition Across from 129	6/15/16 7:15 AM	None Detected	ND
1-S-WC01-180	1st FL Corridor addition Across from 129	6/15/16 7:15 AM	None Detected	ND
1-S-WC02-181	1st FL Corridor addition Across from 129	6/15/16 7:17 AM	None Detected	ND
1-S-WC02-182	1st FL Corridor addition Across from 129	6/15/16 7:17 AM	None Detected	ND
1-S-WC02-183	1st FL Corridor addition Across from 129	6/15/16 7:17 AM	None Detected	ND
1-S-WC02-184	1st FL Corridor addition Across from 129	6/15/16 7:17 AM	None Detected	ND

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
1-S-WC02-185	1st FL Corridor addition Across from 129	6/15/16 7:17 AM	None Detected	ND
2-S-WC01-186	2nd FL Corridor Addition Across from 223	6/15/16 7:19 AM	10.4	BA
2-S-WC01-187	2nd FL Corridor Addition Across from 223	6/15/16 7:19 AM	11.9	BA
2-S-WC01-188	2nd FL Corridor Addition Across from 223	6/15/16 7:19 AM	6.93	BA
2-S-WC01-189	2nd FL Corridor Addition Across from 223	6/15/16 7:19 AM	None Detected	ND
2-S-WC01-190	2nd FL Corridor Addition Across from 223	6/15/16 7:19 AM	None Detected	ND
2-S-WC03-191	2nd FL Corridor Addition Across from 223	6/15/16 7:21 AM	None Detected	ND
2-S-WC03-192	2nd FL Corridor Addition Across from 223	6/15/16 7:21 AM	None Detected	ND
2-S-WC03-193	2nd FL Corridor Addition Across from 223	6/15/16 7:21 AM	None Detected	ND
2-S-WC03-194	2nd FL Corridor Addition Across from 223	6/15/16 7:21 AM	None Detected	ND
2-S-WC03-195	2nd FL Corridor Addition Across from 223	6/15/16 7:21 AM	None Detected	ND
2-S-WC02-196	2nd FL Corridor Addition Across from 223	6/15/16 7:23 AM	None Detected	ND
2-S-WC02-197	2nd FL Corridor Addition Across from 223	6/15/16 7:23 AM	None Detected	ND
2-S-WC02-198	2nd FL Corridor Addition Across from 223	6/15/16 7:23 AM	None Detected	ND
2-S-WC02-199	2nd FL Corridor Addition Across from 223	6/15/16 7:23 AM	None Detected	ND
2-S-WC02-200	2nd FL Corridor Addition Across from 223	6/15/16 7:23 AM	None Detected	ND
3-S-WC01-201	3rd FL Corridor Addition Across from 325	6/15/16 7:25 AM	None Detected	ND
3-S-WC01-202	3rd FL Corridor Addition Across from 325	6/15/16 7:25 AM	None Detected	ND
3-S-WC01-203	3rd FL Corridor Addition Across from 325	6/15/16 7:25 AM	None Detected	ND
3-S-WC01-204	3rd FL Corridor Addition Across from 325	6/15/16 7:25 AM	None Detected	ND
3-S-WC01-205	3rd FL Corridor Addition Across from 325	6/15/16 7:25 AM	None Detected	ND
3-S-WC02-206	3rd FL Corridor Addition Across from 325	6/15/16 7:27 AM	None Detected	ND
3-S-WC02-207	3rd FL Corridor Addition Across from 325	6/15/16 7:27 AM	None Detected	ND
3-S-WC02-208	3rd FL Corridor Addition Across from 325	6/15/16 7:27 AM	None Detected	ND
3-S-WC02-209	3rd FL Corridor Addition Across from 325	6/15/16 7:27 AM	None Detected	ND
3-S-WC02-210	3rd FL Corridor Addition Across from 325	6/15/16 7:27 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND
ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations