



School Lead Water Testing - Data Collection Form

School Short Name **Whittier**
Address 1900 W. 23rd Street

Length of time water remained in pipes before sampled (hours) 13.00
Report based on lab results dated 6/3/16
Date of test 05/24/16
Water last used (Time and date) Approx 4 PM 5/23/16

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
25861-3-N01-F-001	Outside room 301	5/24/16 5:00 AM	1.32	BA
25861-3-N01-F-002	Outside room 301	5/24/16 5:00 AM	1.14	BA
25861-3-N01-F-003	Outside room 301	5/24/16 5:00 AM	1.01	BA
25861-3-N01-F-004	Outside room 301	5/24/16 5:00 AM	1.01	BA
25861-3-N01-F-005	Outside room 301	5/24/16 5:00 AM	0.912	BA
25861-B-E01-F-001	Outside room 017	5/24/16 5:00 AM	0.126	BA
25861-B-E01-F-002	Outside room 017	5/24/16 5:00 AM	0.188	BA
25861-B-E01-F-003	Outside room 017	5/24/16 5:00 AM	0.134	BA
25861-B-E01-F-004	Outside room 017	5/24/16 5:00 AM	<0.120	ND
25861-B-E01-F-005	Outside room 017	5/24/16 5:00 AM	<0.120	ND
25861-B-E-S-001	Kitchen Sink	5/24/16 5:00 AM	1.26	BA
25861-B-E-S-002	Kitchen Sink	5/24/16 5:00 AM	0.222	BA
25861-B-E-S-003	Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
25861-B-E-S-004	Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
25861-B-E-S-005	Kitchen Sink	5/24/16 5:00 AM	<0.120	ND
25861-B-N01-F-001	Basement Outside Room	5/24/16 5:00 AM	0.122	BA
25861-B-N01-F-002	Basement Outside Room	5/24/16 5:00 AM	<0.102	ND
25861-B-N01-F-003	Basement Outside Room	5/24/16 5:00 AM	<0.102	ND
25861-B-N01-F-004	Basement Outside Room	5/24/16 5:00 AM	<0.102	ND
25861-B-N01-F-005	Basement Outside Room	5/24/16 5:00 AM	0.138	BA
25861-B-N02-F-001	Fountain inside room 017	5/24/16 5:00 AM	0.345	BA
25861-B-N02-F-002	Fountain inside room 017	5/24/16 5:00 AM	<0.102	ND
25861-B-N02-F-003	Fountain inside room 017	5/24/16 5:00 AM	<0.102	ND
25861-B-N02-F-004	Fountain inside room 017	5/24/16 5:00 AM	<0.102	ND
25861-B-N02-F-005	Fountain inside room 017	5/24/16 5:00 AM	<0.102	ND
25861-1-N-S-001	Sink Pre-K	5/24/16 5:00 AM	0.183	BA
25861-1-N-S-002	Sink Pre-K	5/24/16 5:00 AM	0.589	BA
25861-1-N-S-003	Sink Pre-K	5/24/16 5:00 AM	0.447	BA
25861-1-N-S-004	Sink Pre-K	5/24/16 5:00 AM	0.33	BA
25861-1-N-S-005	Sink Pre-K	5/24/16 5:00 AM	0.215	BA
25861-2-N03-F-001	F3 hallway outside room 202	5/24/16 5:00 AM	0.325	BA
25861-2-N03-F-002	F3 hallway outside room 202	5/24/16 5:00 AM	0.725	BA
25861-2-N03-F-003	F3 hallway outside room 202	5/24/16 5:00 AM	0.727	BA
25861-2-N03-F-004	F3 hallway outside room 202	5/24/16 5:00 AM	0.73	BA
25861-2-N03-F-005	F3 hallway outside room 202	5/24/16 5:00 AM	0.716	BA
25861-1-N01-F-001	Fountain outside room 102	5/24/16 5:00 AM	0.851	BA
25861-1-N01-F-002	Fountain outside room 102	5/24/16 5:00 AM	0.653	BA
25861-1-N01-F-003	Fountain outside room 102	5/24/16 5:00 AM	0.649	BA
25861-1-N01-F-004	Fountain outside room 102	5/24/16 5:00 AM	0.579	BA
25861-1-N01-F-005	Fountain outside room 102	5/24/16 5:00 AM	0.533	BA
25861-2-N01-F-001	F1 hallway outside room 202	5/24/16 5:00 AM	0.572	BA
25861-2-N01-F-002	F1 hallway outside room 202	5/24/16 5:00 AM	0.734	BA
25861-2-N01-F-003	F1 hallway outside room 202	5/24/16 5:00 AM	0.72	BA
25861-2-N01-F-004	F1 hallway outside room 202	5/24/16 5:00 AM	0.72	BA
25861-2-N01-F-005	F1 hallway outside room 202	5/24/16 5:00 AM	0.774	BA
25861-2-N02-F-001	F2 hallway outside room 202	5/24/16 5:00 AM	0.367	BA

25861-2N02-F-002	F2 hallway outside room 202	5/24/16 5:00 AM	0.948	BA
25861-2-N02-F-003	F2 hallway outside room 202	5/24/16 5:00 AM	0.759	BA
25861-2-N02-F-004	F2 hallway outside room 202	5/24/16 5:00 AM	0.853	BA
25861-2-N02-F-005	F2 hallway outside room 202	5/24/16 5:00	0.801	BA

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit
BA-Below EPA Action Level of 15 ppb
AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations