



## School Lead Water Testing Summary

**School Short Name** [Webster](#)  
**Address** [4055 W. Arthington](#)  
**Facility ID** [51215](#)  
**CPS Team Member** [Craig Edgerley](#)  
**MEC Team Member** [Evan Christian](#)

**Length of time water remained in pipes before sampled** [Approx. 10 hours](#)  
**Water last used (Time and date)** [Approx. 8 PM 4/28/16](#)  
**Date of test** [4/29/2016](#)  
**Report based on lab results dated** [5/11/2016](#)

Sample ID #	Sample Location	Sample Collection Time & Date	Test Results (ppb)	ppb Level
<a href="#">51215-1-K-CS-01</a>	<a href="#">Kitchen</a>	<a href="#">6:03 AM 4/29/16</a>	<a href="#">ND</a>	<a href="#">-</a>
<a href="#">51215-1-N-WC-02</a>	<a href="#">Hallway by Kitchen</a>	<a href="#">6:05 AM 4/29/16</a>	<a href="#">ND</a>	<a href="#">-</a>
<a href="#">51215-1-S-WC-03</a>	<a href="#">Hallway by Main Office</a>	<a href="#">6:10 AM 4/29/16</a>	<a href="#">ND</a>	<a href="#">-</a>
<a href="#">51215-2-S-WC-04</a>	<a href="#">Hallway by Room 211</a>	<a href="#">6:13 AM 4/29/16</a>	<a href="#">ND</a>	<a href="#">-</a>
<a href="#">51215-2-N-WC-05</a>	<a href="#">Hallway by Room 223</a>	<a href="#">6:15 AM 4/29/16</a>	<a href="#">ND</a>	<a href="#">-</a>

**EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L**

### SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit  
BA-Below EPA Action Level of 15 ppb  
AA-Above EPA Action Level

**Chicago Public Schools - Department of Facility Operations**