



# School Lead Water Testing - Data Collection Form

School Short Name    **Beaubien**

Sample ID #	Sample Location	Sample Collection Time & Date	Test Result (ppb)	Test Results
G-C-F01-01	Ground FL Lunchroom	6/11/16 6:00 AM	None Detected	ND
G-C-F01-02	Ground FL Lunchroom	6/11/16 6:00 AM	None Detected	ND
G-C-F01-03	Ground FL Lunchroom	6/11/16 6:00 AM	None Detected	ND
G-C-F01-04	Ground FL Lunchroom	6/11/16 6:00 AM	None Detected	ND
G-C-F01-05	Ground FL Lunchroom	6/11/16 6:00 AM	None Detected	ND
G-C-F02-06	Ground FL Lunchroom	6/11/16 6:02 AM	None Detected	ND
G-C-F02-07	Ground FL Lunchroom	6/11/16 6:02 AM	None Detected	ND
G-C-F02-08	Ground FL Lunchroom	6/11/16 6:02 AM	None Detected	ND
G-C-F02-09	Ground FL Lunchroom	6/11/16 6:02 AM	None Detected	ND
G-C-F02-10	Ground FL Lunchroom	6/11/16 6:02 AM	None Detected	ND
3-SE-F01-11	3rd FL S Wing by Room 305	6/11/16 6:04 AM	None Detected	ND
3-SE-F01-12	3rd FL S Wing by Room 305	6/11/16 6:04 AM	None Detected	ND
3-SE-F01-13	3rd FL S Wing by Room 305	6/11/16 6:04 AM	None Detected	ND
3-SE-F01-14	3rd FL S Wing by Room 305	6/11/16 6:04 AM	None Detected	ND
3-SE-F01-15	3rd FL S Wing by Room 305	6/11/16 6:04 AM	None Detected	ND
2-S-F01-16	By Room 209	6/11/16 6:06 AM	None Detected	ND
2-S-F01-17	By Room 209	6/11/16 6:06 AM	None Detected	ND
2-S-F01-18	By Room 209	6/11/16 6:06 AM	None Detected	ND
2-S-F01-19	By Room 209	6/11/16 6:06 AM	None Detected	ND
2-S-F01-20	By Room 209	6/11/16 6:06 AM	None Detected	ND
2-S-F02-21	By Room 209	6/11/16 6:08 AM	None Detected	ND
2-S-F02-22	By Room 209	6/11/16 6:08 AM	None Detected	ND
2-S-F02-23	By Room 209	6/11/16 6:08 AM	None Detected	ND
2-S-F02-24	By Room 209	6/11/16 6:08 AM	None Detected	ND
2-S-F02-25	By Room 209	6/11/16 6:08 AM	None Detected	ND
2-N-F01-26	2nd FL By Room 205	6/11/16 6:10 AM	None Detected	ND
2-N-F01-27	2nd FL By Room 205	6/11/16 6:10 AM	None Detected	ND
2-N-F01-28	2nd FL By Room 205	6/11/16 6:10 AM	None Detected	ND
2-N-F01-29	2nd FL By Room 205	6/11/16 6:10 AM	None Detected	ND
2-N-F01-30	2nd FL By Room 205	6/11/16 6:10 AM	None Detected	ND
2-N-F02-31	2nd FL By Room 205	6/11/16 6:12 AM	None Detected	ND
2-N-F02-32	2nd FL By Room 205	6/11/16 6:12 AM	None Detected	ND
2-N-F02-33	2nd FL By Room 205	6/11/16 6:12 AM	None Detected	ND
2-N-F02-34	2nd FL By Room 205	6/11/16 6:12 AM	None Detected	ND
2-N-F02-35	2nd FL By Room 205	6/11/16 6:12 AM	None Detected	ND
1-S-F01-36	1st Fl by Room 109	6/11/16 6:14 AM	None Detected	ND
1-S-F01-37	1st Fl by Room 109	6/11/16 6:14 AM	None Detected	ND
1-S-F01-38	1st Fl by Room 109	6/11/16 6:14 AM	None Detected	ND
1-S-F01-39	1st Fl by Room 109	6/11/16 6:14 AM	None Detected	ND
1-S-F01-40	1st Fl by Room 109	6/11/16 6:14 AM	None Detected	ND
1-S-F02-41	1st Fl by Room 109	6/11/16 6:16 AM	None Detected	ND
1-S-F02-42	1st Fl by Room 109	6/11/16 6:16 AM	None Detected	ND
1-S-F02-43	1st Fl by Room 109	6/11/16 6:16 AM	None Detected	ND
1-S-F02-44	1st Fl by Room 109	6/11/16 6:16 AM	None Detected	ND
1-S-F02-45	1st Fl by Room 109	6/11/16 6:16 AM	None Detected	ND
G-N-CS01-46	Kitchen on Ground Level	6/11/16 6:18 AM	None Detected	ND
G-N-CS01-47	Kitchen on Ground Level	6/11/16 6:18 AM	None Detected	ND
G-N-CS01-48	Kitchen on Ground Level	6/11/16 6:18 AM	None Detected	ND
G-N-CS01-49	Kitchen on Ground Level	6/11/16 6:18 AM	None Detected	ND
G-N-CS01-50	Kitchen on Ground Level	6/11/16 6:18 AM	None Detected	ND
G-N-CS02-01	Kitchen on Ground Level	8/10/16 7:55 AM	14.9	BA
G-N-CS02-02	Kitchen on Ground Level	8/10/16 7:55 AM	43	AA
G-N-CS02-03	Kitchen on Ground Level	8/10/16 7:55 AM	21.9	AA
G-N-CS02-04	Kitchen on Ground Level	8/10/16 7:55 AM	15.6	AA
G-N-CS02-05	Kitchen on Ground Level	8/10/16 7:55 AM	19.4	AA
G-N-CS03-56	Kitchen on Ground Level	6/11/16 6:22 AM	None Detected	ND
G-N-CS03-57	Kitchen on Ground Level	6/11/16 6:22 AM	None Detected	ND
G-N-CS03-58	Kitchen on Ground Level	6/11/16 6:22 AM	None Detected	ND
G-N-CS03-59	Kitchen on Ground Level	6/11/16 6:22 AM	None Detected	ND
G-N-CS03-60	Kitchen on Ground Level	6/11/16 6:22 AM	None Detected	ND
1-E-F01-61	E. Side by Mechanical Room	6/11/16 7:00 AM	None Detected	ND
1-E-F01-62	E. Side by Mechanical Room	6/11/16 7:00 AM	None Detected	ND
1-E-F01-63	E. Side by Mechanical Room	6/11/16 7:00 AM	None Detected	ND
1-E-F01-64	E. Side by Mechanical Room	6/11/16 7:00 AM	None Detected	ND
1-E-F01-65	E. Side by Mechanical Room	6/11/16 7:00 AM	None Detected	ND
1-E-F02-66	E. Side by Mechanical Room	6/11/16 7:02 AM	None Detected	ND
1-E-F02-67	E. Side by Mechanical Room	6/11/16 7:02 AM	None Detected	ND
1-E-F02-68	E. Side by Mechanical Room	6/11/16 7:02 AM	None Detected	ND
1-E-F02-69	E. Side by Mechanical Room	6/11/16 7:02 AM	None Detected	ND
1-E-F02-70	E. Side by Mechanical Room	6/11/16 7:02 AM	None Detected	ND

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

## SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level