



School Lead Water Testing Summary

School Short Name **Kellman**

Address 3030 W. Arthington St.

Facility ID 51223

CPS Team Member Prins Sales

MEC Team Member Roxana Ordonez

Length of time water remained in pipes before sampled [Approx 8-9 hours](#)

Water last used (Time and date) [Approx 10 PM 5/9/16](#)

Date of test [5/10/2016](#)

Report based on lab results dated [5/2/2016, 5/18/2016](#)

| Sample ID # | Sample Location | Sample Collection Time & Date | Test Results (ppb) | ppb Level |
|----------------------------------|---------------------|---------------------------------|--------------------|-----------|
| 51223-1-E-CS-01 | Kitchen | 6:35 AM 4/28/16 | ND | - |
| 51223-1-E-F-02 | Inside of Room 111 | 6:41 AM 4/28/16 | ND | - |
| 51223-1-E-F-03 | Hallway by Room 111 | 6:45 AM 4/28/16 | ND | - |
| 51223-1-NW-WC-04 | Hallway by Room 105 | 6:49 AM 4/28/16 | ND | - |
| 51223-2-NW-WC-05 | Hallway by Room 207 | 6:54 AM 4/28/16 | ND | - |
| 51223-2-E-F-06 | Hallway by Room 215 | 6:57 AM 4/28/16 | ND | - |
| 51223-3-E-WC-07 | Hallway by Room 313 | 7:00 AM 4/28/16 | ND | - |
| 51223-3-NW-WC-08 | Hallway by Room 307 | 7:03 AM 4/28/16 | ND | - |
| | | | | |

EPA ACTION LEVEL FOR LEAD IS 15 ppb or 15 µg/L

SPREADSHEET LEGEND

ND-Not Detected at the Reporting Limit

BA-Below EPA Action Level of 15 ppb

AA-Above EPA Action Level

Chicago Public Schools - Department of Facility Operations