

LEGEND

- HYDRANT BOLLARD, PER MOUNTLAKE TERRACE STANDARD PLAN #212
- > FIRE DEPARTMENT CONNECTION (fde)
- +— FH FIRE HYDRANT ASSEMBLY, PER MOUNTLAKE TERRACE STANDARD PLAN #201
- WATER METER
- MH SANITARY SEWER MANHOLE
- CLEAN OUT
- SANITARY SEWER LINE
- WATER LINE WITH 10' EASEMENT

WATER AND SANITARY SEWER CONSTRUCTION NOTES

1. FIRE HYDRANTS SHALL BE ASSEMBLED ACCORDING TO MOUNTLAKE TERRACE STANDARD PLAN #201. HYDRANT GUARD POST SHALL COMPLY WITH MOUNTLAKE TERRACE STANDARD PLAN #212.
2. TEMPORARY AND FINAL PATCHING FOR PIPES CROSSING 228TH ST SW SHALL COMPLY WITH MOUNTLAKE TERRACE STANDARD PLAN #107.
3. THE 2" METER SERVICE SHALL BE INSTALLED ACCORDING TO MOUNTLAKE TERRACE STANDARD PLAN #203 AND THE 3" METER SERVICE SHALL BE INSTALLED ACCORDING TO MOUNTLAKE STANDARD PLAN #204.
4. TRENCHES FOR SANITARY SEWER PIPES SHALL CONFORM TO MOUNTLAKE TERRACE STANDARD PLAN #304.
5. SANITARY SEWER MANHOLES SHALL CONFORM TO MOUNTLAKE TERRACE STANDARD PLAN #305.
6. SANITARY SEWER CLEANOUTS SHALL CONFORM TO MOUNTLAKE TERRACE STANDARD PLAN #303.
7. WATER LINE SHALL GO UNDER STORM LINE.
8. WHERE 18" OF SEPARATION IS NOT MAINTAINED BETWEEN WATER MAIN AND STORM LINE PLACE 2" THICK X 24" SQUARE EXTRUDED POLYSTYRENE INSULATION BOARD ON TOP OF STORM SEWER BEDDED IN SAND.
9. PRIVATE FIRE SYSTEM SHOWN HERE IS FOR INFORMATION ONLY. PRIVATE FIRE SYSTEM TO BE INSTALLED PER SEPARATE PERMIT. REFER TO FIRE PLAN FOR CONSTRUCTION.

Scans: scans013865.pdf

VERTICAL DATUM: NGVD 1929; PT. 56-16
BENCHMARK: NORTH RIM OF MONUMENT CASE AT 56TH AVE. AND 228TH ST. S.W. AS LISTED IN CITY OF MOUNTLAKE TERRACE BENCHMARK LIST.
ELEVATION = 485.65'

PLAN
SCALE: 1" = 30'

PLOT PLAN APPROVED
DATE 8/24/00
Engineering Division

REVISION
AUG 17 2000

WATER AND SEWER PLAN

C4.0

Edmonds School District No. 15

TERRACE PARK SCHOOL


5409 228th Street SW
Mountlake Terrace, Washington

Date:	
Job No.:	9822
Drawn By:	KPH
Checked By:	ARM
Filename:	21-99-014
Revisions:	
1	5/19/00
2	7/25/00
3	8/15/00

PERMIT SET

INTEGRUS
ARCHITECTURE

720 THIRD AVENUE, SUITE 2300 - SEATTLE WA 98104
TELEPHONE 206-428-3137 FAX 206-428-3138



Reid Middleton
728 134th Street SW - Suite 200
Everett, Washington 98204
Ph: 425 741-3800