Cont Alma 19 Augus Banna 19 Walter Buy Cast iron tee with 6" flanged side outlet or tapping tee.
5/8" x 3" bolts with nots for flanged connection, zinc or cadmium plated, or equal. Ring gasket 1/16" rubber cloth inserted. 3. Gate valve, 6° double disc. Non-rising stem, bronze mounted AWWA Standard Specifications for 300 PSI. Testing, 200 PSI service, one end flanged, one end mechanical joint. Valves shall open left and be equipped with 2° square operating 4. Valve box cast iron, Olympic Foundry, Atlas Foundry or equal. 5. 6° C.I. pipe plain ends variable length or spool. pint retainer glands w/set screws. Scan Name: scans06119.pdf inlet connection: Two 2-1/2 N.S.T. hose connections and one 4° pump connection (Scattle Standard): Fainted with rust resistant shop coat and one finish coat of high quality Federal Yellow: All Hydrant to open left and conform to AWWA Standard Specifications 9. 1/4 on yard washed gravel for hydrant drainage. Scan Date: LF = 172' 1.296% The E. Cinman 12 2/82 SAINT PIUS X CHURCH & SOCIAL HALL, MOUNTLAKE JERRACE, WA. GOL ROY W. KOCZARSKI A.I.A. - ARCHITECTS 2203 BOYLSTON E. SEATTLE WA. 98102 / TSL. 324-2340