



SCALE 1"=30'



## NOTES:

1. WATER METER BOXES ON THE FOLLOWING LOTS 14, 15, 18, & 26-31 ARE LOCATED IN PROPOSED DRIVEWAYS. REFER MLT STD. PLAN #202 FOR METER BOX REQUIREMENT IN AREAS WITH VEHICULAR TRAFFIC. ALL SERVICES 3/4" LINE AND 3/4" METER.
2. TRENCH BEDDING FOR WATER MAINS TO BE PER NOTE #8 OF "WATER NOTES" ON SHEET 10. TRENCH BEDDING FOR SANITARY SEWER MAINS TO BE PER NOTE #17 OF "SANITARY SEWER" NOTES ON SHT 10.
3. STATIONING FOR SANITARY SEWER MANHOLES ARE TO CENTER OF THE STRUCTURE.

NOTE: REMOVE TEMP CAP AND CONNECT TO EXISTING AFTER SEWER MAINS HAVE BEEN TESTED, CLEANED, VIDEO INSPECTED AND ACCEPTED BY THE CITY.

LYNNWOOD ACRES UNRECORDED

MOBILE HOME

N 88°45'27" W

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

25' B.S.B.L.

TOP SS MH = 453.69

INV IN S &amp; OUT N = 442.63

CEDARWOOD PARK CONDO.  
VOL. 42 PG. 102

44th AVE. W

216th ST. SW

MURPHY'S CORNER  
VOL. 48 PG. 60-61CB TYPE 2 TOP = 458.61  
12" RCP N = 451.11  
12" RCP S = 451.25  
12" CMP W = 451.23CB TYPE 2 TOP = 459.11  
12" CMP W = 451.41  
12" CMP E IN RESTRICTOR = 451.29  
TOP OF 12" CMP = 455.38  
TOP INSIDE STRUCTURE = 457.75TOP SS MH = 458.86  
INV IN S & OUT N = 447.01CB TYPE 1 TOP = 460.07  
12" RCP N = 453.57  
12" RCP S = 452.84  
8" DUCT E = 454.32SS MH TOP = 460.59  
INV IN S = 449.03  
INV OUT N = 448.95

## WATER CALLOUTS

1. Sta. 0+13 - 7'LT. Install 1 - 12" x 12" x 6" stainless steel tapping sleeve, (FL) 1 - 8" gate valve (FLxMJ)
2. 118 LF ± 8" CL 52 DIP
3. Sta. 1+27 - 7'LT. Install 1 - 8" x 6" (MJ) tee 1 - 6" FL x MJ adaptor 1 - 6" (FLxMJ) gate valve w/blocking
- 3a. Sta. 1+27 - 22'RT. Install standard F.H. assembly w/6" gate valve and blocking per M.L.T. std plan 201
4. 42 LF ± 8" CL 52 DIP
5. Sta. 1+74 - 7'LT. Install 1 - 8" x 6" (FL) Tee w/blocking 1 - 8" FL x MJ adaptor 1 - 8" (FL x MJ) gate valve
6. 78 LF ± 8" CL 52 DIP
7. Sta. 2+50 - 7'LT. Install 1 - 8" 45° (MJ) bend w/blocking
8. 47 LF ± 8" CL 52 DIP

9. Sta. 2+95 - 3'LT. Install 1 - 8" x 6" Tee (FL) 1 - 6" (FL x MJ) Gate Valve w/blocking 1 - 8" (FL x MJ) Gate Valve 1 - 8" FL x MJ adaptor

10. 13 LF ± 8" CL 52 DIP
11. Sta. 3+07 - 7'LT. Install 1 - 8" 11 1/4" Bend (MJ) w/blocking
12. 17 LF ± 8" CL 52 DIP
13. Sta. 3+26 - 5'LT. Install 1 - 8" 22 1/2" Bend (MJ) w/blocking
14. 32 LF ± 8" CL 52 DIP
15. 20 LF ± 8" CL 52 DIP
16. 50 LF ± 8" CL 52 DIP
17. 84 LF ± 8" CL 52 DIP (min radius 205')
18. 43 LF ± 6" CL 52 DIP
19. 27 LF ± 6" CL 52 DIP
20. 15 LF ± 6" CL 52 DIP
21. 40 LF ± 6" CL 52 DIP
22. 21 LF ± 6" CL 52 DIP
23. 38 LF ± 6" CL 52 DIP
24. 98 LF ± 8" CL 52 DIP
25. Install 1-8" 90° Bend (MJ) w/blocking
26. 194 LF ± 8" CL 52 DIP
27. Install 2" Blowoff per MLT std plan 206 1 - 8" FLxMJ adaptor 1 - 8" Blind flange w/blocking
28. Sta. 10+36 - 5'LT. Install 1 - 6" 22 1/2" Bend (MJ) w/blocking
29. Sta. 10+66 - 3'LT. Install 1 - 6" 45° (MJ) Bend w/blocking

MOUNTLAKE TERRACE HIGH SCHOOL

MOUNTLAKE TERRACE

**24 HOUR NOTICE**  
REQUIRED PRIOR TO NEED FOR  
INSPECTION. CALL 24 HOUR REQUEST LINE  
775-9894

**CALL 48 HOURS  
BEFORE YOU DIG  
1-800-424-5555**

**CITY OF MOUNTLAKE TERRACE  
APPROVED PLAN**

DATE: 12.1.95

BY: [Signature]

(EXCEPT WHERE NOTED) SUBJECT TO FIELD  
INSPECTION AND COMPLIANCE TO ALL  
APPLICABLE LAWS, CODES, ORDINANCES,  
STANDARDS AND SPECIFICATIONS OF THE  
CITY OF MOUNTLAKE TERRACE, WASHINGTON

**GROUP FOUR, Inc.**  
16030 JUANITA-WOODVILLE WAY NE  
BOTHELL WASHINGTON 98011  
(206) 775-4591 • (206) 362-4244 • FAX (206) 362-3819  
SURVEYING ENGINEERING PLANNING MANAGEMENT

**MELANIE LANE  
SANITARY SEWER AND WATER PLAN**

SHT 8 OF 11

JOB NO: 91-5009