

# APPLICATION

## for SIDE SEWER PERMIT

OUTSIDE ☒ INSIDE ☐ REPAIRS ☐



CARD No. \_\_\_\_\_

EASEMENT No. \_\_\_\_\_

The City of Mountlake Terrace

OWNER ROD PEDERSON CONTRACTOR MIDLAND CONST. (ROGER) PERMIT No. U-10,11-80  
 HOUSE No. 23303,05 E 44<sup>TH</sup> AV. W. STREET 776-5777  
 AVENUE LOT No. \_\_\_\_\_ BLOCK No. \_\_\_\_\_  
 NAME ADD \_\_\_\_\_

JULY 10, 80 : 9:30  
 1<sup>ST</sup> STAGE OF SYSTEM NOTED,  
 NOT COMPLETE OR APPROVED.  
 BUILDINGS NOT STARTED  
 — 12.10.80  
 ROAD CROSSING HAS SETTLED  
 TWICE FOR A TOTAL OF '18"±.  
 SHOULD BE REBUILT.



BACKFILL WORK ORDER ISSUED \_\_\_\_\_ DEPOSIT, \$ \_\_\_\_\_  
 SEWER WORK ORDER ISSUED \_\_\_\_\_  
 Date \_\_\_\_\_ Approved: 12-11-80 NOT COMPLETED, NO CALL  
 DATE \_\_\_\_\_ BY \_\_\_\_\_