




CONTROL ROOM & ROOF FRAMING PLAN.
1/2" = 1'-0"




ELEVATION ~ WEST WALL




ELEVATION ~ NORTH WALL




ROOF DETAIL
E. & W. WALLS




ROOF DETAIL
N. & S. WALLS



DETAIL ~ EXHAUST
FAN SHELF
1" = 1'-0"



DETAIL ~ GENERATOR LOUVER
1" = 1'-0"



DETAIL
ENGINE EXHAUST

PAINTING SCHEDULE

EXTERIOR WOOD: ONE COAT INERTOL PRIMER N° 625 AND TWO COATS INERTOL EXTERIOR TRIM ENAMEL, WHITE.

INTERIOR WOOD: ONE COAT INERTOL PRIMER N° 623 AND TWO COATS GLAMORTEX ENAMEL, WHITE.

MISCELLANEOUS METALS: (PIPES, VALVES, LADDER, ETC.) ONE COAT INERTOL PRIMER N° 626 AND THREE COATS RAMUC UTILITY ENAMEL, LIGHT GRAY #306.

DOOR & FRAME: TWO COATS GLAMORTEX ENAMEL OVER SHOP PRIME COAT, LIGHT GRAY #306.

EQUIPMENT SUCH AS PUMPS & MOTORS NEED NOT BE REPAINTED IF SUPPLIED WITH TOP QUALITY FINISH COATS. ALL SCRATCHES & BLEMISHES TO BE REPAIRED IN SAME COLOR.

ALL SURFACES TO BE CLEANED AND PREPARED FOR A FIRST CLASS JOB.

Scan Name: scans06378.pdf
Scan Date:



CITY OF MOUNTLAKE TERRACE		SCALE 1/2" = 1'-0"
CONTROL HOUSE PLAN, ELEV'S.		DATE SEPT, 1953
MISCELLANEOUS DETAILS		DESIGN KCT
JAMES H. REID & ASSOCIATES		DRAWN KCT
CONSULTING ENGINEERS 324 MAIN ST. EDMONDS, WASHINGTON		CHECKED LHN
SEWERAGE SYSTEM ~ UNIT 2A		FILE NO. 550/2A-09
		SHEET 10 OF 10