

1) 1973 UNIFORM PLUMBING CODE USED FOR FIXTURE
UNIT COUNTS AND SERVICE LINE SIZING.
2) 8" WATER MAIN TO BE DUG ON IRON PIPE
3) 1" MIN. TYPE PIPING ON JOINTS OR EQUAL.
4) USE 1/2" HERSEY MVR-100 METERS FOR BLDGS #
2, 3 & 4, AND 3/4" x 5/8" MVR-30 METER FOR REC. BLDG.
5) FIRE HYDRANTS TO BE CITY OF MOUNT LAKE TERRACE
STANDARD LOW PROFILE HYDRANT.

- 1) 8" SEWER MAIN TO BE ASBESTOS- CONCRETE, PVC PLASTIC OR PORTLAND CONCRETE CEMENT.
- 2) 6" SIDE SEWERS TO BE VITREOUS CLAY, PVC PLASTIC, ASBESTOS- CONCRETE, OR PORTLAND CONCRETE CEMENT.

NOTE: SEWER PIPE SHALL BE CONCRETE ENCASED WHERE COVER IS LESS THAN 30" STA. 2+05 TO STA. 2+60

NOTE = SANITARY SEWER
CROSSING UNDER LAKEVIEW
DRIVE SHALL BE 12"
WRAPPED STEEL
CASING

SHEET

C / 2

Architects Engineers

T.A. JOHNSON ARCHITECT
L.S. BRAUND ENGINEER

LAKE BALLINGER CONDOMINIUMS
SANITARY SEWER AND WATER SYSTEMS PLAN

5-2A