


PROFILE NOTE BOOK 40-0-43 NO.	SURVEYED	BY	DATE
	PLOTTED	DP	
	GRADES CHECKED		
	B. M. & NOTED		
STRUCTURE NOTATIONS CH'K'D			



Footage	SEALED	11a	SEALED
0		First MH N. of 4-1	
123'		1-1.79 1/2" Arterse on Ponding	
124'		MH 4-1	
192'		Ponding STARTS	
200'		Camera Under Water	
205'		Camera Plowing Lubris	
212'		Camera dense out of Water 3" deep	
215'		Camera Underwater	
218'		Camera Lens out of Water 3" deep	
225'		To 2.35 1/2 To 3 P. Pool Water	
216.5'		Joint Bell	
217'		Joint badly misaligned	
219'		Joint	
240'		MH 4-1	

Scan Name: scans06529.pdf
Scan Date:

NW. 1/4 Sec. 32
T27N R4E W4

GOVERNMENT LOT 4

AS GUILT DRAWING

JAMES H. REID & ASSOCIATES CONSULTING ENGINEERS, 324 MAIN ST., EDMONDS, WASH.	DESIGN	DRAWN	CHECKED	DATE	H. SCALE	FILE NO.
	L.H.N.	J.E.M.	L.N.	3-30-59	V. SCALE	5.50/5-2
					1"=10'	SHEET 2 OF 5
CITY OF MOUND LAKE TERRACE SEWERAGE SYSTEM UNIT 5						