

GENERAL NOTES

- SEE PLUMBING FOUNDATION PLANS FOR CONTINUATION OF CW & SS.
- SEE SHEET C8.2 FOR SANITARY SEWER GENERAL NOTES.
- SEE SHEET C8.3 FOR WATER GENERAL NOTES.
- SEE CITY STD. PLAN 209 FOR THRUST BLOCKING, WATERMAIN INSTALLATION, STERILIZATION AND FLUSHING, AND HYDROSTATIC TEST ON SHEET C8.3.
- SEE CITY STD. PLAN 303 FOR SEWER CLEANOUT DETAILS ON SHEET C8.2.
- SEE CITY STD. PLAN 304 FOR PIPE BEDDING FOR SANITARY SEWERS IN TRENCHES ON SHEET C8.2.
- SEE CITY STD. PLAN 305 & 306 FOR MANHOLE TYPE 1-48" & MANHOLE DETAILS ON SHEET C8.2.
- EXIST. FIRE HYDRANTS AND WATER MAINS CALLED OUT TO BE REMOVED SHALL BE DISPOSED OF OFFSITE BY CONTRACTOR.
- PROVIDE 4' MIN COVER ABOVE NEW 6" SS TO GYM.
- CONTRACTOR IS RESPONSIBLE FOR PRESERVATION OF TREES. REFER TO SPECIFICATION SECTION 02100 REGARDING PROTECTION AND REPLACEMENT.
- BACKFILL FOR REMOVED PIPING SHALL BE SELECT FILL TYPE A PER SPECIFICATION SECTION 02222.
- NEW WATER MAIN TO BE IN SERVICE PRIOR TO DEMOLITION OF EXISTING WATER MAIN.
- SEE MECHANICAL PLANS FOR DEMOLITION/REPLACEMENT OF DOMESTIC WATER LINES WITHIN BUILDING FOOTPRINT.
- PROVIDE TEMPORARY BLOCKING OF PLUG TO ALLOW PIPE TO BE PLACED IN SERVICE WHILE CONCRETE BLOCKING ATTAINS DESIGN STRENGTH.
- COORDINATE SHUTOFF OF EXISTING MAIN WITH CITY. 1 SHUTOFF WITH 6 HOUR MAXIMUM DURATION ALLOWED, 10 AM TO 4 PM, OR 2 SHUTOFFS WITH 4 HOUR MAXIMUM DURATION ALLOWED, 10 AM TO 2 PM. AT CONTRACTORS OPTION, USE CUT-IN CONNECTIONS IN LIEU OF WET TAPS SHOWN.
- ONLY CITY PERSONNEL TO TURN WATER SERVICES OFF/ON.
- SANITARY MANHOLE NO. 1 TO BE CONSTRUCTED PRIOR TO STORM DRAIN. NOTIFY ENGINEER OF EXISTING SANITARY SEWER INVERT TO ALLOW CONFIRMATION OF STORM DRAIN ROUTE.
- CONTRACTOR SHALL ADJUST ALL EXISTING UTILITIES TO NEW GRADE WHETHER SHOWN ON THIS PLAN OR NOT.
- WASHING OF PARKING LOT, DRIVEWAYS OR STREET, TO REMOVE CONSTRUCTION RELATED DIRT IS STRICTLY FORBIDDEN AND SUBJECT TO FINES.

SEE ADDITIONAL NOTES BELOW

GENERAL NOTES CONTINUED

- THE CITY'S CONSTRUCTION INSPECTOR IS TO BE PRESENT TO DETERMINE THE EXISTING SIZE OF ALL WATER MAINS.
- REPLACE ALL EXISTING 6 INCH DIA. WATER MAIN, IF ANY, WITHIN THE SCHOOL PROPERTY WITH 8 INCH DIAMETER CLASS 52 DIP.
- EXISTING FIRE HYDRANTS WHICH ARE TO BE REMOVED SHALL BE TRANSPORTED TO THE CITY'S PUBLIC WORKS SHOP. USE REASONABLE CARE TO AVOID DAMAGE DURING REMOVAL AND TRANSPORT.
- REMOVE EXIST. METER, LID, AND TOP COURSE OF BLOCK. BACKFILL W/ SAND AND PAVE OVER W/ MIN 2" A.C. PAVEMENT.
- TAPPING TEE SHALL BE CLOW MJ TYPE.

CALL 48 HOURS BEFORE YOU DIG
1-800-424-5555

NOTE: EXISTING UNDERGROUND FACILITIES HAVE BEEN SHOWN ON THIS DRAWING FOR THE PURPOSE OF ASSISTING THE CONTRACTOR IN LOCATING SAID FACILITIES IN THE FIELD. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CHECKING ACTUAL LOCATIONS IN THE FIELD AND CHECKING WITH APPROPRIATE AGENCIES THAT MAY HAVE UNDERGROUND FACILITIES WITHIN THE PROJECT LIMITS. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR ANY DAMAGE TO UNDERGROUND FACILITIES RESULTING FROM HIS OPERATIONS.

24 HOUR NOTICE REQUIRED PRIOR TO NEED FOR INSPECTION CALL 24 HOUR REQUEST LINE 775-9694

CITY OF MOUNTLAKE TERRACE
APPROVED PLAN

DATE: _____
BY: _____
(EXCEPT WHERE NOTED) SUBJECT TO FIELD INSPECTION AND COMPLIANCE TO ALL APPLICABLE LAWS, CODES, ORDINANCES, STANDARDS AND SPECIFICATIONS OF THE CITY OF MOUNTLAKE TERRACE, WASHINGTON

