


# Pandora "D" Building Sewer

N 1/4



Performed Repair on 6" collapsed Pipe. And Cleared line of rocks and Dirt. This storm line has been Damaged for a considerable amount of Time.

All clean outs have a meter Box installed over them. Per City. The new sewer has 1/8" per ft Drop on the run, or flat the entire length of the sewer.