
















AUTODESK®

NAVISWORKS®


Clash Report

Level 00 IfcColumn vs Level 3 IfcDuctsSegment	Tolerance	Clashes	New	Active	Reviewed	Approved	Resolved	Type	Status
	0.010m	15	15	0	0	0	0	Hard	OK

								Item 1				Item 2			
Image	Clash Name	Status	Distance	Grid Location	Description	Date Found	Clash Point	Item ID	Layer	Item Name	Item Type	Item ID	Layer	Item Name	Item Type
	Clash1	New	-0.270	H-3 : Level 3	Hard	2025/3/23 19:04	x:220.750, y:32.914, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8r	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122510	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash2	New	-0.270	G-3 : Level 3	Hard	2025/3/23 19:04	x:221.844, y:39.117, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8s	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122509	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash3	New	-0.264	C-3 : Level 3	Hard	2025/3/23 19:04	x:226.219, y:63.931, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8o	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122505	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash4	New	-0.250	F-3 : Level 3	Hard	2025/3/23 19:04	x:222.683, y:45.108, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8t	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122508	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash5	New	-0.177	D-3 : Level 3	Hard	2025/3/23 19:04	x:224.894, y:57.767, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8n	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122506	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash6	New	-0.168	E-3 : Level 3	Hard	2025/3/23 19:04	x:224.007, y:51.271, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8m	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122507	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash7	New	-0.143	E-3 : Level 3	Hard	2025/3/23 19:04	x:224.323, y:53.063, z:10.467	Element ID: 18YHwga450Mw4Fy6M5t_8f	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122514	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2TPDduNgz4dfZSUyJz_iu\$	Level 3	Rectangular Duct:Mitered Elbows / Taps:522128	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash8	New	-0.137	D-2 : Level 3	Hard	2025/3/23 19:04	x:219.130, y:58.785, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_B6	00 - Entry Level	UC-Universal Columns-Column:UC254x254x73:122493	IfcColumn: UC-Universal Columns-Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps









	Clash9	New	-0.137	E-2 : Level 3	Hard	2025/3/23 19:04	x:218.313, y:54.381, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_8_	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122501	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash10	New	-0.137	H-2 : Level 3	Hard	2025/3/23 19:04	x:214.703, y:33.722, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_8w	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122497	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash11	New	-0.137	E-2 : Level 3	Hard	2025/3/23 19:04	x:217.997, y:52.588, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_B5	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122494	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash12	New	-0.137	F.1-2 : Level 3	Hard	2025/3/23 19:04	x:216.554, y:44.215, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_8\$	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122500	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash13	New	-0.137	G-2 : Level 3	Hard	2025/3/23 19:04	x:215.797, y:39.925, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_8x	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122496	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash14	New	-0.137	F-2 : Level 3	Hard	2025/3/23 19:04	x:216.891, y:46.129, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_B4	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122495	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps
	Clash15	New	-0.114	C-2 : Level 3	Hard	2025/3/23 19:04	x:220.185, y:64.995, z:9.925	Element ID: 18YHwga450Mw4Fy6M5t_B7	00 - Entry Level	UC-Universal Columns- Column:UC254x254x73:122492	IfcColumn: UC- Universal Columns- Column:UC254x254x73	Element ID: 2dNgTRFFD6AwGL3IYY7qqC3	Level 3	Rectangular Duct:Mitered Elbows / Taps:508056	IfcFlowSegment: Rectangular Duct:Mitered Elbows / Taps











Level 02 IfcSlab vs Level 2 (all MEP elements)										Tolerance	Clashes	New	Active	Reviewed	Approved	Resolved	Type	Status
										0.010m	3	3	0	0	0	0	Hard	OK











								Item 1				Item 2			
Image	Clash Name	Status	Distance	Grid Location	Description	Date Found	Clash Point	Item ID	Layer	Item Name	Item Type	Item ID	Layer	Item Name	Item Type
	Clash1	New	-2.646	H-3 : Level 2	Hard	2025/3/23 19:05	x:218.661, y:33.898, z:7.200	Element ID: 0lwI9V_Zv7bRdf9X_OzkUO	02 - SSL	Concrete - Cast-in- Place Concrete - 28 MPa	Solid	Element ID: 3XrBtx9eX7mQE6EqWHPe\$V	Level 2	Stahlbalkon:Stahlbalkon:577549	IfcBuildingElementProxy: Stahlbalkon:Stahlbalkon
	Clash2	New	-0.010	F.1-1 : Level 3	Hard	2025/3/23 19:05	x:207.315, y:43.833, z:7.500	Element ID: 0lwI9V_Zv7bRdf9X_OzkUO	02 - SSL	Concrete - Cast-in- Place Concrete - 28 MPa	Solid	Element ID: 1a3hXfc3v66e04O19pWdrC	Level 2	Port_687956	IfcDistributionPort







	Clash3	New	-0.010	F.1-1 : Level 3	Hard	2025/3/23 19:05	x:207.342, y:43.822, z:7.500	Element ID: 0lwI9V_Zv7bRdf9X_OzkUO	02 - SSL	Concrete - Cast-in-Place Concrete - 28 MPa	Solid	Element ID: 2asTCmYYn3dx0cpA551rCw	Level 2	Conduit Body - Type L - Aluminum:Standard:687956	Solid
---	--------	-----	--------	-----------------	------	-----------------	------------------------------	------------------------------------	----------	--	-------	------------------------------------	---------	--	-------

Level 01 IfcBeam vs Level 1 IfcDuctSegment	Tolerance	Clashes	New	Active	Reviewed	Approved	Resolved	Type	Status
	0.040m	34	34	0	0	0	0	Hard	OK

								Item 1				Item 2			
Image	Clash Name	Status	Distance	Grid Location	Description	Date Found	Clash Point	Item ID	Layer	Item Name	Item Type	Item ID	Layer	Item Name	Item Type
	Clash1	New	-0.289	F-1.1 : Level 1	Hard	2025/3/23 19:06	x:214.493, y:47.171, z:3.087	Element ID: 1WrzGm1SD2ev45B_OWQ3Eu	01 - SSL	UB-Universal Beams:UB406x178x60:124796	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 2eg27kdA59xxUQ\$qhznMvZ	Level 1	Rectangular Duct:Mitered Elbows / Taps:401681	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash2	New	-0.262	J-3 : Level 1	Hard	2025/3/23 19:06	x:218.937, y:29.799, z:3.313	Element ID: 1WrzGm1SD2ev45B_OWQ3EH	01 - SSL	UB-Universal Beams:UB406x178x60:124757	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 2qAz6Dn6n0wwlFroYBrv4Y	Level 1	Rectangular Duct:Mitered Elbows / Taps:413502	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash3	New	-0.254	F-1.1 : Level 1	Hard	2025/3/23 19:06	x:213.951, y:46.772, z:3.020	Element ID: 1WrzGm1SD2ev45B_OWQ3Fo	01 - SSL	UB-Universal Beams:UB406x178x60:124726	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 2eg27kdA59xxUQ\$qhznL25	Level 1	Rectangular Duct:Mitered Elbows / Taps:401399	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash4	New	-0.248	F-2 : Level 1	Hard	2025/3/23 19:06	x:216.343, y:46.350, z:3.017	Element ID: 1WrzGm1SD2ev45B_OWQ3Fm	01 - SSL	UB-Universal Beams:UB406x178x60:124724	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 1vmPjBt8n8YuZwaHb4XtZ7	Level 1	Rectangular Duct:Mitered Elbows / Taps:408788	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash5	New	-0.225	F.1-1.1 : Level 1	Hard	2025/3/23 19:06	x:213.615, y:44.867, z:3.151	Element ID: 1WrzGm1SD2ev45B_OWQ3D8	01 - SSL	UB-Universal Beams:UB406x178x60:124812	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 2eg27kdA59xxUQ\$qhznL25	Level 1	Rectangular Duct:Mitered Elbows / Taps:401399	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash6	New	-0.215	E-1.1 : Level 1	Hard	2025/3/23 19:06	x:217.386, y:54.411, z:3.239	Element ID: 1WrzGm1SD2ev45B_OWQ3DG	01 - SSL	UB-Universal Beams:UB406x178x60:124820	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 3SXc9zpn99\$hsjl8fXdI9f	Level 1	Rectangular Duct:Mitered Elbows / Taps:399048	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash7	New	-0.212	J-1.1 : Level 1	Hard	2025/3/23 19:06	x:211.047, y:31.198, z:3.163	Element ID: 1WrzGm1SD2ev45B_OWQ3ET	01 - SSL	UB-Universal Beams:UB406x178x60:124761	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 2R94njNd5C6BKWs2D3HqJg	Level 1	Rectangular Duct:Mitered Elbows / Taps:403284	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash8	New	-0.209	F.1-3 : Level 1	Hard	2025/3/23 19:06	x:220.484, y:43.655, z:3.377	Element ID: 1WrzGm1SD2ev45B_OWQ3DC	01 - SSL	UB-Universal Beams:UB406x178x60:124808	IfcBeam: UB-Universal Beams:UB406x178x60	Element ID: 34uG\$PSz90zOoSrf_95JFK	Level 1	Rectangular Duct:Mitered Elbows / Taps:480945	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps

	Clash9	New	-0.208	E-3 : Level 1	Hard	2025/3/23 19:06	x:221.805, y:53.640, z:3.165	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3DI	01 - SSL	UB-Universal Beams:UB406x178x60:124822	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 34uG\$PSz90zOoSrf_95JqG	Level 1	Rectangular Duct:Mitered Elbows / Taps:481397	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash10	New	-0.204	E-1.1 : Level 1	Hard	2025/3/23 19:06	x:215.747, y:54.282, z:3.071	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3E_	01 - SSL	UB-Universal Beams:UB406x178x60:124794	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3yRNaM3XT1Helhad1XHMA5	Level 1	Rectangular Duct:Mitered Elbows / Taps:445070	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash11	New	-0.202	E-2 : Level 1	Hard	2025/3/23 19:06	x:218.208, y:53.029, z:3.124	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ39_	01 - SSL	UB-Universal Beams:UB406x178x60:124602	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0KpRKIKTTAd9UCVtTRVoSm	Level 1	Rectangular Duct:Mitered Elbows / Taps:410170	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash12	New	-0.200	D-1.1 : Level 1	Hard	2025/3/23 19:06	x:217.722, y:58.908, z:3.224	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3Fd	01 - SSL	UB-Universal Beams:UB406x178x60:124707	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3SXc9zpn99\$hsjl8fxdl9f	Level 1	Rectangular Duct:Mitered Elbows / Taps:399048	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash13	New	-0.186	E-2 : Level 1	Hard	2025/3/23 19:06	x:217.520, y:52.547, z:3.085	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3Fj	01 - SSL	UB-Universal Beams:UB406x178x60:124713	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0KpRKIKTTAd9UCVtTRVoSm	Level 1	Rectangular Duct:Mitered Elbows / Taps:410170	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash14	New	-0.165	C-1.1 : Level 1	Hard	2025/3/23 19:06	x:217.907, y:66.579, z:3.071	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3Em	01 - SSL	UB-Universal Beams:UB406x178x60:124788	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3SXc9zpn99\$hsjl8fxdlCj	Level 1	Rectangular Duct:Mitered Elbows / Taps:399282	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash15	New	-0.151	C-1.1 : Level 1	Hard	2025/3/23 19:06	x:218.816, y:65.112, z:3.224	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3FU	01 - SSL	UB-Universal Beams:UB406x178x60:124698	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3SXc9zpn99\$hsjl8fxdl9_	Level 1	Rectangular Duct:Mitered Elbows / Taps:399071	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash16	New	-0.145	J-1.1 : Level 1	Hard	2025/3/23 19:06	x:211.845, y:32.156, z:3.131	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3D0	01 - SSL	UB-Universal Beams:UB406x178x60:124804	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 2R94njNd5C6BKWs2D3HqJY	Level 1	Rectangular Duct:Mitered Elbows / Taps:403292	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash17	New	-0.115	G-1.1 : Level 1	Hard	2025/3/23 19:06	x:213.286, y:40.328, z:3.132	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3D6	01 - SSL	UB-Universal Beams:UB406x178x60:124802	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3mmn	Level 1	Cable Tray with Fittings:Ladder Cable Tray:797605	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray
	Clash18	New	-0.100	G-2 : Level 1	Hard	2025/3/23 19:06	x:216.167, y:41.453, z:3.132	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ384	01 - SSL	UB-Universal Beams:UB406x178x60:124608	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3mnB	Level 1	Cable Tray with Fittings:Ladder Cable Tray:797663	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray

	Clash19	New	-0.100	G-2 : Level 1	Hard	2025/3/23 19:06	x:215.715, y:38.887, z:3.132	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ386	01 - SSL	UB-Universal Beams:UB406x178x60:124610	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3mm\$	Level 1	Cable Tray with Fittings:Ladder Cable Tray:797611	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray
	Clash20	New	-0.100	H-2 : Level 1	Hard	2025/3/23 19:06	x:214.729, y:33.297, z:3.132	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ380	01 - SSL	UB-Universal Beams:UB406x178x60:124612	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3maK	Level 1	Cable Tray with Fittings:Ladder Cable Tray:798336	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray
	Clash21	New	-0.100	H-3 : Level 1	Hard	2025/3/23 19:06	x:220.393, y:31.532, z:3.157	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ38U	01 - SSL	UB-Universal Beams:UB406x178x60:124634	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 2qAz6Dn6n0wwlFroYBruyl	Level 1	Rectangular Duct:Mitered Elbows / Taps:413966	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash22	New	-0.092	H-2 : Level 1	Hard	2025/3/23 19:06	x:214.523, y:32.485, z:3.006	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ380	01 - SSL	UB-Universal Beams:UB406x178x60:124612	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0Yh6O0Xlz9Uh\$rYU1Y8Ket	Level 1	Rectangular Duct:Mitered Elbows / Taps:411033	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash23	New	-0.092	F-2 : Level 1	Hard	2025/3/23 19:06	x:217.240, y:47.742, z:3.006	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ39u	01 - SSL	UB-Universal Beams:UB406x178x60:124604	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 1vmPjBt8n8YuZwaHb4XtXb	Level 1	Rectangular Duct:Mitered Elbows / Taps:408694	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash24	New	-0.092	G-2 : Level 1	Hard	2025/3/23 19:06	x:215.500, y:38.072, z:3.006	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ386	01 - SSL	UB-Universal Beams:UB406x178x60:124610	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0Yh6O0Xlz9Uh\$rYU1Y8Kgr	Level 1	Rectangular Duct:Mitered Elbows / Taps:410907	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash25	New	-0.082	H-1.1 : Level 1	Hard	2025/3/23 19:06	x:212.145, y:33.902, z:3.077	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3D0	01 - SSL	UB-Universal Beams:UB406x178x60:124804	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 2R94njNd5C6BKWs2D3HqPx	Level 1	Rectangular Duct:Mitered Elbows / Taps:402885	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash26	New	-0.082	G-1.1 : Level 1	Hard	2025/3/23 19:06	x:212.814, y:37.693, z:3.237	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3D6	01 - SSL	UB-Universal Beams:UB406x178x60:124802	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 2R94njNd5C6BKWs2D3HqPx	Level 1	Rectangular Duct:Mitered Elbows / Taps:402885	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash27	New	-0.070	E-2 : Level 1	Hard	2025/3/23 19:06	x:217.202, y:52.604, z:3.296	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3Fj	01 - SSL	UB-Universal Beams:UB406x178x60:124713	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0KpRKIKTTAd9UCVtTRVoOs	Level 1	Rectangular Duct:Mitered Elbows / Taps:410428	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash28	New	-0.054	J-1.1 : Level 1	Hard	2025/3/23 19:06	x:212.191, y:30.989, z:3.315	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3EJ	01 - SSL	UB-Universal Beams:UB406x178x60:124759	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0Yh6O0Xlz9Uh\$rYU1Y8Kfz	Level 1	Rectangular Duct:Mitered Elbows / Taps:411091	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps

	Clash29	New	-0.051	E-3 : Level 1	Hard	2025/3/23 19:06	x:223.708, y:53.222, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3DI	01 - SSL	UB-Universal Beams:UB406x178x60:124822	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3mLkgTZxf3Je3EHhJV2LTH	Level 1	Rectangular Duct:Mitered Elbows / Taps:520209	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash30	New	-0.051	F.1-3 : Level 1	Hard	2025/3/23 19:06	x:221.961, y:43.313, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3DC	01 - SSL	UB-Universal Beams:UB406x178x60:124808	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3mLkgTZxf3Je3EHhJV2LTH	Level 1	Rectangular Duct:Mitered Elbows / Taps:520209	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash31	New	-0.048	F.1-2 : Level 1	Hard	2025/3/23 19:06	x:216.862, y:44.247, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3DC	01 - SSL	UB-Universal Beams:UB406x178x60:124808	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3nR0	Level 1	Cable Tray with Fittings:Ladder Cable Tray:799060	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray
	Clash32	New	-0.048	G-2 : Level 1	Hard	2025/3/23 19:06	x:215.645, y:38.279, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ386	01 - SSL	UB-Universal Beams:UB406x178x60:124610	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0vZ9ZjUyH4TeSwLEAj3mhD	Level 1	Cable Tray with Fittings:Ladder Cable Tray:798041	IfcFlowSegmer Cable Tray with Fittings:Ladder Cable Tray
	Clash33	New	-0.043	C-3 : Level 1	Hard	2025/3/23 19:06	x:225.580, y:63.836, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ3FS	01 - SSL	UB-Universal Beams:UB406x178x60:124696	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 3mLkgTZxf3Je3EHhJV2LTH	Level 1	Rectangular Duct:Mitered Elbows / Taps:520209	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps
	Clash34	New	-0.042	E-2 : Level 1	Hard	2025/3/23 19:06	x:217.981, y:52.277, z:2.994	<i>Element ID:</i> 1WrzGm1SD2ev45B_OWQ39u	01 - SSL	UB-Universal Beams:UB406x178x60:124604	IfcBeam: UB-Universal Beams:UB406x178x60	<i>Element ID:</i> 0KpRKIKTTAd9UCVtTRVoSm	Level 1	Rectangular Duct:Mitered Elbows / Taps:410170	IfcFlowSegmer Rectangular Duct:Mitered Elbows / Taps