

HPL ELECTRIC & POWER LTD.

ROUTINE TEST REPORT

1 Phase,2 Wire,10-60A,3200 impulses per kWh,240 Voltage OF Class 1

REFERENCE STANDARD DETAILS	
MODEL	ELMA 2310A
SR NO.	1098020291
CLASS	0.05
CAL DUE DATE	30-Aug-2025

METER NO.	ME9728617
REF. STND.	IS:16444 (Part 1)
MODEL	SMART METER

ELECTRICAL INSPECTION

High Voltage Test: 4 KV	Pass	Starting Current test(at 0.4% of Ib UPF)	Pass
Insulation Resistance test	Pass	No Load Condition test(at 115% of V ref.)	Pass

TEST OF LIMITS OF ERROR - ALL ERRORS ARE IN %

UPF				0.50 PF (LAG)				0.80 PF (LEAD)			
5% Ib	10% Ib	Ib	I _{max}	10% Ib	20% Ib	Ib	I _{max}	10% Ib	20% Ib	Ib	I _{max}
-0.22	-0.14	-0.07	-0.05	0.09	0.14	0.06	0.16	-0.11	-0.04	0.00	0.00

Date :21-Mar-2025

Note: This is a computer generated document and does not require any signature