

Affected-batch safety brief

Honeywell Lighting Controls - report 2606-0168

Controlled sandbox fixture from the archived GOV.UK report; not an official PDF.

Models: CDW4U1UL and CDW6U1UL

Affected PCB batch: WK 28 YR 25 (July 2025)

Hazard summary

No electric shock risk has been identified for affected batches.

Official report: specific batches recalled by Honeywell Lighting Controls.

Customer communication requires batch verification and human review.

Factual source: GOV.UK report 2606-0168, archived 2026-07-16

<https://www.gov.uk/product-safety-alerts-reports-recalls/product-recall-honeywell-lighting-controls-connect-ultralite-cdw4u1ul-and-cdw6u1ul-2606-0168>