DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: ACMV Transformer Termination Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers the terminations within the PCS MV Cabinet.		
Attachments			

General Inspection

1.1 Verify the compartments are clean and free from any foreign debris.	**Pass / Fail / N/A**
1.2 Verify tape & all temporary labeling is removed.	**Pass / Fail / N/A**

Transformer Terminations

2.1 Verify the cable length is correct.	**Pass / Fail / N/A**
2.2 Verify the termination kit is in good condition and complete.	**Pass / Fail / N/A**
2.3 Verify the installer is certified to use the MV terminations to be installed.	**Pass / Fail / N/A**
2.4 Verify the MV cable is correctly prepared for the termination to be installed.	**Pass / Fail / N/A**
2.5 Verify the cut backs are correct per kit instructions.	**Pass / Fail / N/A**
2.6 Verify the concentric grounds are managed.	**Pass / Fail / N/A**
2.7 Verify the mastic is correctly applied.	**Pass / Fail / N/A**
2.8 Verify the shield and semiconductor cut back is correct.	**Pass / Fail / N/A**
2.9 Verify the semiconductor is clean and chamfered correctly per the kit instructions.	**Pass / Fail / N/A**
2.10 Verify the cable adapter is installed correctly.	**Pass / Fail / N/A**
2.11 Verify the shear bolt lug is installed correctly.	**Pass / Fail / N/A**
2.12 Verify the dead end elbow or T-body is installed correctly.	**Pass / Fail / N/A**

2.13 Verify the dead end elbow or T-body is landed correctly to the transformer and is torqued, and clearly marked. Details: Dimensions in Details:	**Pass** / **Fail** / **N/A**
2.14 Verify the grounding drains are routed and twisted to tie into the ground crimps correctly.	**Pass** / **Fail** / **N/A**
2.15 Verify the drain is tied to the test point on the boot correctly.	**Pass** / **Fail** / **N/A**
2.16 Verify the grounds are terminated correctly.	**Pass** / **Fail** / **N/A**
2.17 Verify the cabinets are resealed, thwarting any entry points for wildlife.	**Pass** / **Fail** / **N/A**
2.18 Verify the ACMV cables are clean.	**Pass** / **Fail** / **N/A**
2.19 Verify the cable sheath is free of any damages.	**Pass** / **Fail** / **N/A**
2.20 Verify the permanent labels are installed.	**Pass** / **Fail** / **N/A**
2.21 Verify the label designation is correct.	**Pass** / **Fail** / **N/A**
2.22 Verify the phases are properly identified.	**Pass** / **Fail** / **N/A**
2.23 Verify the cables are routed to alleviate any stress to the terminations.	**Pass** / **Fail** / **N/A**
2.24 Verify the cabinets are clean and free of any/all foreign debris.	**Pass** / **Fail** / **N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: CAB System Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of the CAB system.		
Attachments			

General Inspection

1.1 Verify the JSA covers all tasks required, clear instructions have been provided and safety measures are in place. — **Pass / Fail / N/A**

1.2 Verify CAB configuration is as specified for the aisle/array — **Pass / Fail / N/A**

Torque Verification

2.1 Verify that L-bracket plates have been tightened evenly and correctly. — **Pass / Fail / N/A**

2.2 Verify that the L- Brackets are free from any and all damage. — **Pass / Fail / N/A**

2.3 Verify Mid-pier mounting bolt torque value is as specified. — **Pass / Fail / N/A**
Details: Dimensions in Details:

2.4 Verify retainer plates torque values are as specified. — **Pass / Fail / N/A**
Details: Dimensions in Details:

2.5 Verify End-pier bolt torque value is as specified. — **Pass / Fail / N/A**
Details: Dimensions in Details:

Visual Inspection

3.1 Verify the CAB height is within tolerance. — **Pass / Fail / N/A**
Details: Dimensions in Details:

3.2 Verify maximum span between CAB hangers is as specified — **Pass / Fail / N/A**
Details: Dimensions in Details:

3.3 Verify the ground conductor is installed as specified. — **Pass / Fail / N/A**

3.4 Verify the messenger cable spacing from module edges are per the drawings. — **Pass / Fail / N/A**
Details: Dimensions in Details:

3.5 Verify that the harnesses and wire assemblies are free of kinks and jacket damage. — **Pass / Fail / N/A**

3.6 Verify the messenger cable is secured to end-post grounding clip, the ground is wire brushed ensuring a bond.	**Pass / Fail / N/A**
3.7 Verify the adjacent end-piers are connected by grounding wire.	**Pass / Fail / N/A**
3.8 Verify the end-pier horizontal spacing from near-intersecting cab lines is per the drawings.	**Pass / Fail / N/A**
3.9 Verify the cables are managed in cab hanger lobes per the drawings.	**Pass / Fail / N/A**
3.10 Verify the quantity of wires do not exceed the CAB hanger capacity.	**Pass / Fail / N/A**
3.11 Verify the DC feeder circuits are the correct size and the jackets are free from any/all damage.	**Pass / Fail / N/A**
3.12 Verify the DC homerun circuits are the correct size and the jackets are free from any/all damage.	**Pass / Fail / N/A**
3.13 Verify the bend radius of the cable is not compromised.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: DC Cable Trenching Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers DC trenching operations, cable installation, and backfill.		
Attachments			

General

1.1 Verify the permit has been approved prior to the execution of the work.	**Pass / Fail / N/A**
1.2 Verify the safety measures are in place.	**Pass / Fail / N/A**
1.3 Verify the correct trench configuration.	**Pass / Fail / N/A**

DC Trenching Inspection

2.1 Verify the trench is cut to the proper depth as specified in the drawings. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.2 Verify the trench is the proper width per the number of circuits in it. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.3 Verify correct number of DC cables are in the trench.	**Pass / Fail / N/A**
2.4 Verify the spacing between DC cables in conduits is correct. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.5 Verify the trench ground is installed.	**Pass / Fail / N/A**
2.6 Verify the trench bedding is the acceptable thickness and correct material. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.7 Verify the trench is free of 3/8" greater material.	**Pass / Fail / N/A**
2.8 Verify the trench is free of any foreign material and trash.	**Pass / Fail / N/A**
2.9 Verify the DC cables are spaced correctly from the sides of the trench walls. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.10 Verify the bend radius of the cable has not been exceeded anywhere in the trench layout.	**Pass / Fail / N/A**

2.11 Verify the trench is backfilled per specifications. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.12 Verify lifts were placed no larger than as specified in the drawings/electrical SOW. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.13 Verify warning/marker tape is installed at the correct depth.	**Pass / Fail / N/A**
2.14 Verify compaction tests have passed for all areas tested in the trench run. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.15 Verify the compaction tests have been submitted to DEPCOM.	**Pass / Fail / N/A**

AC/DC Crossing

3.1 Verify the correct spacing requirements are adhered to between ACMV and DC cable trenches.	**Pass / Fail / N/A**
3.2 Verify the DC cables installed in conduits or split-duct.	**Pass / Fail / N/A**
3.3 Verify the DC cables installed at proper depth. Details: Dimensions in Details:	**Pass / Fail / N/A**
3.4 Verify the burial tape installed between AC and DC cables.	**Pass / Fail / N/A**

Transition Rack Inspection

4.1 Verify that a ground conductor has been installed in each conduit	**Pass / Fail / N/A**
4.2 Verify the correct separation between AC motor power/comms and DC feeders is per design.	**Pass / Fail / N/A**
4.3 Verify transition rack location is as specified.	**Pass / Fail / N/A**
4.4 Verify that the transition rack and conduits are plumb.	**Pass / Fail / N/A**
4.5 Verify that conduit cut edges are reamed as not to damage cable.	**Pass / Fail / N/A**
4.6 Verify bell ends have been installed.	**Pass / Fail / N/A**
4.7 Verify conduit embedment is as specified.	**Pass / Fail / N/A**
4.8 Verify the conduits are sealed on both ends.	**Pass / Fail / N/A**
4.9 Verify that the cable spacing is maintained up into the conduit.	**Pass / Fail / N/A**
4.10 Verify that cables are correctly supported moving into the conduit.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: DC Inverter Terminations Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the terminations of the DC collection system in the interior of the inverters.		
Attachments			

Inspection

1.1 Verify the cable sheath is free of any damages.	**Pass / Fail / N/A**
1.2 Verify the permanent labels are installed.	**Pass / Fail / N/A**
1.3 Verify the label designation is correct.	**Pass / Fail / N/A**
1.4 Verify the correct lugs installed and crimped.	**Pass / Fail / N/A**
1.5 Verify the DC ground wire is managed, maintained, neat, and correctly terminated.	**Pass / Fail / N/A**
1.6 Verify all the lugs are landed, correctly installed, torqued, and clearly marked. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.7 Verify the termination hardware is correct.	**Pass / Fail / N/A**
1.8 Verify the DC conduit wells are installed per design and installation manuals and will naturally drain any water.	**Pass / Fail / N/A**
1.9 Verify the conduit rough cut length above finished pad is at the specified distance above grade.	**Pass / Fail / N/A**
1.10 Verify temporary labeling on the cables entering the conduit window have been removed.	**Pass / Fail / N/A**
1.11 Verify the interior of the cabinets is clean and free of any foreign debris.	**Pass / Fail / N/A**
1.12 Verify the cabinets are resealed, thwarting any entry points for wildlife.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Electrical Combiner Box Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of electrical components, landing of cables, terminations, and other items in the combiner box.		
Attachments			

Inspection

1.1 Verify all fuse holders are open with no fuses installed.	**Pass / Fail / N/A**
1.2 Verify that all string wires are secure.	**Pass / Fail / N/A**
1.3 Verify the correct lugs are used with the correct dye.	**Pass / Fail / N/A**
1.4 Verify the DC Feeders are landed and torqued to the required tension. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.5 Verify all exterior grounds are installed, torqued, marked, and crimped per design.	**Pass / Fail / N/A**
1.6 Verify the DC feeders are the correct size.	**Pass / Fail / N/A**
1.7 Verify the cord grips for DC feeders are tight.	**Pass / Fail / N/A**
1.8 Verify all strings/DC feeders are dressed in a neat and professional manner.	**Pass / Fail / N/A**
1.9 Verify the correct permanent labels on the box are installed.	**Pass / Fail / N/A**
1.10 Verify that the hardware installed is correct.	**Pass / Fail / N/A**
1.11 Verify the enclosure interior is clean and free of debris.	**Pass / Fail / N/A**
1.12 Verify the door is secured and locked.	**Pass / Fail / N/A**
1.13 Verify the disconnect is open with lock out/tag out.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Fence Grounding Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers the installation of the project's fence grounding system.		
Attachments			

Inspection

1.1 Verify the correct wire gage of copper ground wire is used per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.2 Verify the permanent fence is properly spaced away from any overhead powerlines and are the correct lengths. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.3 Verify the ground wire is installed at the correct depth per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.4 Verify proper installation of insulation panels.	**Pass / Fail / N/A**
1.5 Verify the proper grounding equipment is installed per design.	**Pass / Fail / N/A**
1.6 Verify the copper clad ground rods are the correct length and are correctly installed per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.7 Verify the ground wire is properly installed at the proper distances from the gates. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.8 Verify the post grounding connector and fence fabric ground clamps are at each point meeting the ground wire at grade.	**Pass / Fail / N/A**
1.9 Verify the use of a fabric ground clamp is 2 to 3 feet on center, with a minimum of 3 total.	**Pass / Fail / N/A**
1.10 Verify at each fence grounding location, the use of a fabric ground clamp at the tension wire.	**Pass / Fail / N/A**
1.11 Verify at each fence grounding location, the use of a fabric ground clamp at the top rail.	**Pass / Fail / N/A**
1.12 Verify the use of post grounding connectors at each crossbar are installed correctly per design.	**Pass / Fail / N/A**

1.13 Verify all irreversible ground connectors are fully compressed.	**Pass / Fail / N/A**
1.14 Verify the ground grid is installed correctly per design at all gate locations.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Generation Collection Metering Switchgear Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of the metering switchgear.		
Attachments			

Inspection

1.1 Verify the switchgear is installed per installation manual and drawings.	**Pass / Fail / N/A**
1.2 Verify the 3rd party equipment is calibrated and acceptable for use, and are testing with the current IEEE certifications.	**Pass / Fail / N/A**
1.3 Verify the GSMS is not lifted from the bushings at any time during lift.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Generation Sectionalizing Cabinet Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installations of the sectionalizing cabinet.		
Attachments			

Inspection

1.1 Verify the ground ring is installed 3’ from the cabinet per design.	**Pass / Fail / N/A**
1.2 Verify the #2/0 AWG ground is at least 18” below grade.	**Pass / Fail / N/A**
1.3 Verify ¾” Diameter X 10’ long copper clad ground rods are installed per design.	**Pass / Fail / N/A**
1.4 Verify that the connections follow the configurations listed are per design.	**Pass / Fail / N/A**
1.5 Verify at least the corner of the ground ring is used as a grounding test well. Ensure the other three corners are ground rods.	**Pass / Fail / N/A**
1.6 Verify the grounding test well has 6” of clean sand at the bottom.	**Pass / Fail / N/A**
1.7 Verify the irreversible compression ground connection from ground ring to cabinet is installed correctly per design.	**Pass / Fail / N/A**
1.8 Verify the elbow sleeve present with PVC SCH 40 6” x 48” radius is installed per design.	**Pass / Fail / N/A**
1.9 Verify all conduits have end bells installed correctly.	**Pass / Fail / N/A**
1.10 Verify all components are free of damage.	**Pass / Fail / N/A**
1.11 Verify the cold shrink to the rejacketing is installed correctly per design.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: MC4 Connector Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers the installation of MC4 connectors on the string harnesses for the DC Collection System.		
Attachments			

Inspection

1.1 Verify the installer is certified by the manufacturer, and the certificate is on file.	**Pass / Fail / N/A**
1.2 Verify the PV-connectors are isolated from the power supply while being assembled or disassembled.	**Pass / Fail / N/A**
1.3 Verify the proper tools to be used and are in working condition as stated in assembly instructions, and are being used properly.	**Pass / Fail / N/A**
1.4 Verify the cable has been prepared and stripped per the manufacturer's recommendations.	**Pass / Fail / N/A**
1.5 Verify the solid contacts are crimped correctly per the manufacturer's specifications	**Pass / Fail / N/A**
1.6 Verify the connectors have been assembled correctly per manufacturer's recommendations.	**Pass / Fail / N/A**
1.7 Verify that the Staubli specific wrench tool and spanner are used to tighten the gland nut to the required torque as per the installation manual.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Mechanical Combiner Box Installation Inspection

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the mechanical install of the combiner box. It does not include cable terminations or electrical landing of cables.		
Attachments			

Combiner Box - Mechanical

1.1 Verify the combiner box is mounted per design, secure and tight. **Pass / Fail / N/A**

1.2 Verify combiner box is plumb and level. **Pass / Fail / N/A**

1.3 Verify the combiner box bottom ground clearance to grade is correct. **Pass / Fail / N/A**
Details: Dimensions in Details:

1.4 Verify the enclosure interior is clean and free of debris. **Pass / Fail / N/A**

1.5 Verify that torque marks are correct and present. **Pass / Fail / N/A**
Details: Dimensions in Details:

1.6 Verify that the hardware installed is correct. **Pass / Fail / N/A**

1.7 Verify the door is secured and locked. **Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: MET Station, Pyranometer, Weather Sensor, Soiling System, and DAS Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of the MET Station, Pyranometer, Weather Sensor, Soiling System, and DAS systems.		
Attachments			

Enclosure Inspection

1.1 Verify the enclosures are secure to the post, and devices are secured to the mast.	**Pass / Fail / N/A**
1.2 Verify the enclosures are installed plumb and level.	**Pass / Fail / N/A**
1.3 Verify the inside of the enclosures are dust and moisture free.	**Pass / Fail / N/A**
1.4 Verify the remote weather station and UPS are installed at correct height and locations.	**Pass / Fail / N/A**
1.5 Verify all cables and conduits are secured and in a neat, workmanlike manner, no pinches or binds are present per design.	**Pass / Fail / N/A**
1.6 Verify all sensor, communication, and power cables are labeled properly per design and manufacturer specifications.	**Pass / Fail / N/A**
1.7 Verify the POA sensors are installed in the correct locations per design.	**Pass / Fail / N/A**
1.8 Verify the post is grounded with #2/0 AWG. Ground connection is installed correctly, torqued, and clearly marked.	**Pass / Fail / N/A**
1.9 Verify all components are free of damage.	**Pass / Fail / N/A**
1.10 Verify power cables are properly supported and secured.	**Pass / Fail / N/A**
1.11 Verify all permanent ID labels are correct and applied.	**Pass / Fail / N/A**
1.12 Verify the MET station cabinet door is not racked or binding, and the latch/clasp works.	**Pass / Fail / N/A**
1.13 Verify the installation of SCADA components are per design.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: MVAC/LVAC Trench Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the trenching operations of MV/LV trenches and installation of the cables.		
Attachments			

Inspection

1.1 Verify the requirements of the approved permit are being adhered to and executed throughout installation.	**Pass / Fail / N/A**
1.2 Verify the correct trench configuration.	**Pass / Fail / N/A**
1.3 Verify the trench is cut to the proper depth as specified per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.4 Verify the trench is the proper width for the cables. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.5 Verify the trench bedding is the acceptable thickness and correct material per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.6 Verify the ACMV/LVAC cables installed at the proper depth.	**Pass / Fail / N/A**
1.7 Verify the trench is free of 3/8" greater material.	**Pass / Fail / N/A**
1.8 Verify the trench is free of any foreign material and trash.	**Pass / Fail / N/A**
1.9 Verify the proper spacing distance between parallel runs. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.10 Verify the ACMV cable is spaced correctly from the sides of the trench walls. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.11 Verify all 3 phases are present and identified with phase tape.	**Pass / Fail / N/A**
1.12 Verify the ACMV cables are tri-plexed.	**Pass / Fail / N/A**
1.13 Verify the bend radius of the cable has not been exceeded anywhere in the trench layout per design.	**Pass / Fail / N/A**

1.14 Verify the correct spacing requirements are adhered to between fiber optic cables and MV cables. **Pass** / **Fail** / **N/A**
Details: Dimensions in Details:

1.15 Verify the trench ground is installed. **Pass** / **Fail** / **N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: PCS Auxiliary Power Rack Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of the auxiliary rack at the PCS.		
Attachments			

Inspection

1.1 Verify the concrete piers are a minimum of 4' deep and the bottom of the hole is free of any foreign debris.	**Pass / Fail / N/A**
1.2 Verify the 3" pipe posts are aligned with the PCS pad.	**Pass / Fail / N/A**
1.3 Verify the pipe is set 3” from bottom of the concrete pier for concrete cover.	**Pass / Fail / N/A**
1.4 Verify the posts are plumb.	**Pass / Fail / N/A**
1.5 Verify the posts are capped.	**Pass / Fail / N/A**
1.6 Verify all PVC conduits are the correct size per design.	**Pass / Fail / N/A**
1.7 Verify there are no loose components, and all clamps and hardware are secured.	**Pass / Fail / N/A**
1.8 Verify all cabinets and enclosures secured neatly to rack, in a neat workman like manner to prevent water ingress.	**Pass / Fail / N/A**
1.9 Verify the 120V power conduit is installed correctly with the correct amount of circuits per design.	**Pass / Fail / N/A**
1.10 Verify the communications conduit is installed correctly per design.	**Pass / Fail / N/A**
1.11 Verify the grounding conduit is installed correctly per design.	**Pass / Fail / N/A**
1.12 Verify the conduit ends are chamfered to eliminate sharp edges at ends and transitions between the correct conduits.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: PCS Auxiliary Power Rack Terminations Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the terminations and conditions within the electrical enclosures on the auxiliary rack.		
Attachments			

Inspection

1.1 Verify tape & all temporary labeling is removed.	**Pass / Fail / N/A**
1.2 Verify the correct power and communication cables are installed.	**Pass / Fail / N/A**
1.3 Verify the cabinets are cleaned & sealed.	**Pass / Fail / N/A**
1.4 Verify the fiber optic cables are properly terminated.	**Pass / Fail / N/A**
1.5 Verify the correct cable schedule.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: PCS Conduit Rough-In Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the process of roughing in the PCS conduits and all related underground items.		
Attachments			

General Inspection

1.1 Verify the conduits are well supported and secured to a rigid structure.	**Pass / Fail / N/A**
1.2 Verify both ends of conduits are labeled per design.	**Pass / Fail / N/A**
1.3 All inspections of electrical underground (ex. grounding) have passed before backfill, if/where applicable.	**Pass / Fail / N/A**
1.4 Verify backfill compaction is met, tested, and report has been submitted to DEPCOM project team per approved formatting noted in operating plans or by project team.	**Pass / Fail / N/A**
1.5 Verify all irreversible compression ground taps are fully compressed.	**Pass / Fail / N/A**
1.6 Verify the copper clad ground rod is ¾" dia. X 10' long and part number is per design.	**Pass / Fail / N/A**
1.7 Verify the irreversible compression ground rod connector matches the part number per design.	**Pass / Fail / N/A**
1.8 Verify the irreversible compression ground rod connectors are fully compressed.	**Pass / Fail / N/A**
1.9 Verify the grounding test well matches the part number per design.	**Pass / Fail / N/A**
1.10 Verify the bottom of the grounding test well is 18" below grade and the well cover is flush with the grade.	**Pass / Fail / N/A**
1.11 Verify the ground test well mechanical ground rod connector matches the part number per design.	**Pass / Fail / N/A**
1.12 Verify the ground test well mechanical ground rod connector is correctly torqued, marked, and accessible. Details: Dimensions in Details:	**Pass / Fail / N/A**

DC Feeder Conduit Installation

2.1 Verify the correct conduit sizes and conduit quantities are installed through their respective conduit windows.	**Pass / Fail / N/A**

2.2 Verify the correct cable sizes and cable quantities are pulled through their respective conduits.	**Pass / Fail / N/A**
2.3 Verify the installed DC feeder conduit schedule matches conduit legend per design.	**Pass / Fail / N/A**
2.4 Verify all conduits have bell ends properly installed on both conduit ends, and the conduits ends have been cleanly and correctly chamfered.	**Pass / Fail / N/A**
2.5 Verify the conduits passing through a gland plate have the appropriate male terminal adapter and bell ends are installed on the underground end.	**Pass / Fail / N/A**
2.6 Verify the DC compartment/entry window quantities (including ground) are current and available.	**Pass / Fail / N/A**
2.7 Verify the conduits are orientated and configured correctly per design.	**Pass / Fail / N/A**
2.8 Verify the conduit sweeps extend past the skid's foundation and ground ring at the specified distance per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.9 Verify the DC conduit wells are installed per design and installation manuals and will naturally drain any water.	**Pass / Fail / N/A**
2.10 Verify temporary labeling on the cables entering the conduit window have been installed.	**Pass / Fail / N/A**

LV/MVAC Conduit Installation

3.1 Verify the correct conduit sizes and conduit quantities are installed through their respective conduit windows.	**Pass / Fail / N/A**
3.2 Verify the correct cable sizes and cable quantities are pulled through their respective conduits.	**Pass / Fail / N/A**
3.3 Verify the installed ACMV feeder conduit schedule matches conduit legend per design.	**Pass / Fail / N/A**
3.4 Verify all conduits have bell ends properly installed on both conduit ends, and the conduits ends have been cleanly and correctly chamfered.	**Pass / Fail / N/A**
3.5 Verify the conduits passing through a gland plate have the appropriate male terminal adapter and bell ends are installed on the underground end.	**Pass / Fail / N/A**
3.6 Verify the AC compartment/entry window quantities (including ground) are current and available.	**Pass / Fail / N/A**
3.7 Verify the conduits are orientated and configured correctly per design.	**Pass / Fail / N/A**
3.8 Verify the conduit elbows specified radius are per design.	**Pass / Fail / N/A**

3.9 Verify the conduit sweeps extend past the skid's foundation and ground ring at the specified distance per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
3.10 Verify the AC conduit wells are installed per design and installation manuals and will naturally drain any water.	**Pass / Fail / N/A**
3.11 Conduit rough cut length above finished pad is at the specified distance above grade.	**Pass / Fail / N/A**
3.12 Verify temporary labeling on the cables entering the conduit window have been installed.	**Pass / Fail / N/A**

PCS Ground Conduit & Equipment Installation

4.1 Verify the correct conduit sizes and conduit quantities are installed through their respective conduit windows.	**Pass / Fail / N/A**
4.2 Verify the correct cable sizes and cable quantities are pulled through their respective conduits.	**Pass / Fail / N/A**
4.3 Verify the installed skid ground conduit schedule matches conduit legend per design.	**Pass / Fail / N/A**
4.4 Verify all conduits have bell ends properly installed on both conduit ends, and the conduits ends have been cleanly and correctly chamfered.	**Pass / Fail / N/A**
4.5 Verify the conduits passing through a gland plate have the appropriate male terminal adapter and bell ends are installed on the underground end.	**Pass / Fail / N/A**
4.6 Verify there are at least two (2) PCS skid ground conduits as per design.	**Pass / Fail / N/A**
4.7 Verify the PCS skid ground conduits are located near the opposite corners with adequate distance from the edge of pad, and near the termination point per designs.	**Pass / Fail / N/A**
4.8 Verify the PCS skid ground conductor has not been run along the external surface of the foundation.	**Pass / Fail / N/A**
4.9 Verify the conduits are orientated and configured correctly per design.	**Pass / Fail / N/A**
4.10 Verify the conduit elbows specified radius are per design.	**Pass / Fail / N/A**
4.11 Verify the conduit wells are installed per design and installation manuals and will naturally drain any water.	**Pass / Fail / N/A**
4.12 Conduit rough cut length above finished pad is at the specified distance above grade.	**Pass / Fail / N/A**
4.13 Verify temporary labeling on the cables entering the conduit window have been installed.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: PCS Skid Grounding Terminations Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the grounding terminations to the frame of the PCS.		
Attachments			

Inspection

1.1 Verify the compartments are clean and free from any foreign debris.	**Pass / Fail / N/A**
1.2 Verify tape & all temporary labeling is removed.	**Pass / Fail / N/A**
1.3 Verify the correct quantity of grounds are installed.	**Pass / Fail / N/A**
1.4 Verify the grounds are terminated correctly.	**Pass / Fail / N/A**
1.5 Verify the wire management is correct per design.	**Pass / Fail / N/A**
1.6 Verify the correct termination hardware combination.	**Pass / Fail / N/A**
1.7 Verify the grounding lugs are correctly installed, torqued and clearly marked. Details: Dimensions in Details:	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: String Inverter Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection report covers the installation of the string inverters.		
Attachments			

String Inverter Install - Mechanical

1.1 Verify the spacing between inverters are per design.	**Pass / Fail / N/A**
1.2 Verify the top of the inverters align with top of ACCP.	**Pass / Fail / N/A**
1.3 Verify the top of the inverters are at the correct elevation above finished grade.	**Pass / Fail / N/A**
1.4 Verify the proper hardware is used for mounting the string inverter mounting brackets.	**Pass / Fail / N/A**
1.5 Verify the AC conduit stub-up connect directly to string inverter bottom openings.	**Pass / Fail / N/A**
1.6 Verify the PVC end bells are installed below and above grade.	**Pass / Fail / N/A**
1.7 Verify the string inverters are installed plumb and level.	**Pass / Fail / N/A**
1.8 Verify the above grade Unistrut conduit straps are correctly tightened.	**Pass / Fail / N/A**
1.9 Verify the conduits installed plumb, lock-nuts and bushings secure and properly seated.	**Pass / Fail / N/A**
1.10 Verify all components are free of damage.	**Pass / Fail / N/A**
1.11 Verify there are no open holes in the string inverter, thwarting any intrusions of wildlife entry.	**Pass / Fail / N/A**

String Inverter Install - Electrical

2.1 Verify all AC feeders & DC homeruns have been megger tested and results have been submitted to DEPCOM and have been approved.	**Pass / Fail / N/A**
2.2 Verify there are no fuses installed in the string inverter.	**Pass / Fail / N/A**
2.3 Verify the positive & negative homerun cables are properly connected to string inverter with the correct connectors.	**Pass / Fail / N/A**

2.4 Verify the AC feeder hardware components are UL listed for application.	**Pass / Fail / N/A**
2.5 Verify the AV feeder lug is properly crimped with the manufacturer approved crimp tool & die.	**Pass / Fail / N/A**
2.6 Verify there are gaps between insulation and lug.	**Pass / Fail / N/A**
2.7 Verify that the amount of exposed conductor between compression lug and insulation on AC feeders is per design.	**Pass / Fail / N/A**
2.8 Verify the heat shrink tubing is properly applied to AC feeder lugs.	**Pass / Fail / N/A**
2.9 Verify the AC feeder terminations are installed correctly, torqued and clearly marked. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.10 Verify the lock-nuts and bushings are fully tightened.	**Pass / Fail / N/A**
2.11 Verify the enclosure bonding lug is installed correctly, torqued and clearly marked. Details: Dimensions in Details:	**Pass / Fail / N/A**
2.12 Verify the approved foam seal is installed in all conduit entries.	**Pass / Fail / N/A**
2.13 Verify the proper slack in DC homerun cable has the correct service loop.	**Pass / Fail / N/A**
2.14 Verify the cables are managed in a neat, workmanlike manner, no bends are exceeding the bend radius of the cables per design.	**Pass / Fail / N/A**
2.15 Verify the label designation is correct.	**Pass / Fail / N/A**
2.16 Verify the correct circuits are installed in the correct inverters.	**Pass / Fail / N/A**
2.17 Verify the proper cable length for routing to correct fuse / final termination point.	**Pass / Fail / N/A**
2.18 Verify the components and conductors are free of any damage.	**Pass / Fail / N/A**
2.19 Verify the arc blast shield is installed on the AC side.	**Pass / Fail / N/A**
2.20 Verify the enclosure and internal components are clean and free of moisture.	**Pass / Fail / N/A**
2.21 Verify the door is closed and secured, and locked after inspection.	**Pass / Fail / N/A**
2.22 Verify the permanent labels are installed.	**Pass / Fail / N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Underground PCS Grounding Electrode and Equipment Grounding System Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers the grounding system of the PCS and equipment.		
Attachments			

Inspection

1.1 Verify the PCS ground ring conductor is #2/0, bare copper.	**Pass / Fail / N/A**
1.2 Verify the PCS ground ring from PCS skid frame on all sides is per design.	**Pass / Fail / N/A**
1.3 Verify PCS ground ring burial depth is per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.4 Verify all irreversible compression ground taps match part numbers in drawing for various conductor sizes and quantities.	**Pass / Fail / N/A**
1.5 Verify all irreversible compression ground taps are fully compressed.	**Pass / Fail / N/A**
1.6 Verify the copper clad ground rod is ¾" dia. X 10'-0" long, or as per design, and the part number matches the drawing.	**Pass / Fail / N/A**
1.7 Verify the irreversible compression ground rod connector matches the part number in drawing.	**Pass / Fail / N/A**
1.8 Verify the irreversible compression ground rod connectors are fully compressed per design.	**Pass / Fail / N/A**
1.9 Verify the grounding test well matches the part number in the drawing.	**Pass / Fail / N/A**
1.10 Verify the depth below grade of the grounding test well and the well cover is flush with the grade as per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.11 Verify the depth of clean sand fill within the test well is per design. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.12 Verify the ground test well mechanical ground rod connector matches the part number in drawing.	**Pass / Fail / N/A**

1.13 Verify the ground test well mechanical ground rod connector is correctly torqued, marked, and accessible. Details: Dimensions in Details:	**Pass** / **Fail** / **N/A**
1.14 Verify the PCS ground ring is bonded to equipment sub-base per design.	**Pass** / **Fail** / **N/A**
1.15 Verify the PCS enclosure is bonded to PCS grounding ring as required per PCS manufacturer manuals and per design.	**Pass** / **Fail** / **N/A**
1.16 Verify the cadweld inspections are submitted to DEPCOM when applicable.	**Pass** / **Fail** / **N/A**

DEPCOM Power
9185 E Pima Center Pkwy
Suite 100
Scottsdale, Arizona 85258
P: (480) 270-6910

Inspection Template: Wire Management Installation Inspection Report

Type	Quality	**Trade**	Electrical
Description	This inspection covers the installation and management of string harness apart of the DC collection system.		
Attachments			

Inspection

1.1 Verify the area is clear of debris and trash.	**Pass / Fail / N/A**
1.2 Verify the voltage rating of all DC cables match the eBOM and POs per design.	**Pass / Fail / N/A**
1.3 Verify the row configuration is as specified.	**Pass / Fail / N/A**
1.4 Verify sharp edges and pinch points on framing have been avoided.	**Pass / Fail / N/A**
1.5 Verify the module leads bend radius out of the diode do not place undue stress on cables. Details: Dimensions in Details:	**Pass / Fail / N/A**
1.6 Verify the module leads and string connectors are not forming the bottom of a drip loop.	**Pass / Fail / N/A**
1.7 Verify that the harnesses and string wire assemblies are free of kinks and jacket damage.	**Pass / Fail / N/A**
1.8 Verify that all slack is managed per design.	**Pass / Fail / N/A**
1.9 Verify the connectors, x/t joints, and in-line fuses are not secured to the metal structure.	**Pass / Fail / N/A**
1.10 Verify the harnesses, harness jumpers, and harness whips do not subject the connectors, x/t joints, or in-line fuses to tensile loads	**Pass / Fail / N/A**
1.11 Verify the bending radius of the cable is not compromised per design.	**Pass / Fail / N/A**
1.12 Verify the cable ties are installed at the specified distance away from the module connectors, x/t joints, and in-line fuses as per design.	**Pass / Fail / N/A**
1.13 Verify the tracker to tracker transition must has a cable tie at the specified distances per design. Details: Dimensions in Details:	**Pass / Fail / N/A**

1.14 Verify the cable ties are not over tensioned resulting in distortion to the wire assemblies.	**Pass** / **Fail** / **N/A**
1.15 Verify the quantity of lead wires in the cable tie are not over tensioned and the tensional load rating is not exceeding the manufacturing spec and are per design.	**Pass** / **Fail** / **N/A**
1.16 Verify cable ties are located on module frame, and oriented correctly per design, unless otherwise specified.	**Pass** / **Fail** / **N/A**
1.17 Verify the cable ties are trimmed and managed neatly and consistently.	**Pass** / **Fail** / **N/A**
1.18 Verify cable tie ends are not littered on the ground.	**Pass** / **Fail** / **N/A**
1.19 Verify correct quantity of circuits and conductor counts at end of each row is correct. Details: Dimensions in Details:	**Pass** / **Fail** / **N/A**
1.20 Verify the MC4 connectors are clean (no visible dirt or debris) and installed and connected, and seated correctly.	**Pass** / **Fail** / **N/A**
1.21 Verify that the CAB transitions are properly seated in CAB hangars in the designated channel.	**Pass** / **Fail** / **N/A**
1.22 Verify that the string labels are in place and adhere fully to the jacket of the cable.	**Pass** / **Fail** / **N/A**