

Distribution HV Substation Transformer Capacity & Load Information

NOTICE: This data is published for general information purposes only. This data is not intended to be relied upon by any third party for the purposes of decision-making and any such reliance will be at the user's own risk. Any prospective developers are advised to carry out their own due diligence prior to commencing a project.

NEITHER ESB NETWORKS LIMITED, ESB, NOR ANY PERSON ACTING ON ITS OR THEIR BEHALF:

(i) MAKES ANY REPRESENTATION, WARRANTY, OR UNDERTAKING (EXPRESS OR IMPLIED) WITH RESPECT TO THE ACCURACY OR COMPLETENESS OF THE INFORMATION CONTAINED IN THIS DOCUMENT OR THAT IT IS UP TO DATE AT ANY GIVEN TIME, OR

(ii) SHALL UNDER ANY CIRCUMSTANCES BE LIABLE, WHETHER IN CONTRACT, TORT (INCLUDING NEGLIGENCE), BREACH OF STATUTORY DUTY, MISREPRESENTATION (WHETHER INNOCENT OR NEGLIGENT) OR OTHERWISE, FOR ANY LOSSES, WHETHER DIRECT OR INDIRECT, FINANCIAL OR OTHERWISE, AND WHETHER OR NOT FORSEEABLE, ARISING AS A RESULT OF, OR IN CONNECTION WITH, THE USE OF, OR RELIANCE ON, ANY OF THE INFORMATION CONTAINED IN THIS DOCUMENT. ANY AND ALL SUCH LIABILITY IS EXPRESSLY EXCLUDED TO THE FULLEST EXTENT PERMITTED BY LAW.

110kV Substations

110kV Substation	Number of Transformers & MVA Rating: Number x Rating	Winter Peak (MW)	Summer Valley (MW)	Secondary Voltage Level
Ahane	1x12.5	4.87	1.04	10
Ardnacrusha	2x63	84.30	22.26	38
Arigna	1x15	4.51	1.49	20
Arklow	2x63	29.19	9.60	38
Arklow	2x20	8.79	1.93	10
Artane	2x20	16.39	4.01	10
Athlone	2x63	72.58	25.48	38
Athy	2x20	18.87	5.70	10
Ballybeg	2x20	14.46	4.20	10
Ballydine	1x30	11.50	3.19	38
Ballylickey	1x63	10.86	4.01	38
Baltrasna	2x20	14.48	4.15	20
Bandon	2x31.5	27.82	10.38	38
Bandon	1x20	5.51	1.96	10
Banoge	2x20	4.67	2.47	20
Barnahely	2x31.5	16.16	7.96	38
Barnahely	3x20	21.29	13.82	20
Barrymore	1x31.5	31.48	10.61	38
Bellacorrick	1x15	7.25	2.09	38

Bellacorrick	1x10	0.41	0.16	20
Binbane	2x63	30.14	2.22	38
Blackrock	2x63	73.74	25.10	38
Blake	1x31.5	28.01	8.65	38
Boggeragh	2x63	-	-	38
Butlerstown	2x31.5	39.99	11.46	38
Cabra	2x20	13.98	4.52	10
Cahir	2x31.5	26.82	8.70	38
Carlow	2x63	64.22	18.13	38
Carrick on Shannon	2x31.5	30.55	9.50	38
Carrickmines	2x63	74.04	18.53	38
Carrowbeg	1x31.5	20.31	11.12	38
Castlebar	2x31.5	35.34	9.76	38
Castlevew	2x31.5	24.56	10.90	10
Cathaleens Falls	1x31.5	19.72	6.55	38
Cauteen	2x63	-	-	38
Central Park	2x20	11.43	4.15	10
Charleville	1x30	19.95	6.17	38
City West	2x20	24.08	16.72	10
Cloon	1x30	26.29	6.66	38
College Park	3x20	24.04	15.83	10
Cookstown	2x63	47.34	15.70	38
Cookstown	2x20	15.38	5.39	10
Coolroe	2x20	12.15	6.70	20
Corderry	2x20	-	-	20
Cowcross	1x31.5	16.93	6.04	38
Crane	1x31.5	27.79	7.16	38
Crane	1x20	11.31	3.83	20
Crory	1x63	-	-	20
Dallow	1x31.5	18.41	4.85	38
Dalton	1x31.5	26.14	7.69	38
Doon	2x31.5	29.33	8.81	38
Drumline	1x31.5,1x30	31.09	13.02	38
Drybridge	2x63	89.62	26.28	38
Dundalk	2x63	67.62	20.14	38
Dunfirth	1x20	9.49	2.89	20
Dungarvan	1x30,1x31.5	29.70	12.96	38
Dunmanway	2x31.5	38.35	12.36	38
Ennis	2x31,5	35.45	16.30	38
Ennis	2x20	12.46	3.40	10
Fassaroe	2x63	59.80	19.27	38
Finglas	2x63	68.68	22.21	38
Finglas/McDermott (1)	2x63	74.66	23.58	38
Finglas/McDermott (2)	2x63	54.65	17.54	38
Galway	3x63	109.65	38.80	38
Galway	2x20	22.08	7.48	10
Garrow	1x20	-	-	20

Glasmore	2x63	84.60	28.64	38
Glenlara	2x31.5	14.31	4.51	38
Glenree	1x63	-	-	38
Gortawee	1x31.5	8.83	6.44	38
Grange	2x63	55.56	15.80	38
Grangecastle	1x63	56.32	20.35	38
Grangecastle	2x20	16.31	11.61	10
Great Island	1x31.5	15.58	5.17	38
Griffinrath	2x63	82.94	26.36	38
Harolds Cross	2x20	16.62	5.92	10
Ikerrin	1x31.5	33.02	11.38	38
Inchicore (North)	2x63	74.02	23.33	38
Inchicore/Francis St	2x63	55.82	15.07	38
Inchicore/Milltown	2x63	74.83	23.17	38
Kilbarry	2x63	79.87	11.85	38
Kilbarry	1x20	15.29	5.22	10
Kilkenny	2x63	61.67	17.61	38
Killoteran	2x20	13.14	7.25	10
Kilmore	3x20	18.60	13.19	10
Kilteel	2x31.5	36.69	9.25	38
Knockearagh	2x31.5	41.76	14.79	38
Lanesboro	1x31.5	17.05	4.73	38
Letterkenny	2x63	70.83	24.50	38
Liberty St	2x20	22.82	8.08	10
Limerick	2x63	76.26	28.60	38
Lisdrum	2x31.5	30.35	11.80	38
Macetown	2x20	27.42	10.13	10
Macroom	1x31.5	19.23	12.49	38
Mallow	2x31.5	24.15	7.45	38
Marina	2x20	16.01	4.75	10
Meath Hill	2x31.5	50.97	11.90	38
Midleton	1x31.5	35.72	11.01	38
Midleton	1x20	16.13	7.17	10
Milltown	2x20	20.30	8.09	10
Misery Hill	2x20	22.74	10.75	10
Monread	2x20	13.93	4.66	10
Moy	2x31.5	27.66	8.13	38
Mullingar	2x31.5	34.59	8.94	38
Mullingar	2x20	14.36	4.16	10
Navan	2x63	66.92	17.22	38
Nenagh	1x31.5	22.79	7.72	38
Newbridge	2x31.5	56.18	20.70	38
North Quay	2x20	16.01	5.52	10
Oughtragh	1x31.5	28.95	9.65	38
Pelletstown	2x20	16.60	4.26	10
Poppintree	2x20	20.37	6.26	10
Portlaoise	2x31.5	62.64	17.00	38

Pottery Road	2x20	15.86	5.38	10
Rathkeale	2x30	27.44	6.29	38
Reamore	2x63	-	-	38
Richmond	2x31.5	36.26	9.96	38
Ringaskiddy	1x12.5	3.92	0.90	10
Ringsend	2x20	8.47	5.99	10
Ringsend/Francis St	2x63	56.55	24.91	38
Ringsend/Milltown	2x63	70.67	30.90	38
Salthill	1x63	23.55	11.52	38
Salthill	2x31.5	27.32	9.51	10
Shankill (North)	2x63	61.18	13.83	38
Singland	2x20	14.16	5.00	10
Sligo	2x63	58.05	19.87	38
Somerset	1x31.5	20.51	6.26	38
Sorne Hill	1x20	-	-	20
Stratford	1x31.5	22.52	5.66	38
Taney	2x20	11.48	3.16	10
Thornsberry	2x63	34.14	10.61	38
Thurles	2x31.5	29.31	9.27	38
Tipperary	1x31.5	20.18	6.91	38
Tonroe	1x31.5	15.90	6.38	38
Trabeg	2x31.5	74.73	28.09	38
Trabeg	2x20	17.98	6.18	10
Tralee	2x63	50.07	14.72	38
Trien	2x31.5	25.98	0.06	38
Trien T143	1x63	-	-	38
Trillick	1x31.5	13.78	6.39	38
Trillick T142	1x31.5	-	-	38
Tullabrack	1x15	5.81	2.52	38
Waterford	1x31.5,1x63	64.77	22.26	38
Wexford	2x63	47.71	16.37	38
Wexford	1x20	9.48	2.93	20
Wolfe Tone	2x20	32.16	10.94	10

38kV Substations

38kV Substation	Number of Transformers & MVA Rating: Number x Rating	Winter Peak (MW)	Summer Valley (MW)	Secondary Voltage Level	Feeding 110kV Substation
Abbeyfeale	2x5	6.97	1.88	10kV	Trien
Abbeylands	2x10	10.69	2.50	10kV	Navan
Academy St	2x5,1x10	18.23	4.03	20kV & 10kV	Navan
Achill	1x5	2.76	1.36	20kV	Carrowbeg
Aghagad	2x5	2.63	0.80	10kV	Sligo
Aghamore	1x5,1x2	3.04	1.01	10kV	Lanesboro

Ardfinnan	2x5	3.78	0.75	10kV & 20kV	Cahir
Ardgeeha	2x5	8.89	2.51	10kV	Doon
Ardnaree	2x10	6.77	1.69	10kV & 20kV	Moy
Ashbourne	1x15,1x10	11.53	3.61	20kV	Finglas
Athboy	1x2,2x5	4.15	1.08	10kV & 20kV	Navan
Athenry	2x5	11.77	2.99	10kV	Galway
Athgarvan	2x10	16.84	7.28	10kV	Newbridge
Athlone	2x10	17.71	3.13	10kV	Athlone
Bagnalstown	2x5	9.02	2.11	10kV	Carlow
Bailieboro	2x5	6.03	1.12	10kV	Meath Hill
Balbriggan	1x5,1x10	10.69	3.24	10kV	Glasmore
Balgaddy	2x10	12.25	3.46	10kV	Grangecastle
Ballaghadereen	2x5	6.92	3.66	10kV	Tonroe
Ballinacurra	1x5,1x10	9.58	2.66	10kV	Limerick
Ballinasloe	2x5	5.73	1.60	10kV	Somerset
Ballinclea	1x10	4.74	1.19	10kV	Blackrock
Ballincollig	4x10	6.89	1.53	10kV & 20kV	Kilbarry
Ballinderry	2x10	14.71	3.94	10kV & 20kV	Mullingar
Ballinrobe	2x10	5.37	1.67	20kV	Dalton
Ballyard	2x5	6.55	1.81	10kV	Tralee
Ballybailie	1x5,1x2	4.92	1.35	10kV	Dundalk
Ballybay	1x5	4.72	2.10	10kV	Lisdrum
Ballybeggan	2x10	11.68	3.81	10kV	Tralee
Ballyboden	2x10	13.15	3.37	10kV	Cookstown
Ballybunion	2x5	3.68	1.33	20kV	Trien
Ballyconnell	2x5	8.18	2.56	20kV	Gortawee
Ballycoolen	3x10	14.82	7.03	10kV	Finglas
Ballycrossaun	2x5	4.90	1.78	20kV	Somerset
Ballydehob	1x5	2.84	1.21	20kV	Dunmanway
Ballygar	1x2,1x5	4.38	1.28	10kV	Athlone
Ballyhale	2x5	6.08	1.54	10kV & 20kV	Kilkenny
Ballyhaunis	2x5	9.14	2.64	10kV	Dalton
Ballyjamesduff	2x10	9.35	2.99	10kV	Shankill (North)
Ballymacarry	1x5	1.98	0.50	20kV	Trillick
Ballymahon	1x5	5.31	1.29	10kV	Athlone
Ballymote	1x5	3.45	0.63	10kV	Sligo
Ballymount	2x10	9.02	2.56	10kV	Inchicore (North)
Ballymun	2x10	10.20	2.93	10kV	Finglas/McDermott (2)
Ballyragget	1x5	5.64	1.32	10kV	Kilkenny
Ballyraine	2x5	8.43	2.19	10kV	Letterkenny
Ballyricard	2x10	11.94	3.43	10kV	Tralee
Ballyshannon	2x5	5.22	1.67	10kV	Cathaleens Falls
Ballytivnan	2x10	9.68	3.75	10kV	Sligo
Baltinglass	2x5	10.33	2.71	20kV	Stratford
Banagher	1x5,1x2	2.24	0.63	10kV	Dallow
Bangor-Erris	1x5	2.53	0.63	20kV	Bellacorrick
Bantry	2x5	6.60	2.32	10kV	Ballylickey

Barntown	1x5	1.72	0.43	10kV	Wexford
Beal Na Blath	1x10,1x5	4.07	1.49	20kV	Macroom
Bealstown/Campile	2x5	5.90	1.82	10kV	Great Island
Bedford Row T41,T42	2x15	13.33	5.66	10kV	Ringsend/Francis St
Bedford Row T43,T44	2x15	15.87	7.22	10kV	Ringsend/Francis St
Belfield	2x10	12.16	4.98	10kV	Blackrock
Belgard	2x10	9.89	3.34	10kV	Cookstown
Bellefield	2x10	7.57	1.76	10kV	Crane
Belmullet	1x5	3.72	1.05	10kV	Bellacorrick
Belview	1x5	3.47	0.60	20kV	Waterford
Birdhill	2x10	10.16	2.57	20kV	Ardnacrusha
Birr	2x10	11.45	2.80	10kV & 20kV	Dallow
Bishopstown	2x10	13.82	3.63	10kV	Kilbarry
Blake	2x5	8.10	2.94	10kV	Blake
Blessington	2x10	10.02	2.62	20kV	Newbridge
Boghall Road	2x10	9.91	3.64	10kV	Fassaroe
Boyle	2x5	5.92	1.68	10kV	Carrick on Shannon
Bray	2x10	15.57	3.38	10kV	Fassaroe
Brewery Road	2x10	8.80	3.24	10kV	Carrickmines
Bruff	2x5	4.68	1.30	10kV & 20kV	Ardnacrusha
Bunclody	2x5	6.10	2.06	20kV	Crane
Buncrana	2x5	8.73	2.28	20kV	Trillick
Bundoran	2x5	4.47	1.62	10kV	Cathaleens Falls
Bush	2x5	2.69	0.25	20kV	Dundalk
Bushfield	2x10	7.73	5.18	10kV	Athlone
Buttevant	2x2	4.86	1.60	10kV	Mallow
Cahir	2x10	8.61	2.86	10kV	Cahir
Cahircalla	2x5	7.69	2.07	10kV	Ennis
Cahirdavin	2x10	9.06	1.00	10kV	Ardnacrusha
Callan	2x5	5.98	1.41	10kV	Kilkenny
Camden Row	1x15	12.76	4.03	10kV	Inchicore/Francis St
Cappamore	2x5, 1x10	7.90	1.86	10kV & 20kV	Ardnacrusha
Carndonagh	2x5	5.37	1.50	20kV	Trillick
Carraroe	1x5	4.83	1.32	10kV	Galway
Carrick on Shannon	2x5	8.30	2.90	10kV	Carrick on Shannon
Carrickmacross	2x10	12.80	3.40	10kV	Meath Hill
Carrickmines	2x10	13.33	3.59	10kV	Carrickmines
Carrigaline	2x5	8.63	1.88	10kV	Barnahely
Carrigallen	1x5	3.28	1.01	20kV	Carrick on Shannon
Carriglawn	2x5	5.67	2.10	10kV	Wexford
Carrigshane	2x5	5.26	2.02	10kV	Midelton
Carrigtwohill	1x5	1.39	0.54	10kV	Cowcross
Carrowbeg	3x10	12.29	5.49	10kV & 20kV	Carrowbeg
Cartrontrouy	2x5	8.92	2.35	10kV	Athlone
Cashel	2x5	7.07	2.08	10kV	Cahir
Castleblaney	2x5	9.71	2.56	10kV	Dundalk
Castlecomer	2x5	6.38	1.56	10kV	Kilkenny

Castleisland	2x5	9.16	2.33	10kV	Tralee
Castleknock	2x5	4.63	0.53	10kV	Finglas
Castlelyons	2x5	6.38	1.53	20kV	Barrymore
Castlerea	2x5	4.85	1.42	10kV	Carrick on Shannon
Castletownbere	2x5	3.69	1.42	10kV & 20kV	Ballylickey
Castletownroche	1x5	1.78	0.71	10kV	Mallow
Castletroy	2x5	3.00	1.31	10kV	Limerick
Causeway	2x5	4.61	1.58	10kV	Tralee
Cavan	2x10	9.89	3.37	10kV	Shankill (North)
Celbridge	2x10	13.09	3.63	10kV	Griffinrath
Charlestown	1x5	3.24	0.91	10kV	Tonroe
Charleville	1x10	5.03	1.87	20kV	Charleville
Churchtown	2x10	4.97	0.99	10kV	Rathkeale
Clara	2x10	8.97	2.58	10kV & 20kV	Thornsberry
Claregalway	2x5	9.37	2.81	10kV & 20kV	Galway
Clifden	2x5	4.77	2.11	10kV	Galway
Clonakilty	2x5	9.38	2.50	10kV	Dunmanway
Clonard	2x5	5.75	1.30	10kV	Wexford
Clondalkin	3x10	21.94	3.89	10kV	Inchicore (North)
Clones	2x5	7.44	2.24	10kV	Shankill (North)
Clonminch	2x10	14.43	4.48	10kV & 20kV	Thornsberry
Clonroche	2x5	5.35	0.85	20kV	Wexford
Clonshaugh	3x10	3.08	1.40	10kV	Finglas
Clontarf	1x10	8.96	2.19	10kV	Finglas/McDermott (2)
Cloonbannin	1x5	3.32	0.88	10kV	Glenlara
Cloonlough	2x5	5.30	1.89	10kV	Barrymore
Cloyne	1x5	4.29	1.25	10kV	Mideltion
Cobh	2x5	8.21	1.88	10kV	Cowcross
Coes Road	2x5	5.41	1.50	10kV	Dundalk
Colligan	2x10	7.61	1.86	10kV	Dungarvan
Collinstown	2x5	2.18	1.13	10kV	Grange
Collooney	2x5	7.54	2.02	10kV & 20kV	Sligo
Cong	2x5	4.97	1.03	20kV	Cloon
Convoy	1x5,1x2	3.67	0.94	10kV	Letterkenny
Coolcarron	1x5,1x2	3.98	0.61	10kV	Barrymore
Coolcorcoran	2x10	11.75	5.73	10kV	Knockearagh
Coolgreaney Rd	2x5	1.41	0.36	10kV	Arklow
Coolmine	2x10	17.59	4.71	10kV	Finglas
Coolock	2x10	8.17	2.36	10kV	Finglas/McDermott (2)
Corbally	2x5	4.16	0.91	10kV	Ardnacrusha
Cranmore	2x5	7.60	3.00	10kV	Sligo
Cranny	1x2	0.92	0.21	10kV	Ennis
Cratloe	2x5	5.48	1.63	20kV	Ardnacrusha
Creagh	2x5	10.14	3.69	20kV	Athlone
Creaslough	1x5	1.91	0.68	20kV	Letterkenny
Cregg Road	2x2	3.87	1.24	10kV	Ballydine
Crossmolina	1x2,1x5	3.20	0.94	10kV	Moy

Crumlin	2x10	12.28	5.19	10kV	Inchicore/Milltown
Cullion	2x5	10.89	2.75	10kV	Letterkenny
Curra	1x5	2.12	0.50	10kV	Somerset
Curraglass	1x5	1.67	0.41	10kV	Barrymore
Curraleigh	2x5	6.64	2.09	20kV	Kilbarry
Dalton	2x10	9.26	2.67	20kV	Dalton
Deansgrange	2x10	7.98	2.12	10kV	Carrickmines
Deerpark	2x5	6.75	2.12	10kV	Ballydine
Delvin	1x2,1x3.2	4.12	0.94	10kV	Mullingar
Dennehys Cross	2x15	17.49	7.50	10kV	Trabeg
Derrybeg	2x5	4.75	1.40	10kV	Binbane
Derrycramph	2x5	10.85	2.74	10kV	Shankill (North)
Dingle	2x5	5.33	2.24	10kV & 20kV	Oughtragh
Dock Road	2x5	5.46	2.35	10kV	Limerick
Dodder Road	1x10	5.81	1.36	10kV	Inchicore/Milltown
Donegal	2x5	9.21	2.94	10kV	Cathaleens Falls
Donnybrook	2x10	11.10	6.55	10kV	Ringsend/Milltown
Douglas	2x10	14.23	4.05	10kV	Trabeg
Drumbear	2x5	8.81	2.16	10kV	Lisdrum
Drumcondra	2x10	9.99	3.35	10kV	Finglas/McDermott (1)
Drumline	2x5	6.36	2.10	20kV	Drumline
Drumquin	1x5	3.36	0.83	10kV	Ennis
Drybridge	2x5	10.58	2.61	10kV	Drybridge
Duleek	2x5	6.40	3.07	20kV	Drybridge
Dun Laoghaire	2x10	9.41	3.25	10kV	Blackrock
Dundalk	2x10	10.80	2.41	10kV	Dundalk
Dundrum	2x10	15.26	3.98	10kV	Blackrock
Dungloe	1x2,1x5	4.21	1.20	10kV	Binbane
Dunleer	2x5	6.37	1.46	10kV	Drybridge
Dunmanway	1x10	2.26	0.64	20kV	Dunmanway
East Wall Road	2x10	5.57	3.86	10kV	Ringsend/Milltown
Edenderry	2x10	13.97	3.72	20kV	Blake
Edgeworthstown	2x10	9.74	1.50	20kV	Richmond
Emyvale	1x5	5.01	1.04	20kV	Lisdrum
Ennis North	2x5	8.44	2.72	10kV	Ennis
Enniscrone	2x5	3.21	1.30	20kV	Moy
Enniskeane	2x5	1.94	0.27	10kV	Bandon
Ennistymon	2x5	7.19	3.00	10kV	Ennis
Errigal	2x10	9.52	2.76	10kV & 20kV	Shankill (North)
Factory Cross	2x10	2.08	0.94	10kV	Barnahely
Fairhill	1x10	7.64	2.80	10kV	Kilbarry
Fairview	1x15	12.17	3.45	10kV	Finglas/McDermott (2)
Fermoy North	2x5	9.94	5.45	10kV	Barrymore
Ferns	1x10	3.44	0.64	20kV	Crane
Finisklin	2x5	4.83	2.64	10kV	Sligo
Finnea	2x5	6.00	1.84	20kV	Shankill (North)
Foxhole	2x10	12.08	3.69	20kV	Dungarvan

Foynes	1x5,1x2	4.92	1.13	10kV	Rathkeale
Garden City	2x5	6.78	2.63	10kV	Arklow
Garranacanty	2x10	9.41	3.31	20kV	Tipperary
Garryowen	2x5	7.09	1.21	10kV	Limerick
Garryspillane	1x5	4.81	1.42	10kV	Tipperary
Garville Avenue	1x10	8.36	2.27	10kV	Inchicore/Milltown
Gilloge	2x5	5.75	1.73	10kV	Ardnacrusha
Glasmore	2x10	16.31	6.36	20kV	Glasmore
Glasnevin	1x10	6.93	1.90	10kV	Finglas/McDermott (1)
Glebe	2x10	9.56	3.56	10kV	Richmond
Glengarriff	1x5	0.72	0.33	20kV	Ballylickey
Glengooie	1x2,1x5	5.48	1.55	10kV	Thurles
Glennamaddy	1x5	4.71	1.22	20kV	Athlone
Glenties	1x5,1x2	3.55	1.37	10kV	Binbane
Gloucester Place	2x10	12.90	3.82	10kV	Finglas/McDermott (1)
Goresbridge	2x5	5.97	1.34	10kV	Kilkenny
Gort	2x5	6.58	1.65	10kV	Ennis
Gorteen	1x5	1.58	0.40	10kV	Tonroe
Gortlee	2x5	7.58	2.03	10kV	Letterkenny
Graigue	2x10	11.13	2.84	10kV	Carlow
Graiguenamanagh	2x2	4.01	0.80	10kV	Kilkenny
Granagh	2x5	6.46	2.52	10kV	Waterford
Granby Row	1x10	6.32	1.99	10kV	Finglas/McDermott (1)
Grange	2x10	20.09	6.30	10kV	Grange
Grange (South)	3x5	9.57	2.01	10kV & 20kV	Butlerstown
Greenhills	1x10	7.01	2.04	10kV	Inchicore/Milltown
Greystones	2x10	13.90	3.95	10kV	Fassaroe
Gurranbane	2x5	6.31	2.91	20kV	Oughtragh
Gweedore	1x5	2.07	0.70	20kV	Letterkenny
Headford	2x2	4.98	1.15	10kV	Cloon
Headford Road	2x10	13.41	4.07	10kV	Galway
Holycross Road	2x5	8.77	2.19	10kV	Thurles
Howth Junction	2x10	10.63	2.30	10kV	Grange
Inch	2x5	2.23	0.93	20kV	Oughtragh
Inchicore Cen T43	1x10	3.58	1.12	10kV	Inchicore/Francis St
Inchicore Cen T45	1x10	6.29	1.98	10kV	Inchicore/Francis St
Inchicore Nth T41	1x10	6.23	1.34	10kV	Inchicore (North)
Jeninstown	1x5	4.60	1.33	20kV	Dundalk
Johnstown	2x10	12.67	4.45	10kV	Kilteel
Julianstown	2x5	11.66	2.30	20kV	Drybridge
Kanturk	2x5	8.23	2.40	10kV	Glenlara
Kells	2x5	6.29	1.74	10kV	Navan
Kenmare	2x5	4.11	1.52	10kV & 20kV	Knockearagh
Kilbarry	2x10	22.10	5.17	10kV	Kilbarry
Kilcar	1x5	2.45	0.87	10kV	Binbane
Kilcarragh	2x5	4.70	1.43	20kV	Butlerstown
Kilclogher	1x2,1x5	3.32	1.11	10kV	Dungarvan

Kilcock	2x10	10.12	2.65	20kV	Griffinrath
Kilcolgan	2x5	6.20	1.68	10kV & 20kV	Galway
Kilcoole	2x5	7.30	2.03	10kV	Fassaroe
Kilcullen	2x5, 1x10	9.61	2.60	10kV & 20kV	Stratford
Kildare	3x5	11.16	2.78	10kV	Newbridge/Portlaoise
Kilflynn	1x5	3.67	1.37	10kV	Tralee
Kilgarvan	1x5	1.32	0.58	20kV	Knockearagh
Kilkee	1x5	2.27	1.31	10kV	Tullabrack
Killacloyne	2x5,1x10	12.57	7.52	10kV	Midelton
Killeshandra	2x5	3.40	3.57	10kV	Gortawee
Killinick	2x10	9.42	3.52	20kV	Wexford
Killybegs	2x15	7.47	2.53	10kV	Binbane
Kilmacthomas	2x5	5.31	1.84	20kV	Dungarvan
Kilmagig	1x2,1x5	3.48	0.58	10kV	Arklow
Kilmallock	1x2,1x5	4.69	0.89	10kV	Charleville
Kilmartin	1x5	2.97	0.57	10kV	Arklow
Kilmeaden	1x5	1.45	0.38	10kV	Butlerstown
Kilmoney	1x10,1x5	8.91	2.46	10kV	Trabeg
Kilross Road	1x2,1x5	4.59	2.84	10kV	Tipperary
Kilrush	2x5	6.02	1.98	10kV	Tullabrack
Kilsaran	1x5	7.45	1.02	10kV	Drybridge
Kilshanny	2x2	3.65	1.02	10kV	Cahir
Kiltimagh	1x5	2.11	0.50	10kV	Castlebar
Kimmage	2x10	14.87	3.39	10kV	Inchicore/Milltown
Kingsbridge	2x10	13.71	6.94	10kV	Inchicore/Francis St
Kingscourt	2x10	7.54	2.25	10kV	Meath Hill
Kinsale	2x5	10.37	3.40	10kV	Bandon
Knockaphunta	2x5	5.04	1.57	10kV	Castlebar
Knockbrogan	2x5	5.27	1.21	10kV	Bandon
Kyleeragh	1x10,1x5	8.35	2.47	10kV	Ardnacrusa
Kyletaun	2x5	9.49	3.13	10kV	Rathkeale
Lake	2x5	3.51	0.91	10kV	Dunmanway
Lawlesstown	2x10	11.72	3.47	10kV & 20kV	Doon
Lee Bridge	1x10,1x5	11.01	4.31	10kV	Macroom
Leeson Street	2x10	14.76	5.50	10kV	Ringsend/Milltown
Leixlip	2x10	14.32	5.71	10kV	Griffinrath
Liffey Valley	2x10	9.45	2.95	10kV	Inchicore (North)
Lisdrum	1x5	2.61	2.16	20kV	Lisdrum
Lismore	2x2	3.81	1.03	10kV	Dungarvan
Little Bray	2x10	9.26	4.37	10kV	Fassaroe
Little Island	2x2	1.84	0.46	10kV	Cowcross
Little Mills	1x5	3.42	1.06	10kV	Dundalk
Lloyd	2x5	1.88	0.19	10kV	Navan
Longford	2x10	12.39	3.00	20kV	Richmond
Loughanalla	2x5	6.24	1.62	10kV	Mullingar
Loughlinstown	2x10	13.99	4.58	10kV	Carrickmines
Loughrea	2x5	8.78	2.27	10kV	Somerset

Loughshinney	2x10	11.25	3.06	10kV	Glasmore
Loughtagalla	2x5	7.49	2.06	10kV	Thurles
Lucan East	2x5	9.77	1.89	10kV	Grangecastle
Lumcloon	2x5	2.83	0.69	20kV	Dallow
Macroon	1x5	2.88	0.69	20kV	Macroon
Malahide	2x10	14.53	3.74	10kV	Grange
Mallow	2x10	9.00	2.23	10kV	Mallow
Manor Street	2x10	13.44	4.36	10kV	Waterford
Manorhamilton	1x15, 1x5	4.66	2.01	20kV	Sligo
Marrowbone Lane	1x15	9.62	3.19	10kV	Inchicore/Francis St
Marshes	3x10	9.99	2.75	10kV & 20kV	Dundalk
Mayfield	2x10	9.32	2.37	10kV	Kilbarry
McDonagh	2x10	10.89	2.96	10kV	Kilkenny
Merrion Square	2x10	9.04	3.98	10kV	Ringsend/Milltown
Merville	2x10	8.69	2.02	10kV	Finglas/McDermott (1)
Milford (North)	2x5	9.26	2.93	10kV	Letterkenny
Milford (South)	1x5	4.63	1.66	10kV	Charleville
Milltown (South)	2x10	12.00	3.10	20kV	Oughtragh
Miltown Malbay	1x5	2.53	0.86	10kV	Tullabrack
Moate	1x2,1x5	4.19	0.97	10kV	Athlone
Mohill	2x5	5.35	1.48	20kV	Carrick on Shannon
Moneenageisha	2x10	9.14	3.78	10kV	Galway
Moneycooly	3x10	18.06	4.84	10kV	Griffinrath
Monfin	2x2	2.43	0.73	10kV	Wexford
Monkstown	2x10	14.06	4.37	10kV	Blackrock
Mornington Road	2x10	12.52	3.89	10kV	Drybridge
Morristown	2x5	9.04	1.52	10kV	Newbridge
Mount Merrion	2x10	12.90	2.47	10kV	Carrickmines
Mount Misery	2x5	6.87	2.53	10kV	Waterford
Mountgorry	2x10	16.70	5.15	10kV	Glasmore
Mountmellick	2x5	5.89	1.49	10kV	Portlaoise
Mountrath	2x5	4.94	1.47	10kV	Portlaoise
Moville	2x5	4.37	1.53	20kV	Trillick
Moy	2x10	10.00	2.19	20kV	Moy
Moylish	2x5	5.90	1.29	10kV	Ardnacrusha
Mulgannon	2x10	12.56	5.59	10kV	Wexford
Mullagh	3x5	8.05	1.18	10kV	Meath Hill
Naas	2x10	10.26	3.55	10kV	Kilteel
Nenagh	3x10	12.95	5.52	10kV & 20kV	Ardnacrusha
New Ross	2x5	9.69	3.35	10kV	Great Island
Newbrook	1x5	4.01	0.91	10kV	Mullingar
Newcastlewest	2x5	5.38	2.09	10kV	Rathkeale
Newmarket (Dublin)	1x10	10.18	2.21	10kV	Inchicore/Francis St
Newmarket (South)	2x5	2.76	1.23	10kV	Glenlara
Newport	2x5	3.71	0.91	20kV	Carrowbeg
Newtowncunningham	2x5	5.72	1.73	10kV	Letterkenny
Oakfield	2x10	10.58	2.42	10kV	Sligo

Old Bawn	2x10	15.21	3.09	10kV	Cookstown
Oldcastle	2x5	3.64	0.82	10kV & 20kV	Mullingar
Oranmore	2x5	9.25	4.56	10kV	Galway
Oughterard	2x5	4.93	1.33	10kV	Galway
Pallas	2x5	10.97	2.58	10kV	Portlaoise
Palmerstown	2x10	13.16	3.55	10kV	Finglas
Parkmore	2x5	7.53	3.77	10kV	Galway
Patrickswell	2x5	8.53	2.10	20kV	Limerick
Pembroke	4x10	24.19	4.54	10kV	Ringsend/Milltown
Phibsboro	2x10	10.14	4.54	10kV	Finglas/McDermott (1)
Pollerton	2x10	15.77	4.30	10kV	Carlow
Portarlington	3x5	15.28	3.75	10kV	Portlaoise/Blake
Portlaoise	2x10	18.70	5.86	10kV	Portlaoise
Portlaw	2x2	1.30	0.45	10kV	Butlerstown
Purcells Inch	1x10	3.63	1.28	10kV	Kilkenny
Rahans	1x5	2.16	1.33	10kV	Moy
Raheen	2x10	16.07	5.25	10kV	Limerick
Ramparts	2x10	9.13	2.57	10kV	Dundalk
Ramstown	2x5	8.14	1.97	10kV	Crane
Randalstown	1x5	4.03	1.60	10kV	Navan
Rathdowney	1x5	3.36	1.21	10kV	Ikerrin
Rathdrum	1x5	3.37	1.38	10kV	Arklow
Rathgoggin	2x5	5.66	1.50	10kV	Charleville
Rathmore	2x5	5.94	1.69	10kV & 20kV	Knockearagh
Rathmullan	2x10	12.99	3.35	10kV	Drybridge
Recess	1x5	1.12	0.40	10kV	Galway
Rineanna	2x10	10.40	5.76	10kV	Drumline
Ringaskiddy T41	1x10	3.92	0.90	10kV	Barnahely
Riverstown	2x5	7.68	2.17	10kV	Kilbarry
Roches Street	2x10	8.84	3.95	10kV	Limerick
Roosky	1x5	2.56	0.66	10kV	Richmond
Rosbercon	1x2,1x5, 1x10	4.64	1.28	10kV & 20kV	Waterford
Roscommon	2x10	12.27	5.94	10kV	Lanesboro
Roscrea	2x10	12.20	4.42	10kV	Ikerrin
Rosehill	2x10	14.50	3.79	10kV	Kilkenny
Rosgier	2x5	5.67	1.32	10kV	Letterkenny
Rosscarbery	2x5	3.92	1.79	10kV	Dunmanway
Saggart	2x5	9.43	3.29	10kV	Grangecastle
Sallins	2x10	11.51	2.99	10kV	Griffinrath
Sallynoggin	2x10	11.68	2.89	10kV	Blackrock
Sandyford	2x10	12.18	3.73	10kV	Carrickmines
Santry	2x10	11.13	3.73	10kV	Finglas/McDermott (2)
Scariff	1x5	3.21	0.82	10kV	Ennis
Scarteen	2x5,1x2	6.60	2.21	10kV	Mallow
Screebe	1x5,1x2	1.82	0.63	10kV	Galway
Semperit	3x10	19.62	9.48	10kV	Grangecastle
Shannon	2x10	11.87	2.53	10kV	Drumline

Shercock	2x5	4.52	0.93	10kV	Meath Hill
Sheriff St.	2x10	9.29	4.11	10kV	Ringsend/Francis St
Shillelagh	2x5	6.76	3.05	20kV	Carlow
Skibbereen	2x5	7.31	2.58	10kV	Dunmanway
Slane	1x10,1x5	5.36	0.73	10kV & 20kV	Drybridge
Smearla	2x10	9.92	3.08	10kV	Trien
South Hill	1x10,1x5	10.92	2.51	10kV	Limerick
South King Street	2x10	10.86	4.38	10kV	Ringsend/Francis St
Spa Road	2x5,1x2	5.85	1.77	10kV	Doon
Spiddal	1x5,1x2	4.76	1.89	10kV	Galway
Springs	2x10	6.88	2.68	20kV	Dungarvan
Srah	2x5,1x10	8.13	2.78	10kV	Thornsberrry
Stickillen	2x5	4.68	0.90	10kV	Drybridge
Stranorlar	2x10	9.08	2.26	20kV	Letterkenny
Sutton	2x10	6.82	2.31	10kV	Grange
Swinford	2x5	6.68	2.19	10kV	Castlebar
Swords	2x10	13.36	7.62	10kV	Glasmere
Talbot's Inch	2x5	5.61	2.16	10kV	Kilkenny
Telaydon	2x10	6.95	1.91	10kV & 20kV	Lisdrum
Templemore	2x10	7.19	2.19	10kV	Ikerrin
Templeogue	2x10	13.35	2.55	10kV	Inchicore/Milltown
Termonfeckin Road	2x5	9.26	2.62	10kV	Drybridge
Timoleague	1x5	4.79	1.55	10kV	Dunmanway
Tinahask	2x5	7.48	2.37	10kV	Arklow
Togher	2x10	12.22	3.89	10kV	Trabeg
Toomevara	1x5	3.93	1.22	10kV	Ikerrin
Tramore	2x10	10.94	3.12	10kV	Butlerstown
Trim	3x5	13.83	3.58	10kV & 20kV	Navan
Trimms Lane	2x10	10.63	3.77	10kV	Galway
Tuam North	2x5	10.18	3.24	10kV	Cloon
Tuam South	1x5	4.76	1.67	10kV	Cloon
Tubbercurry	1x2,1x5	2.64	0.68	10kV	Tonroe
Tulla	2x5	5.31	1.86	10kV	Ennis
Tullow	2x10	9.32	3.31	20kV	Carlow
Tullynamalra	1x5	4.77	2.20	10kV	Meath Hill
Turlough Road	3x5	6.35	1.48	10kV	Castlebar
Tycor	2x5	5.74	1.62	10kV	Waterford
Tymon	2x10	11.56	2.59	10kV	Cookstown
Unidare	2x10	7.42	2.55	10kV	Finglas/McDermott (1)
Virginia	2x5	5.73	2.57	10kV	Shankill (North)
Waterford	2x5	3.24	0.97	10kV	Waterford
Waterford Ind Est	3x10	9.08	2.36	10kV	Butlerstown
Watling Street T41	1x10	3.44	1.69	10kV	Inchicore/Francis St
Watling Street T42	1x10	3.91	2.07	10kV	Inchicore/Francis St
Westport	2x10	6.60	2.96	20kV	Carrowbeg
Whitechurch	2x10	11.23	2.69	20kV	Kilbarry
Whitehall	1x10	7.03	1.84	10kV	Finglas/McDermott (1)

Whitestown	2x10	9.76	2.93	10kV	Cookstown
Windsor Road	2x5	4.64	2.23	20kV	Castlebar
Woodford	2x5	10.39	3.60	10kV	Knockearagh