

***ATTACHMENT "A" & "B"**

STREET LIGHTING NOTES TO THE CONTRACTOR

The contractor shall protect and maintain all street lighting facilities existing in the work area. Should any damage to the street lighting system occur, the contractor shall immediately notify the Bureau of Street Lighting, Field Operations Division at (323) 913-4744. After 4:30 PM Monday through Thursday, or 3:30 PM on Friday, contact the Electric Trouble Board of the Department of Water and Power at (800) 821-5278 from the (213) area code, or (800) 821-5279 from the (818) area code.

The contractor shall arrange for the immediate repair and restoration of the damaged street lighting system at no cost to the City. A licensed electrical contractor is required to make all repairs necessary to the street lighting facilities.

The contractor shall install all proposed facilities 12 inches clear of the street lighting foundations, pullboxes, and conduits, except where otherwise stated herein. Two business days prior to working near the street lighting circuit the contractor shall arrange for the presence of a City of Los Angeles, Public Works inspector, (213) 485-5080 or (818) 374-1188, to verify all clearance requirements are met. Where a conflict exists between the street lighting facilities and the proposed improvements, approval for relocation of the street lighting facilities may be obtained by contacting the Street Lighting Engineer at (213) 847-1459.

The contractor shall proceed with extreme caution when working near the high voltage series circuit. Unauthorized work on the series circuit can result in severe injury or death. The contractor shall notify the Bureau of Street Lighting, Field Operations Division (323) 913-4744 two business days prior to working near the street lighting circuit.

This plan has been reviewed by the Bureau of Street Lighting and approved for the encroachment of new utilities within the Bureau of Street Lighting easement as specified hereon and within this plan:

of vault/cabinet locations: _____ # of conduit locations: _____

Linear footage of conduit: _____ If _____

Approved: _____

for

_____,
Executive Director, Bureau of Street Lighting

Date