

Question 1: Have there been any updates to the RFP document posted?

ANSWER: Yes, there have been several changes to the RFP, which are included in the current RFP document on the APCo Website in red-line format. The edited sections include the following:

- Section 5.5
- Section 5.7
- Section 8.1.11
- Section 10.1

Question 2: Can you please elaborate on what APCo is looking for when asking “expected annual availability(%)”?

Answer: APCo is looking for the percentage of time that the project that is being bid is expected to be available for operation.

$$\text{Expected Annual Availability (\%)} = \frac{\text{Hours in which the Facility is expected to be available to operate in any given year}}{8760}$$

Question 3: Is the RFP set for COD Date on 12/31/2021? Would APCo take earlier COD date? If so, how would you like that delivered in the RFP?

Answer: Section 8.1.7 of the RFP states that the project must have an estimated COD BY December 31, 2021. APCo will entertain bids with an earlier COD, but will not accept bids that have an estimated COD after 12/31/21. Please note that APCo will not give a Notice to Proceed until after it has received Regulatory Approvals for the project. Which is expected by May of 2020, but this is only an estimate and there are many variables that could change this.