


GRIDLOK BRACE - ISOMETRIC VIEW

TABLE 1 - PLENUM HEIGHT STUD SPECIFICATION

| PLENUM HEIGHT (mm) | BRACE STUD TYPE |
|--------------------|-------------------------------|
| 0-1600 | 64x0.50BMT LIPPED STUD |
| 1600-2000 | 92x0.75BMT LIPPED STUD |
| 2000-2600 | BOXED 64x0.50BMT LIPPED STUD |
| 2600-3000 | BOXED 92x0.75BMT LIPPED STUD |
| 3000+ | SPECIFIC ENGINEERING REQUIRED |

- NOTES:
1. INSTALL STUDS AS PER MANUFACTURER'S SPEC
 2. INSTALL GRIDLOCK AS PER MANUFACTURER'S SPEC
 3. WHERE BOXED STUDS ARE USED INSTALL AS PER MANUFACTURER'S SPEC
 4. SCREWED CONNECTION MIN SPACING AS SHOWN:

 5. REPRESENTATIVE ONLY. SEE BREVITY SPEC FOR DETAILS
 6. ANY CHANGES ON SITE TO BE APPROVED BY BREVITY

DESIGNER:

Brevity

Victoria Park Market,
Unit 72B,
210 Victoria Street West
Auckland 1010

+64 9 216 7104
www.teambrevity.com

| Tolerances (unless specified) | 1-100 | <1000 | >1000 |
|-------------------------------|-------|-------|-------|
| | ± 2 | ± 10 | ± 70 |



| Rev | Description |
|-----|-------------|
| A | FOR CONSENT |
| | |
| | |
| | |

| | | |
|----------|-------------|----------|
| Designed | BREVITY LTD | 16/01/23 |
| Drawn | BREVITY LTD | 16/01/23 |
| | | |
| | | |

GRIDLOK BRACE
SPECIFICATION DRAWING

| | |
|---------|--------------|
| Scale | Do not Scale |
| DRG No. | Sheet |
| 050-33E | 1 OF 1 |