



# SmartFlo™ System Sizing Pocket Guide

Curves and sizing information for all SmartFlo systems

## SQE Curves - 3,000 rpm to 10,700 rpm

---

<b>5SQE</b> System Curves.....	3 - 11
<b>10SQE</b> System Curves .....	12 - 17
<b>15SQE</b> System Curves .....	18 - 24
<b>22SQE</b> System Curves .....	25 - 30
<b>30SQE</b> System Curves .....	31 - 33

## Sections


---

<b>1. SQE Sizing Guide</b> .....	34 - 36
<b>2. CU331SP System Curves</b> .....	37 - 60
CU331SP Sizing Guide .....	61 - 62
<b>3. Technical Data</b> .....	63 - 64
<b>Cable Sizing</b> .....	65 - 66
<b>Friction Loss Table</b> .....	67 - 68

---

<b>4. NOTES</b> .....	69 - 74
-----------------------	---------

# SQE SmartFlo™ System Curves



SQE

Pressure  
Tank (2 gal.)


Pressure Sensor




CU 301




5SQE




5SQE




5SQE



5SQE




5SQE







5SQE




5SQE




5SQE




5SQE




10SQE




10SQE



10SQE




10SQE







10SQE




10SQE




15SQE




155QE




15SQE




155QE






15SQE

15SQE







15SQE




22SQE






22SQE


22SQE






22SQE


22SQE




22SQE



30SQE








30SQE

30SQE



# SQE SmartFlo™ System Sizing



Follow these 2 steps.

## STEP 1

Calculate maximum head requirements at rated flow conditions:

$H_{max} \text{ (required)} = \text{dynamic head} + \text{system pressure (in feet)} + \text{friction loss} + \text{above grade elevation.}$

## STEP 2


Select pump from the chart on the following page:

- Choose model family based on desired flow rate i.e. 15SQE for a flow rate of 15 gpm.

1

Continues on next page ➤


- Select the first model with a value in Column 2 that is greater than the Hmax calculated in Step 1.
- For example: the choice for a 22 gpm model with an Hmax of 140' would be the 22SQE-160. Double check your selection in the performance curve found in the front of this book.




Col. 1


Col. 2

System Sizing Matrix		
Pump Type Model B	Shutoff Head (0 GPM) @ 3000 RPM Min. Speed	Head @ Rated GPM @ 10700 RPM Max. Speed
	TDH(Feet)	TDH(Feet)
5SQE-90	12	104
5SQE-140	18	161
5SQE-180	24	218
5SQE-230	31	275
5SQE-270	37	332
5SQE-320	43	389
5SQE-360	49	446
5SQE-410	55	503
5SQE-450	61	560
10SQE-110	12	102
10SQE-160	17	158
10SQE-200	23	214
10SQE-240	29	270
10SQE-290	34	326
10SQE-330	40	382
15SQE-70	10	80
15SQE-110	14	121
15SQE-150	19	161
15SQE-180	24	202
15SQE-220	29	242
15SQE-250	33	283
15SQE-290	38	323
22SQE-40	5	35
22SQE-80	9	75
22SQE-120	14	115
22SQE-160	18	155
22SQE-190	23	195
22SQE-220	27	235
30SQE-40	5	31
30SQE-90	11	78
30SQE-130	16	125







TM05 6411 5012




TM056412 5012









TM05 64114 5012



TM05 64115 5012




TM05 6416 5012




TM05 6417 5012


2




TM05 6418 5012




TM05 6419 5012










TM05 6421 5012




TM05 6422 5012








TM05 6425 5012




TM05 6426 5012




TM05 6427 5012

2




TM05 6428 5012








TM05 6429 5012



TM05 6430 5012







TM05 6433 5012

# CU331SP SmartFlo™ System Sizing



Follow these 3 steps.

## STEP 1

Calculate maximum head requirements at rated flow conditions:

2

**H<sub>max</sub>** = dynamic head + system psi (feet) + friction loss + above grade elevation.

		Dynamic head
+		System psi (feet)
+		Friction Loss
+		Above grade elevation
=		<b>H<sub>max</sub></b>

## STEP 2

Select pump from performance curves as follows:

Select a model in which the calculated value of **H<sub>max</sub>** is within the maximum performance curve of the pump.

## STEP 3

Select the CU331SP that corresponds to the correct motor Hp and enclosure type.

CU331SP  
Variable  
Frequency  
Drive



2

### IMPORTANT NOTE:

**MUST BE USED WITH 3 PHASE MOTORS**

PUMP TYPE	HP	VOLTAGE	FULL LOAD AMPS	
			230V	115V
5SQE05-90	1/2	230V/115V	2.1	4.2
5SQE05-140	1/2	230V/115V	2.9	6.0
5SQE05-180	1/2	230V/115V	3.7	7.7
5SQE07-230	3/4	230V	4.6	
5SQE07-270	3/4	230V	5.3	
5SQE07-320	3/4	230V	6.2	
5SQE10-360	1	230V	7.2	
5SQE10-410	1	230V	8.1	
5SQE15-450	1 1/2	230V	9.2	
10SQE05-110	1/2	230V/115V	2.9	6.1
10SQE05-160	1/2	230V/115V	4.1	8.6
10SQE07-200	3/4	230V	5.3	
10SQE7-240	3/4	230V	6.0	
10SQE10-290	1	230V	7.7	
10SQE15-330	1 1/2	230V	8.9	
15SQE05-70	1/2	230V/115V	2.9	6.0
15SQE05-110	1/2	230V/115V	4.0	8.3
15SQE07-150	3/4	230V	5.1	
15SQE07-180	3/4	230V	6.2	
15SQE10-220	1	230V	7.4	
15SQE10-250	1	230V	8.4	
15SQE15-290	1 1/2	230V	9.7	
22SQE05-40	1/2	230V/115V	1.9	3.9
22SQE05-80	1/2	230V/115V	3.4	7.2
22SQE07-120	3/4	230V	4.9	
22SQE07-160	3/4	230V	6.4	
22SQE10-190	1	230V	7.9	
22SQE15-220	1 1/2	230V	9.5	
30SQE05-40	1/2	230V/115V	2.8	5.7
30SQE07-90	3/4	230V	5.2	
30SQE10-130	1	230V	7.6	



OVERLOAD AMPS		MIN. WELL DIA.	DISCHARGE
230V	115V		
5	11	3"	1" NPT
5	11	3"	1" NPT
5	11	3"	1" NPT
8		3"	1" NPT
8		3"	1" NPT
8		3"	1" NPT
11		3"	1" NPT
11		3"	1" NPT
12		3"	1" NPT
5	11	3"	1 1/4" NPT
8	11	3"	1 1/4" NPT
8		3"	1 1/4" NPT
8		3"	1 1/4" NPT
11		3"	1 1/4" NPT
12		3"	1 1/4" NPT
5	11	3"	1 1/4" NPT
5	11	3"	1 1/4" NPT
8		3"	1 1/4" NPT
8		3"	1 1/4" NPT
11		3"	1 1/4" NPT
11		3"	1 1/4" NPT
12		3"	1 1/4" NPT
5	11	3"	1 1/2" NPT
5	11	3"	1 1/2" NPT
8		3"	1 1/2" NPT
8		3"	1 1/2" NPT
11		3"	1 1/2" NPT
12		3"	1 1/2" NPT
5	11	3"	1 1/2" NPT
8		3"	1 1/2" NPT
11		3"	1 1/2" NPT

## Cable length selection tables

The following table (Fig. 7) lists the recommended copper cable sizes and various cable lengths for SQE motors. Proper wire size will ensure that adequate voltage will be supplied to the motor.

To assure adequate voltage, the maximum cable lengths are calculated for when the motor is running at maximum nameplate amps. Cable sizes larger than specified may always be used and will reduce power loss.

**The use of cables smaller than the recommended sizes will void the warranty. Smaller cable sizes may cause under-voltage alarms.**

Fig. 7

# SQ/SQE ONLY

Motor Rating		Copper Wire Size (AWG)									
Volts	HP	AMPS	14	12	10	8	6	4	2		
115	1/2	12	140	220	360	550	880	1390	2260		
230	1/2	5.2	640	1000	1660	2250	4060				
230	3/4	8.4	400	620	1030	1580	2510	3970			
230	1	11.2	300	460	770	1190	1890	2980	4850		
230	1 1/2	12	280	430	720	1110	1760	2780	4530		

Cable length is in feet

Note: The calculations in the table are based on supply of 115V or 230V

Max recommended cable length between the CU300/301 and SQE = 200m (656 ft)

## Friction Loss Table - SCH 40 Steel Pipe

(Friction Loss in Feet of Head Per 100 Feet of Pipe)

GPM	GPH	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"	4"
		ID 0.622"	ID 0.824"	ID 1.049"	ID 1.380"	ID 1.610"	ID 2.067"	ID 2.469"	ID 3.068"	ID 4.026"
2	120	4.8								
3	180	10	2.5							
4	240	17.1	4.2							
5	300	25.8	6.3	1.9						
6	360	36.5	8.9	2.7						
7	420	48.7	11.8	3.6						
8	480	62.7	15	4.5						
9	540	78.3	18.8	5.7						
10	600	95.9	23	6.9	1.8					
12	720		32.6	9.6	2.5	1.2				
14	840		43.5	12.8	3.3	1.5				
16	960		56.3	16.5	4.2	2				
20	1,200		86.1	25.1	6.3	2.9				
25	1,500			38.7	9.6	4.5	1.3			
30	1,800			54.6	13.6	6.3	1.8			
35	2,100			73.3	18.2	8.4	2.4			
40	2,400			95	23.5	10.8	3.1	1.3		
45	2,700				29.4	13.5	3.9	1.6		
50	3,000				36	16.4	4.7	1.9		
60	3,600				51	23.2	6.6	2.7		
70	4,200				68.8	31.3	8.9	3.6	1.2	
80	4,800				89.2	40.5	11.4	4.6	1.6	
90	5,400					51	14.2	5.8	2	
100	6,000					62.2	17.4	7.1	2.4	
120	7,200						24.7	10.1	3.4	
140	8,400						33.2	13.5	4.5	1.2
160	9,600						43	17.5	5.8	1.5
200	12,000						66.3	27	8.9	2.3
260	15,600							45	14.8	3.7
300	18,000							59.6	19.5	4.9

## Friction Loss Table - Valves and Fittings

(Friction Loss in Equivalent number of Feet of Straight Pipe)

TYPE OF FITTING AND APPLICATION	PIPE AND FITTING	NOMINAL SIZE OF FITTING AND PIPE						
		1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"
		EQUIVALENT LENGTH OF PIPE(IN FEET)						
Insert Coupling	Plastic	3	3	3	3	3	3	3
Threaded Adapter (Plastic to Thread)	Plastic	3	3	3	3	3	3	3
90° Standard Elbow	Steel	2	2	3	4	4	5	6
	Plastic	2	2	3	4	4	5	6
Standard Tee (Flow Through Run)	Steel	1	2	2	3	3	4	4
	Plastic	1	2	2	3	3	4	4
Standard Tee (Flow Through Side)	Steel	4	5	6	7	8	11	13
	Plastic	4	5	6	7	8	11	13
Gate Valve <sup>1</sup>	Steel	1	1	1	1	2	2	2
Swing Check Valve <sup>1</sup>	Steel	5	7	9	12	13	17	21

# Friction Loss Table - SCH 40 PVC

(Friction Loss in Feet of Head Per 100 Feet of Pipe)

GPM	GPH	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"	2 1/2"	3"	4"
		ID	ID	ID	ID	ID	ID	ID	ID	ID
		0.622"	0.824"	1.049"	1.380"	1.610"	2.067"	2.469"	3.068"	4.026"
2	120	4.1								
3	180	8.7								
4	240	14.8	2.2							
			3.7							
5	300	22.2	5.7	1.8						
6	360	31.2	8	2.5						
7	420	41.5	10.6	3.3						
8	480	53	13.5	4.2						
9	540	66	16.8	5.2						
10	600	80.5	20.4	6.3	1.7					
12	720		28.6	8.9	2.3	1.1				
14	840		38	11.8	3.1	1.4				
16	960		48.6	15.1	4	1.9				
20	1,200		60.5	22.8	6	2.8				
25	1,500			38.7	9.1	4.3	1.3			
30	1,800				12.7	6	1.8			
35	2,100				16.9	8	2.4			
40	2,400				21.6	10.2	3	1.1		
45	2,700				28	12.5	3.8	1.4		
50	3,000					15.4	4.6	1.7		
60	3,600					21.6	6.4	2.3		
70	4,200					28.7	8.5	3	1.2	
80	4,800					36.8	10.9	3.8	1.4	
90	5,400					45.7	13.6	4.8	1.8	
100	6,000					56.6	16.5	5.7	2.2	
120	7,200						23.1	8	3	
140	8,400						30.6	10.5	4	1.1
160	9,600						39.3	13.4	5	1.4
200	12,000						66.3	20.1	7.6	2.1
260	15,600							32.4	12.2	3.4
300	18,000							42.1	15.8	4.4

## NOTES:

Based on schedule 40 steel and plastic fittings.

Figures given are friction losses in terms of Equivalent Lengths of straight pipe.

1 Friction loss figures are for screwed valves and are based on equivalent lengths of steel pipe.

4









4



**GRUNDFOS Kansas City**

17100 West 118th Terrace  
Olathe, Kansas 66061  
Phone: (913) 227-3400  
Fax: (913) 227-3500

[www.grundfos.us](http://www.grundfos.us)

**GRUNDFOS Canada**

2941 Brighton Road  
Oakville, Ontario  
L6H 6C9  
Phone: (905) 829-9533  
Fax: (905) 829-9512

[www.grundfos.ca](http://www.grundfos.ca)

**GRUNDFOS Mexico**

Boulevard TLC No. 15  
Parque Industrial Stiva Aeropuerto  
C.P. 66600 Apodaca, N.L. Mexico  
Phone: 011-52-81-8144 4000  
Fax: 011-52-81-8144 4010

[www.grundfos.mx](http://www.grundfos.mx)