MILITARY SPECIFICATION

CIRCUIT BREAKERS (AUTOMATIC - ALB-1) AND SWITCH, TOGGLE
(CIRCUIT BREAKER, NON-AUTOMATIC - NLB-1) AIR, INSULATED HOUSING,
125 VOLTS AND BELOW, A.C. AND D.C., (NAVAL SHIPBOARD USE)

This amendment forms a part of MIL-C-17588E(SH), dated 26 November 1985, and is approved for use by the Naval Sea Systems Command, Department of the Navy, and is available for use by all Departments and Agencies of the Department of Defense.

PAGE 7

3.5.2, Table IV under Time - seconds: Delete "0.028" and substitute "0.400".

PAGE 11

Table VI: Delete and substitute:

"TABLE VI. Sampling for quality conformance inspection.

Number of items in lot offered for inspection	Number of items in sample
8 and under	2
9 - 15	3
16 - 25	5
26 - 40	8
41 - 65	13
66 - 110	20
111 - 180	25
181 - 300	30
301 - 500	40
Over 501	50

"

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:21Z
Check the source to verify that this is the current version before use.

PAGE 14

4.8.4.2, line 3 and 4: Delete "The maximum current value test shall be performed followed after a cooling period of at least 15 minutes, by the minimum current value test."

Preparing activity:
Navy - SH
(Project 5925-N114)

Source: https://assist.dla.mil -- Downloaded: 2026-10-18T10:21Z
Check the source to verify that this is the current version before use.