MILITARY SPECIFICATION
PANEL, DISTRIBUTION, BATTERY CHARGING

This Amendment forms a part of Military Specification MIL-P-52457B(ME), dated 15 July 1977.

PAGE 3

3.1.2, delete first two sentences and substitute:

"3.1.2 Design and operation. The panel contains two manually controllable 12 volts, 8 amps current limited charging stations for a reduced charge rate of individual 12 V batteries, two manually controllable 24 volts, 8 amps current limited charging stations for a reduced charge rate of two 12 V batteries connected in series, and eight non-controllable 24 volts, 20 amps current limited charging stations for series arrangements of two 12 V batteries. In addition, the panel may be used to charge non-standard 6 V batteries in series and non-standard 24 V batteries directly if required."

PAGE 5

3.10.1, delete and substitute:

"3.10.1 Low temperature operation. There shall be no breakage, deformation or degradation of any part, component or electrical connection that requires maintenance action prior to or during performance of the functional characteristics test specified in 4.6.1. The test shall be performed at an ambient temperature of minus 32° C (-25° F) and the temperature compensated trip range for all circuit breakers shall be 3 to 60 seconds. The panel shall then be operated for 30 minutes without failure in this same ambient environment. The test shall be performed as specified in 4.6.8."

PAGE 9

4.6.1 Functional characteristics; delete sentence in line 8 and substitute: "Connect a nominal 28 volt DC power source, uniformly adjustable from 26 to 32 volts, to the panel power connector."

4.6.1, add after line 10: "In performance of this test, adjust the voltage as required and trim the external resistance to achieve the currents specified."

4.6.1 (a) Designated load; delete sentence and substitute: "Load these stations with a nominal value resistor of 2.0 ohms having a minimum power rating of 300 watts that is series connected with the 3 ohm, 225 watt resistor contained in the panel."

FSC 6130

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:19Z
Check the source to verify that this is the current version before use.

4.6.1 (b)) Designated load; delete sentence and substitute: "Load these stations with a nominal value resistor of 2.3 ohms having a minimum power rating of 350 watts that is series connected with the 2 ohm, 150 watt resistor contained in the panel."

PAGE 13

Line 2: Change "2 hours" to "4 hours".

PAGE 15


6.1., delete and substitute:

"6.1. Intended use. These panels are intended to be used with the MEP Model 026A, 28 volt, 3 KW DC generator for charging standard 2 HN and 6 TN twelve volt lead acid batteries. This arrangement may be used in any area where charging capabilities using utility electric power are not available."

Custodians:
Army - ME

Preparing activity:
Army - ME

Project 6130-A203



Source: https://assist.dla.mil -- Downloaded: 202610-22T21:19Z
Check the source to verify that this is the current version before use.