MILITARY SPECIFICATION

GENERATOR SET, DIESEL ENGINE DRIVEN

200 KILOWATT, 50/60 HERTZ, UTILITY, (TACTICAL)

This amendment forms a part of Military Specification MIL-G-52884/14, dated 10 December 1975, and is approved for use by all Departments and Agencies of the Department of Defense.

PAGE 2

Delete paragraph 3.6.4 as written, and substitute:

"3.6.4 Transient performance. With the regulation set between 2.7 and 3 percent and following a sudden increase or decrease in load up to and including 50 percent of rated load, the governing system shall re-establish stable engine operating conditions within 3 seconds. For any such sudden decreases in load, the maximum transient frequency change above the new steady state frequency shall not be more than 4 percent of rated frequency. For any such sudden increases in load, the maximum transient frequency change below the new steady state frequency shall not be more than 3 percent of rated frequency. In addition, the circuit interrupter shall not trip when going from no load to rated load or rated load to no load with the Battle Short Switch in the normal (OFF) position."

Custodians:
Army - ME
Navy - YD
Air Force - 99

Review activity:
DLA - GS

Preparing activity:
Army - ME

Project 6115-0212

FSC 6115

Source: https://assist.dla.mil -- Downloaded: 2026-10-22T21:38Z
Check the source to verify that this is the current version before use.